

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月27日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.42	14.14	55.23	2.87	17.00	11.64	1.24	72630.97
1	8.55	13.99	58.26	3.26	17.12	11.58	1.24	73026.12
2	5.93	13.99	50.01	2.64	15.05	12.25	1.25	69912.44
3	6.44	13.50	53.30	1.92	16.62	11.62	1.24	74114.87
4	7.75	13.39	55.05	2.15	15.92	11.74	1.24	73414.95
5	6.86	13.48	51.05	3.12	15.56	11.82	1.23	76377.69
6	8.65	13.55	57.24	2.51	16.10	11.85	1.24	72192.71
7	6.93	13.43	58.71	2.45	16.09	11.76	1.24	73094.68
8	8.17	13.23	55.36	4.05	15.00	11.75	1.24	73642.25
9	8.18	13.66	52.24	3.68	14.81	11.98	1.24	71415.57
10	9.05	13.39	49.64	3.90	15.29	11.78	1.23	73377.99
11	3.89	14.47	68.30	2.78	14.67	12.56	1.24	67374.93
12	1.90	14.74	64.09	2.08	14.96	12.62	1.24	66796.28
13	1.85	13.31	40.19	1.83	15.40	11.70	1.22	73916.97
14	1.93	14.18	67.51	1.51	15.99	12.25	1.22	69298.16
15	5.47	13.67	57.59	1.38	16.03	11.89	1.23	71556.45
16	14.46	14.54	37.83	1.91	16.10	11.21	1.23	76746.10
17	16.53	13.38	39.29	2.77	16.27	11.47	1.23	74258.74
18	10.57	12.90	41.30	2.55	15.76	11.37	1.23	76002.34
19	7.23	13.32	50.12	2.15	16.20	11.63	1.23	73452.97
20	13.32	13.02	40.47	3.15	15.25	11.55	1.23	74622.60
21	11.40	13.95	51.11	3.13	15.34	11.71	1.24	73133.14
22	12.19	13.47	57.51	3.62	15.08	11.81	1.25	72285.09
23	16.74	14.48	40.21	3.97	14.97	11.93	1.25	71051.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.52	13.72	52.15	2.72	15.69	11.81	1.24	72653.97
最 大 值	16.74	14.74	68.30	4.05	17.12	12.62	1.25	76746.10
發生時間	23	12	11	8	1	12		16
最 小 值	1.85	12.90	37.83	1.38	14.67	11.21	1.20	66796.28
發生時間	13	18	16	15	11	16		12
零點偏移(率)	-0.16 %	-0.10 %	-0.13 %	-0.00 %		0.02	-0.01	0.30 %
全幅偏移(率)	-0.33 %	-0.35 %	-0.21 %	-0.26 %		0.49	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月27日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	2.57	12.16	54.94	0.76	20.28	9.99	0.97	87881.56
1	2.75	12.72	52.63	0.66	22.59	8.98	0.97	92513.09
2	2.30	13.24	48.36	0.89	18.91	10.32	0.95	85472.74
3	2.30	13.18	39.33	0.91	18.39	10.39	0.94	87370.59
4	2.23	12.20	50.17	0.77	18.31	10.35	0.94	87452.89
5	2.24	12.31	54.56	0.74	18.15	10.82	0.95	83910.40
6	2.67	12.14	45.98	0.83	18.18	10.51	0.94	86180.18
7	2.49	12.32	50.34	0.59	19.15	10.13	0.94	88343.42
8	2.34	12.08	52.69	0.68	18.56	10.33	0.94	86816.84
9	2.29	12.22	46.07	0.72	18.06	10.47	0.94	85844.98
10	2.41	12.70	60.84	0.41	18.92	10.75	0.94	82804.65
11	2.22	12.61	44.82	0.95	17.86	10.77	0.94	82988.68
12	2.35	13.50	62.29	0.65	19.17	10.30	0.94	85504.04
13	2.10	12.64	63.06	0.95	17.29	10.94	0.94	83187.46
14	1.90	12.70	54.98	1.35	16.99	10.64	0.94	86235.55
15	2.03	12.75	46.36	0.63	17.46	10.90	0.95	79581.09
16	2.03	12.54	38.14	0.82	18.22	10.03	0.94	85903.96
17	1.99	13.69	48.01	2.26	16.86	10.79	0.94	85332.28
18	2.32	12.80	55.52	1.68	17.42	10.94	0.94	83826.70
19	2.52	14.85	41.24	1.92	17.40	10.49	0.94	87220.93
20	3.59	14.05	39.94	1.72	16.11	11.10	0.94	83643.54
21	3.05	12.81	41.62	1.56	17.33	10.88	0.94	83596.40
22	3.96	12.36	46.48	0.99	18.85	10.11	0.94	88556.21
23	3.92	13.11	46.88	0.93	17.81	10.85	0.95	84060.45
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.52	12.82	49.39	1.02	18.26	10.49	0.94	85592.86
最 大 值	3.96	14.85	63.06	2.26	22.59	11.10	0.97	92513.09
發生時間	22	19	13	17	1	20		1
最 小 值	1.90	12.08	38.14	0.41	16.11	8.98	0.94	79581.09
發生時間	14	8	16	10	20	1		15
零點偏移(率)	-0.02 %	-0.02 %	-0.03 %	-0.01 %		0.01	-0.01	0.10 %
全幅偏移(率)	0.38 %	0.27 %	-0.24 %	0.50 %		-0.08	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月27日

報表日期: 114年10月27日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	11.96	12.78	48.75	1.75	17.74	8.81	1.40	80150.96
1	12.58	11.32	54.75	2.22	19.17	9.49	1.41	80243.81
2	10.66	12.97	54.79	1.92	18.36	9.45	1.41	79253.29
3	12.55	11.31	54.93	2.16	17.74	9.47	1.41	79993.80
4	10.49	11.04	54.33	1.97	17.91	9.58	1.43	81197.79
5	13.03	11.60	58.99	2.06	19.07	9.48	1.42	81204.92
6	10.97	11.76	54.58	1.83	18.36	9.48	1.41	81302.43
7	3.41	11.17	54.16	1.42	17.50	9.63	1.36	85184.49
8	10.87	11.45	54.24	1.95	17.29	9.70	1.36	79597.63
9	10.12	11.18	58.53	1.95	17.16	9.80	1.36	78003.88
10	10.93	11.08	60.59	2.12	18.16	9.52	1.37	80177.25
11	11.15	11.71	66.83	1.85	17.24	10.28	1.37	77963.25
12	8.25	11.55	57.60	1.67	18.18	9.75	1.39	77822.61
13	8.71	11.33	56.68	1.69	17.57	9.78	1.37	76453.68
14	5.93	11.21	54.90	1.39	17.90	9.61	1.36	77271.77
15	10.23	11.64	52.32	1.78	17.52	9.49	1.37	78142.38
16	10.71	12.22	60.73	1.78	18.91	9.31	1.38	82606.44
17	14.30	12.94	57.65	2.53	18.23	9.31	1.39	82387.81
18	11.37	12.37	52.90	2.58	17.30	9.13	1.37	77883.84
19	11.79	12.84	53.04	2.27	18.18	8.93	1.37	81453.75
20	12.12	12.36	53.23	2.11	16.53	9.48	1.39	76731.84
21	12.80	13.61	50.59	2.88	16.20	9.41	1.38	77150.52
22	15.09	1.45	50.80	0.05	16.90	9.04	1.37	76082.39
23	8.58	10.57	56.92	0.02	17.25	9.90	1.37	72491.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.78	11.39	55.53	1.83	17.77	9.49	1.38	79197.99
最 大 值	15.09	13.61	66.83	2.88	19.17	10.28	1.43	85184.49
發生時間	22	21	11	21	1	11		7
最 小 值	3.41	1.45	48.75	0.02	16.20	8.81	1.36	72491.23
發生時間	7	22	0	23	21	0		23
零點偏移(率)	-0.08 %	-0.08 %	-0.03 %	-0.00 %		-0.02	-0.01	0.00 %
全幅偏移(率)	0.14 %	1.01 %	1.32 %	-0.65 %		0.38	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								