

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月13日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.84	13.00	58.83	2.27	13.67	12.27	1.29	73680.99
1	9.20	13.18	63.53	1.89	14.40	12.59	1.29	71460.25
2	10.74	12.52	59.77	1.92	16.51	11.02	1.29	82967.78
3	14.61	15.02	44.49	2.87	14.25	11.48	1.31	81260.56
4	10.44	12.42	57.30	1.48	15.75	11.97	1.30	76679.47
5	9.74	12.80	52.22	3.50	16.14	11.39	1.29	88003.77
6	12.76	12.92	52.75	3.91	15.81	11.44	1.29	82363.34
7	8.93	13.11	41.12	2.54	14.37	11.83	1.26	77832.24
8	10.68	12.17	45.93	2.31	14.52	12.15	1.29	76018.95
9	9.70	11.69	56.47	2.22	15.94	11.51	1.30	79480.23
10	14.35	11.72	51.92	3.69	14.07	11.65	1.29	80327.68
11	7.26	12.65	43.67	4.51	13.44	11.97	1.29	76128.86
12	11.03	12.03	42.82	3.29	15.11	11.93	1.29	74340.13
13	8.67	11.42	41.12	2.84	15.53	11.36	1.29	79042.35
14	9.88	11.93	45.62	2.21	15.55	11.85	1.29	75056.34
15	10.06	12.35	46.82	3.02	15.52	11.58	1.29	76341.48
16	10.06	11.65	51.13	4.90	14.38	11.55	1.29	79245.23
17	11.53	11.93	51.14	3.16	12.87	12.03	1.29	75353.44
18	10.17	12.17	51.89	2.79	13.57	11.87	1.29	75440.54
19	11.96	12.35	54.07	2.76	14.82	11.39	1.29	75690.25
20	4.87	11.33	42.34	3.16	14.52	11.24	1.29	76518.23
21	10.71	11.72	53.70	3.13	16.21	11.22	1.29	78543.39
22	10.44	11.81	56.57	3.49	14.05	11.56	1.29	78228.70
23	8.93	13.17	52.73	1.89	14.33	12.71	1.28	69201.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.27	12.38	50.75	2.91	14.81	11.73	1.29	77466.88
最大值	14.61	15.02	63.53	4.90	16.51	12.71	1.32	88003.77
發生時間	3	3	1	16	2	23		5
最小值	4.87	11.33	41.12	1.48	12.87	11.02	1.26	69201.04
發生時間	20	20	7	4	17	2		23
零點偏移(率)	-0.11 %	-0.01 %	-0.06 %	0.00 %		-0.04	-0.01	0.30 %
全幅偏移(率)	-1.07 %	-1.42 %	-0.48 %	-1.32 %		0.03	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月13日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.34	11.97	45.31	1.43	16.05	10.63	1.06	75781.19
1	4.22	11.61	44.03	1.30	16.09	10.46	1.06	73485.15
2	5.24	11.95	47.28	1.86	14.69	10.95	1.06	72809.27
3	8.29	11.53	47.04	1.61	15.26	10.53	1.06	77753.21
4	8.86	11.65	51.35	1.48	15.17	10.66	1.06	76691.71
5	7.79	12.11	50.53	1.79	15.14	10.80	1.06	78433.47
6	11.01	12.07	53.49	1.67	15.97	10.98	1.04	77740.98
7	16.85	11.97	48.91	2.68	14.86	11.00	1.03	78028.37
8	13.29	12.01	49.06	2.84	14.30	11.12	1.05	77528.58
9	5.61	12.11	54.28	2.17	15.09	11.13	1.05	78745.44
10	10.29	11.91	53.02	2.85	15.06	10.96	1.06	78407.31
11	4.87	12.15	56.01	2.20	14.52	11.21	1.04	76168.81
12	7.12	11.75	52.21	1.61	15.22	10.81	1.05	77343.98
13	5.97	12.14	51.74	1.98	14.54	10.97	1.05	75916.12
14	5.90	11.89	55.37	1.89	14.42	10.96	1.06	76353.40
15	9.52	12.26	58.00	2.01	13.37	11.26	1.06	74138.19
16	5.39	11.92	56.59	1.85	13.41	11.12	1.05	75661.77
17	3.56	11.98	58.94	1.66	13.60	11.15	1.04	76836.67
18	7.13	11.75	65.18	1.86	14.84	10.86	1.05	79789.79
19	10.32	12.13	67.89	1.13	15.87	11.10	1.06	77756.46
20	9.85	12.07	48.44	1.92	14.11	11.02	1.06	79534.99
21	9.12	12.10	50.21	2.24	14.60	11.14	1.06	78960.29
22	8.77	11.86	42.47	1.30	16.06	10.81	1.06	78099.98
23	8.67	11.94	58.83	1.33	14.98	10.84	1.04	78616.76
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.17	11.95	52.76	1.86	14.88	10.94	1.05	77107.58
最大值	16.85	12.26	67.89	2.85	16.09	11.26	1.08	79789.79
發生時間	7	15	19	10	1	15		18
最小值	3.56	11.53	42.47	1.13	13.37	10.46	1.02	72809.27
發生時間	17	3	22	19	15	1		2
零點偏移(率)	-0.64 %	-0.08 %	-0.06 %	-0.01 %		-0.08	-0.01	0.10 %
全幅偏移(率)	-0.06 %	-0.04 %	0.29 %	-0.02 %		-0.02	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月13日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.09	11.54	54.71	3.04	15.97	9.85	1.41	74403.97
1	9.99	11.37	57.96	3.20	15.11	10.18	1.40	71582.44
2	10.02	11.19	60.97	3.38	16.10	9.98	1.40	71755.16
3	11.27	11.29	52.14	3.48	15.91	9.64	1.41	73917.61
4	8.53	11.12	57.26	3.02	15.54	10.10	1.40	71330.28
5	8.68	11.93	68.06	3.31	15.37	10.83	1.41	68224.38
6	6.76	12.46	49.36	3.47	16.02	10.48	1.42	71402.11
7	8.20	11.55	63.75	3.59	15.19	10.23	1.43	74080.61
8	9.90	11.20	54.96	1.89	14.69	10.34	1.43	71336.01
9	8.91	10.90	46.92	1.76	15.00	9.98	1.43	71597.86
10	10.06	11.41	48.70	1.87	15.56	9.83	1.42	71312.07
11	9.40	11.06	50.50	1.66	15.36	9.91	1.41	70668.82
12	10.30	10.98	48.41	1.66	16.06	9.77	1.41	71162.93
13	8.42	10.88	48.52	1.51	15.49	9.60	1.40	70955.94
14	10.24	10.98	48.10	1.55	14.48	9.94	1.37	68904.22
15	8.80	11.37	54.87	2.65	14.66	9.94	1.36	69649.59
16	8.78	11.39	53.73	3.09	15.02	9.64	1.36	71933.70
17	10.08	10.93	54.19	2.66	16.49	9.65	1.38	73528.77
18	8.98	11.12	54.21	2.76	15.66	9.91	1.38	72915.40
19	9.52	14.42	50.51	2.81	15.72	9.59	1.39	71462.94
20	7.44	13.60	47.06	3.37	14.16	9.29	1.39	68794.46
21	12.07	11.29	59.03	2.01	13.72	10.57	1.37	73919.41
22	12.08	11.37	61.01	3.35	12.75	10.84	1.39	72940.85
23	8.86	11.97	62.87	4.08	13.05	11.28	1.39	69376.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.52	11.56	54.49	2.72	15.13	10.06	1.40	71548.16
最大值	12.08	14.42	68.06	4.08	16.49	11.28	1.43	74403.97
發生時間	22	19	5	23	17	23		0
最小值	6.76	10.88	46.92	1.51	12.75	9.29	1.36	68224.38
發生時間	6	13	9	13	22	20		5
零點偏移(率)	-0.11 %	0.00 %	-0.22 %	0.00 %		-0.07	-0.01	0.00 %
全幅偏移(率)	0.01 %	0.33 %	0.09 %	-0.11 %		0.00	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								