

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年3月8日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.94	4.00	42.95	3.81	13.29	12.63	1.39	68460.29
1	9.75	2.21	43.99	3.45	13.52	12.47	1.41	69626.53
2	9.50	2.27	43.34	2.87	14.61	12.42	1.45	68792.70
3	3.11	4.31	56.74	3.04	14.13	13.48	1.50	61306.67
4	1.61	3.10	45.30	2.50	14.48	12.47	1.43	69339.10
5	4.41	11.50	66.70	2.98	14.23	13.17	1.42	64194.63
6	3.01	5.47	51.48	2.91	14.16	12.75	1.42	67242.65
7	9.64	4.34	52.29	2.51	15.22	11.91	1.41	72870.51
8	9.80	4.50	48.12	3.19	14.23	12.48	1.45	69486.77
9	6.66	5.52	59.44	2.30	15.12	12.15	1.42	71300.04
10	7.86	5.63	47.59	3.07	13.64	12.44	1.46	70073.46
11	8.34	5.39	51.68	2.96	14.22	12.33	1.44	69943.69
12	9.32	5.42	60.08	2.90	14.64	12.44	1.47	69216.90
13	11.86	6.05	52.57	3.40	13.67	12.58	1.42	68726.85
14	7.40	20.07	59.29	3.29	13.69	13.02	1.41	66316.44
15	2.15	14.12	46.35	3.03	14.24	12.34	1.51	69857.70
16	1.19	12.59	48.77	3.44	13.69	12.46	1.52	69436.25
17	3.02	2.24	61.03	3.37	13.82	12.49	1.54	69213.98
18	3.96	3.58	51.01	3.73	13.45	12.46	1.51	69218.18
19	10.11	3.30	59.76	3.98	14.17	12.42	1.48	69339.65
20	2.56	4.45	59.30	2.87	14.89	12.29	1.47	69685.66
21	10.49	9.63	60.26	3.66	14.49	12.20	1.50	71211.89
22	8.77	3.82	55.47	3.52	14.08	12.38	1.46	69468.53
23	8.97	3.97	51.79	3.84	13.56	12.53	1.44	68752.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.81	6.14	53.14	3.19	14.14	12.51	1.46	68878.38
最大值	11.86	20.07	66.70	3.98	15.22	13.48	1.74	72870.51
發生時間	13	14	5	19	7	3		7
最小值	1.19	2.21	42.95	2.30	13.29	11.91	1.38	61306.67
發生時間	16	1	0	9	0	7		3
零點偏移(率)	-0.10 %	-0.08 %	-0.05 %	0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	1.71 %	0.74 %	-1.14 %	0.16 %		0.08	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年3月8日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.12	3.69	45.40	2.29	16.14	10.86	1.38	82445.49
1	3.68	4.17	49.81	1.53	16.89	10.67	1.38	84176.92
2	10.03	4.25	49.48	1.86	18.16	10.35	1.41	86760.77
3	6.58	3.70	52.19	1.63	18.63	10.83	1.44	80364.73
4	9.58	3.61	42.33	2.50	18.18	10.09	1.44	84573.44
5	11.06	5.88	43.95	2.80	16.88	10.37	1.43	83660.69
6	10.21	3.65	51.30	2.61	15.95	10.83	1.43	82516.09
7	10.21	3.36	54.47	2.13	17.37	10.47	1.43	86764.69
8	7.78	4.41	52.56	2.07	16.62	10.76	1.43	83608.15
9	7.39	3.59	54.65	2.02	16.60	10.79	1.39	83812.79
10	12.04	5.05	57.00	2.64	14.87	11.06	1.40	82914.97
11	11.47	6.78	56.46	3.16	14.55	10.87	1.40	80480.90
12	10.88	4.01	54.41	2.91	16.96	10.47	1.38	80703.20
13	11.72	4.71	46.06	2.82	15.90	10.66	1.38	79013.68
14	2.78	16.81	63.45	2.07	14.51	11.39	1.38	76665.51
15	校正	校正	校正	校正	替代	校正	1.44	74189.54
16	8.19	13.98	57.43	2.62	15.56	10.59	1.46	80280.98
17	8.10	2.41	46.17	2.12	16.27	10.53	1.47	82813.46
18	10.37	3.02	52.92	2.08	17.46	10.22	1.49	86000.38
19	9.30	3.22	55.05	2.18	16.48	10.67	1.48	83166.18
20	12.84	4.05	45.62	2.46	16.43	10.55	1.43	83656.08
21	10.00	3.20	57.24	2.22	16.79	10.61	1.45	85448.78
22	9.51	6.42	51.01	2.55	15.92	10.62	1.49	81604.94
23	8.69	3.24	46.56	2.50	16.66	10.33	1.49	80587.27
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	24
平均值	9.28	5.10	51.54	2.34	16.51	10.63	1.43	82342.07
最大值	12.84	16.81	63.45	3.16	18.63	11.39	1.49	86764.69
發生時間	20	14	14	11	3	14		7
最小值	2.78	2.41	42.33	1.53	14.51	10.09	1.37	74189.54
發生時間	14	17	4	1	14	4		15
零點偏移(率)	-0.03 %	-0.09 %	-0.02 %	-0.00 %		-0.06	0.00	0.00 %
全幅偏移(率)	0.46 %	0.81 %	-0.22 %	0.14 %		0.04	-0.03	0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年3月8日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.07	8.15	47.94	2.42	14.49	11.23	1.77	81788.81
1	9.36	3.32	53.09	1.96	15.00	11.04	1.77	84438.71
2	8.46	4.02	55.19	1.58	15.91	11.22	1.79	82316.00
3	8.55	3.65	49.78	1.41	17.47	10.68	1.80	84697.27
4	9.66	3.93	56.09	1.79	16.21	10.66	1.80	85138.57
5	10.52	7.53	46.97	1.81	15.12	11.05	1.80	83465.43
6	9.98	4.22	62.26	1.70	15.69	11.46	1.80	80176.91
7	1.22	4.35	54.49	0.79	17.06	10.75	1.81	82389.10
8	3.07	4.38	51.50	0.92	16.39	10.79	1.80	84675.67
9	1.33	3.68	55.80	0.90	16.81	10.97	1.80	84051.46
10	6.41	6.19	52.40	1.69	15.14	11.03	1.84	84478.67
11	11.78	9.71	51.27	3.10	13.90	11.43	1.83	80431.80
12	9.93	2.91	50.49	2.08	14.75	11.18	1.84	80163.80
13	10.67	3.74	52.88	2.03	15.69	11.29	1.83	81988.94
14	8.25	無效	51.39	4.89	13.92	11.40	1.81	74767.23
15	11.87	無效	46.81	7.34	12.13	11.24	1.39	76044.24
16	9.64	15.26	46.23	2.43	15.64	10.50	1.40	79143.76
17	7.98	4.35	48.94	2.50	14.85	11.00	1.40	81217.86
18	10.81	4.59	53.36	2.65	14.97	11.08	1.41	83181.37
19	11.30	4.42	51.68	2.84	14.63	11.01	1.38	81669.95
20	8.13	4.91	57.20	2.31	15.58	10.92	1.39	81065.72
21	7.57	5.32	51.41	2.36	14.86	11.00	1.38	82447.00
22	9.26	3.57	57.34	2.59	14.89	11.15	1.38	82301.23
23	10.94	3.44	57.39	2.81	14.37	11.33	1.38	81649.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	22	24	24	24	24	24	24
平均值	8.70	5.26	52.58	2.37	15.23	11.06	1.65	81820.39
最大值	12.07	15.26	62.26	7.34	17.47	11.46	1.84	85138.57
發生時間	0	16	6	15	3	6		4
最小值	1.22	2.91	46.23	0.79	12.13	10.50	1.38	74767.23
發生時間	7	12	16	7	15	16		14
零點偏移(率)	-0.16 %	-0.07 %	-0.06 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.06 %	0.83 %	-0.90 %	-0.04 %		-0.05	0.00	0.20 %
有效比率	100.00 %	91.67 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								