

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月04日

報表日期: 115年08月04日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	8.30	12.88	59.32	2.82	18.33	11.23	1.20	80797.90
1	7.86	11.76	59.52	1.74	18.60	11.30	1.19	80166.81
2	7.80	11.51	56.50	2.59	17.45	11.21	1.19	82020.59
3	8.71	11.93	55.65	3.44	15.74	11.67	1.21	79957.78
4	9.52	12.13	59.17	3.10	15.86	11.75	1.18	79544.49
5	10.67	11.65	54.03	2.66	17.01	11.41	1.19	77334.58
6	10.84	11.66	55.84	2.66	17.12	11.27	1.20	81565.72
7	7.84	11.80	48.24	2.33	15.72	11.60	1.20	80347.53
8	10.16	13.64	41.57	3.28	16.41	11.42	1.21	77875.86
9	8.92	12.76	42.02	2.86	15.31	11.81	1.20	78120.92
10	8.75	12.04	52.09	2.22	16.07	11.77	1.20	79072.96
11	10.16	12.41	49.80	2.35	15.92	11.83	1.18	78857.93
12	8.27	13.63	59.61	2.00	16.39	12.03	1.20	76198.58
13	10.22	14.52	51.02	2.45	16.35	11.64	1.18	79199.94
14	8.05	14.03	63.36	1.49	17.39	12.08	1.18	71772.87
15	10.34	13.20	53.63	2.29	17.25	11.25	1.18	74206.94
16	11.68	12.59	46.19	3.54	16.72	11.18	1.18	74964.77
17	6.89	12.48	46.62	2.87	17.82	10.82	1.18	77243.43
18	9.70	13.50	48.60	3.63	20.19	10.20	1.18	79399.89
19	4.45	12.37	63.06	1.65	17.45	10.97	1.18	76162.64
20	10.13	12.49	58.92	2.70	17.97	11.03	1.18	75349.64
21	12.24	12.52	56.24	2.50	19.48	10.58	1.18	77364.76
22	8.31	12.92	55.41	2.81	17.36	10.91	1.18	75666.24
23	9.64	13.74	62.21	2.27	17.92	10.87	1.18	75567.13
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.14	12.67	54.11	2.59	17.16	11.33	1.19	77865.00
最 大 值	12.24	14.52	63.36	3.63	20.19	12.08	1.24	82020.59
發生時間	21	13	14	18	18	14		2
最 小 值	4.45	11.51	41.57	1.49	15.31	10.20	1.18	71772.87
發生時間	19	2	8	14	9	18		14
零點偏移(率)	0.00 %	0.00 %	-0.03 %	-0.01 %		-0.02	-0.01	0.10 %
全幅偏移(率)	-0.17 %	-0.65 %	0.52 %	-0.26 %		0.01	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月04日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	5.83	12.38	39.70	1.96	18.80	10.85	0.88	82030.39
1	2.70	13.86	42.74	2.20	19.14	11.06	0.88	79915.84
2	2.15	13.71	53.94	2.89	17.61	11.24	0.87	80562.94
3	4.47	13.18	54.10	2.73	17.45	11.30	0.88	80444.03
4	2.79	13.89	49.64	2.81	17.80	11.08	0.86	81189.85
5	4.17	14.83	63.00	2.42	16.63	11.21	0.87	81463.50
6	9.59	12.02	52.35	2.40	18.19	10.69	0.85	85835.92
7	12.02	12.23	52.26	2.15	17.97	10.89	0.85	82531.55
8	8.46	12.26	54.43	1.95	17.88	10.91	0.86	82331.65
9	12.50	12.72	48.22	3.06	17.79	10.91	0.86	82483.43
10	8.05	12.83	44.51	2.57	16.77	11.37	0.85	80797.10
11	12.18	12.58	50.29	3.24	16.68	11.24	0.84	80920.88
12	10.57	12.77	54.60	1.95	16.83	11.43	0.88	79103.17
13	10.01	12.96	52.87	2.52	17.35	11.42	0.88	78379.53
14	9.80	12.64	50.58	3.11	17.18	11.24	0.85	80218.84
15	7.84	12.92	50.48	2.23	15.26	11.60	0.83	78646.27
16	7.04	12.61	63.82	2.59	16.43	11.43	0.83	79647.35
17	5.90	12.46	60.01	3.51	17.14	11.16	0.83	80939.49
18	7.02	12.28	46.97	2.64	17.55	10.87	0.85	83072.68
19	6.11	12.49	58.28	2.47	18.94	10.42	0.84	85310.14
20	5.53	12.19	67.46	3.99	16.84	11.00	0.84	82727.12
21	6.62	12.65	40.78	2.89	17.90	11.00	0.84	81938.37
22	3.11	12.92	48.07	2.06	17.60	11.21	0.85	79633.91
23	3.12	12.61	60.60	1.07	18.73	11.05	0.85	80600.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.98	12.83	52.49	2.56	17.52	11.11	0.85	81280.18
最 大 值	12.50	14.83	67.46	3.99	19.14	11.60	0.88	85835.92
發生時間	9	5	20	20	1	15		6
最 小 值	2.15	12.02	39.70	1.07	15.26	10.42	0.83	78379.53
發生時間	2	6	0	23	15	19		13
零點偏移(率)	-0.05 %	0.01 %	-0.05 %	-0.01 %		0.00	-0.01	-0.20 %
全幅偏移(率)	-0.74 %	-0.46 %	0.45 %	-0.88 %		-0.14	-0.06	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月04日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.14	11.29	61.49	0.93	18.97	9.89	1.45	77263.16
1	1.00	11.73	60.42	1.62	20.65	9.95	1.47	75650.57
2	0.99	11.23	61.13	1.58	19.58	9.57	1.46	77932.23
3	0.77	11.58	58.18	1.60	18.14	10.01	1.47	76896.99
4	2.54	11.54	54.74	1.70	18.55	9.87	1.48	78093.53
5	0.75	11.80	50.71	1.65	17.16	10.32	1.47	76717.83
6	0.67	11.83	52.04	1.75	15.78	10.65	1.47	74597.01
7	3.18	11.73	57.47	2.67	16.90	10.48	1.40	72810.74
8	1.85	12.01	60.52	2.53	16.76	10.13	1.42	72265.15
9	2.78	11.19	58.89	2.53	17.78	9.75	1.37	75754.70
10	2.26	11.49	60.44	2.49	17.36	10.00	1.36	75019.83
11	1.52	11.79	58.84	2.36	16.81	10.19	1.37	72886.34
12	2.40	11.20	59.99	2.33	17.61	9.71	1.41	73992.64
13	1.96	11.22	53.58	2.27	17.92	9.62	1.40	74605.71
14	2.50	12.75	55.23	2.41	18.10	9.47	1.40	74350.78
15	3.65	12.14	56.34	2.39	17.22	9.61	1.37	72761.51
16	1.81	12.28	57.46	2.17	18.01	9.69	1.36	75235.59
17	2.68	12.19	58.04	2.36	17.73	9.85	1.37	76279.18
18	2.31	12.49	58.13	2.35	17.88	10.11	1.41	77899.54
19	2.34	13.15	60.18	2.60	16.96	10.32	1.37	75535.82
20	4.57	12.51	61.16	2.62	18.57	9.98	1.36	80300.07
21	3.53	13.14	64.79	2.28	19.70	9.26	1.40	79932.60
22	3.06	12.16	59.29	0.41	18.06	9.83	1.38	77695.76
23	5.00	11.96	55.08	2.61	19.34	9.52	1.43	78053.17
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.30	11.93	58.09	2.09	17.98	9.91	1.41	75938.77
最 大 值	5.00	13.15	64.79	2.67	20.65	10.65	1.48	80300.07
發生時間	23	19	21	7	1	6		20
最 小 值	0.67	11.19	50.71	0.41	15.78	9.26	1.35	72265.15
發生時間	6	9	5	22	6	21		8
零點偏移(率)	-0.13 %	-0.01 %	-0.01 %	-0.06 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	-1.26 %	-0.51 %	-0.32 %	-0.47 %		0.31	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								