

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月26日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.40	12.22	47.90	2.63	16.96	11.59	1.26	78907.93
1	8.85	12.44	53.16	3.34	17.01	11.32	1.26	80131.69
2	8.35	12.25	49.26	2.93	15.37	11.52	1.25	80528.57
3	9.79	12.05	47.11	2.24	16.19	11.62	1.26	79713.43
4	9.91	12.23	55.05	2.66	16.75	11.58	1.27	80029.58
5	8.35	12.09	50.87	3.31	16.46	11.42	1.26	78179.19
6	10.29	12.05	51.99	2.36	15.77	11.64	1.28	79468.83
7	6.80	11.84	55.30	2.81	16.98	11.30	1.29	82067.10
8	3.72	12.15	51.08	2.58	14.34	11.94	1.29	76239.14
9	6.51	12.75	52.00	1.65	16.34	12.21	1.31	73627.87
10	3.82	12.78	49.95	1.30	16.65	12.08	1.29	74731.44
11	5.14	12.81	56.88	2.04	15.96	11.81	1.29	76393.11
12	5.78	12.62	47.65	2.35	15.37	11.66	1.29	77087.75
13	6.21	12.56	66.66	1.98	16.86	11.76	1.29	76567.50
14	6.18	12.28	51.29	3.05	16.39	11.52	1.28	77326.26
15	4.17	13.01	44.07	1.68	16.51	11.67	1.27	77186.22
16	4.52	12.33	47.85	1.75	16.93	11.71	1.29	78476.42
17	4.40	12.04	52.71	1.35	17.60	11.51	1.29	79491.51
18	3.98	11.90	41.73	1.88	16.33	11.46	1.29	80369.77
19	5.74	13.05	59.48	1.62	17.38	11.45	1.29	79796.11
20	8.68	11.99	43.71	2.61	15.46	11.55	1.29	79400.65
21	9.17	12.39	51.45	1.59	16.94	11.56	1.30	76800.56
22	8.97	12.30	61.49	1.13	18.45	11.37	1.31	78064.01
23	7.15	12.39	41.81	1.53	19.12	11.08	1.29	81297.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.87	12.35	51.27	2.18	16.59	11.60	1.28	78411.77
最大值	10.29	13.05	66.66	3.34	19.12	12.21	1.32	82067.10
發生時間	6	19	13	1	23	9		7
最小值	3.72	11.84	41.73	1.13	14.34	11.08	1.25	73627.87
發生時間	8	7	18	22	8	23		9
零點偏移(率)	0.00 %	0.01 %	0.00 %	0.00 %		-0.07	-0.01	0.20 %
全幅偏移(率)	-0.63 %	0.15 %	0.21 %	0.63 %		-0.12	0.10	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月26日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.06	12.15	50.66	2.41	15.05	10.99	1.00	76307.47
1	10.29	12.93	50.22	2.71	16.16	10.89	0.99	76113.61
2	7.87	12.07	48.19	2.36	15.80	10.72	0.99	77674.38
3	10.26	12.05	52.29	2.03	16.00	10.73	0.99	77420.27
4	11.07	12.05	54.90	2.43	16.19	10.72	0.99	78121.15
5	8.92	11.90	46.03	1.99	16.59	10.58	0.99	78120.58
6	9.73	12.22	46.24	1.91	14.15	11.11	0.99	77564.11
7	6.26	12.26	56.45	1.53	16.09	10.98	1.01	75424.87
8	8.96	12.12	46.86	1.72	15.46	10.94	1.02	75679.28
9	9.03	11.91	50.39	1.68	16.41	10.68	1.02	77121.28
10	12.29	11.90	51.80	2.18	15.76	10.74	1.01	76333.61
11	7.41	11.88	49.95	1.70	16.15	10.62	1.02	76772.81
12	12.61	11.92	47.75	2.10	15.80	10.62	1.02	74618.86
13	6.77	11.16	37.82	1.20	17.29	9.55	1.03	76128.72
14	9.88	11.23	37.79	1.24	16.48	10.00	1.03	74659.00
15	7.45	11.29	36.83	1.36	16.59	9.96	1.02	73060.78
16	8.71	12.58	36.99	1.95	17.10	9.18	1.00	76444.56
17	9.73	11.11	44.87	2.45	16.22	9.37	1.01	74378.36
18	7.99	12.01	45.50	2.87	14.93	9.72	0.99	73795.46
19	12.53	11.59	54.53	1.52	16.51	9.68	0.98	75562.47
20	7.89	10.74	58.87	0.53	17.25	9.50	0.97	76028.40
21	9.46	10.83	56.68	0.95	19.12	9.28	0.98	78878.78
22	10.52	11.39	60.55	0.81	18.77	9.94	0.99	76501.88
23	9.42	11.35	48.22	1.10	19.34	9.66	0.99	79836.18
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.46	11.78	48.77	1.78	16.47	10.26	1.00	76356.12
最大值	12.61	12.93	60.55	2.87	19.34	11.11	1.05	79836.18
發生時間	12	1	22	18	23	6		23
最小值	6.26	10.74	36.83	0.53	14.15	9.18	0.97	73060.78
發生時間	7	20	15	20	6	16		15
零點偏移(率)	-0.13 %	0.00 %	-0.03 %	-0.01 %		-0.10	-0.01	0.10 %
全幅偏移(率)	0.66 %	1.07 %	1.04 %	0.34 %		-0.17	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月26日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.75	12.13	49.37	2.30	17.02	9.52	1.43	72402.51
1	7.62	12.59	51.62	2.15	18.11	9.48	1.44	73071.05
2	9.27	11.48	51.74	2.33	16.39	9.68	1.45	71362.72
3	13.12	11.55	49.75	2.87	16.85	9.45	1.46	73007.02
4	7.64	11.65	54.09	2.05	16.92	9.63	1.46	71647.30
5	8.60	11.31	50.65	2.22	17.76	9.29	1.45	73411.81
6	11.72	11.78	49.82	2.43	17.07	9.41	1.45	71818.36
7	11.44	11.35	42.15	2.72	18.41	9.19	1.40	74545.36
8	8.12	11.09	50.63	2.92	16.71	9.51	1.41	71329.09
9	9.19	11.07	52.46	2.41	16.96	9.48	1.41	70760.61
10	10.99	11.04	50.71	2.78	18.16	9.16	1.42	72917.46
11	7.20	10.95	45.51	2.24	17.76	9.22	1.39	72307.76
12	7.63	11.56	53.03	1.32	17.70	9.75	1.41	69169.43
13	9.09	11.11	50.39	1.45	18.33	9.22	1.39	73581.75
14	8.54	11.27	51.75	1.17	17.18	9.70	1.37	70311.70
15	10.23	11.08	55.61	1.14	18.47	9.67	1.36	70556.83
16	9.22	11.08	54.70	1.54	18.20	9.40	1.38	76206.65
17	9.64	11.93	56.21	1.70	15.30	10.18	1.40	72675.21
18	5.21	15.46	54.06	3.68	16.35	9.81	1.41	73307.05
19	10.77	11.15	40.45	0.86	17.84	9.35	1.39	75419.36
20	10.21	11.25	44.96	1.72	17.01	9.57	1.39	72591.74
21	8.48	10.98	50.04	0.95	17.91	9.68	1.41	76123.52
22	10.09	11.47	46.11	1.15	15.62	10.04	1.41	71986.43
23	9.55	11.57	48.07	2.07	17.78	9.81	1.41	73634.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.31	11.58	50.16	2.01	17.33	9.55	1.41	72672.70
最大值	13.12	15.46	56.21	3.68	18.47	10.18	1.46	76206.65
發生時間	3	18	17	18	15	17		16
最小值	5.21	10.95	40.45	0.86	15.30	9.16	1.36	69169.43
發生時間	18	11	19	19	17	10		12
零點偏移(率)	-0.03 %	0.01 %	-0.01 %	0.00 %		-0.35	-0.01	0.00 %
全幅偏移(率)	-0.37 %	-0.75 %	1.06 %	1.17 %		0.04	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								