

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.69	11.62	52.77	1.29	17.77	11.13	1.21	81785.26
1	8.23	11.94	56.23	1.17	19.13	11.23	1.21	79929.73
2	11.15	11.28	51.49	2.41	17.94	10.59	1.22	86206.60
3	7.80	12.16	58.94	3.00	15.76	11.04	1.21	84768.94
4	5.97	12.56	56.35	3.16	15.16	11.29	1.22	83025.09
5	9.95	12.20	46.11	2.42	17.56	10.57	1.25	87736.17
6	9.05	12.46	55.51	2.02	18.18	10.93	1.25	83086.52
7	9.98	12.77	51.21	2.28	16.98	11.12	1.24	82521.77
8	8.34	13.30	51.28	2.14	16.84	11.02	1.23	83707.12
9	9.53	13.14	51.03	2.39	15.82	11.38	1.24	81641.63
10	10.93	13.35	54.28	2.52	15.23	11.54	1.23	80716.38
11	8.30	13.52	56.43	2.23	15.99	11.43	1.22	80917.87
12	8.97	13.37	54.17	1.98	15.49	11.64	1.23	79499.98
13	9.10	13.11	56.41	1.29	18.16	10.93	1.22	82885.67
14	9.10	13.35	51.86	1.69	17.30	11.04	1.21	82924.86
15	7.28	13.01	61.53	1.32	18.42	11.16	1.22	80891.86
16	8.67	14.03	47.03	2.44	15.99	11.07	1.22	84117.55
17	11.54	13.85	56.12	2.66	16.52	10.97	1.22	84417.63
18	7.63	11.13	54.58	1.89	16.77	11.04	1.22	83294.85
19	9.91	11.23	58.65	1.66	17.67	11.01	1.23	82681.32
20	8.93	10.84	37.38	1.54	18.63	10.58	1.22	85297.57
21	10.42	10.82	41.12	1.59	18.82	10.50	1.23	85899.42
22	11.65	11.13	62.20	1.53	18.56	10.69	1.21	84407.22
23	5.45	10.88	53.19	2.05	19.55	10.33	1.21	86041.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.98	12.38	53.16	2.03	17.26	11.01	1.22	83266.78
最大值	11.65	14.03	62.20	3.16	19.55	11.64	1.25	87736.17
發生時間	22	16	22	4	23	12		5
最小值	5.45	10.82	37.38	1.17	15.16	10.33	1.19	79499.98
發生時間	23	21	20	1	4	23		12
零點偏移(率)	-0.14 %	-0.00 %	-0.01 %	0.00 %		-0.01	-0.01	0.10 %
全幅偏移(率)	-2.33 %	-0.67 %	0.93 %	-0.19 %		0.15	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.69	13.60	52.85	0.76	19.18	10.70	0.99	75536.65
1	4.51	13.47	55.25	0.81	19.13	10.63	1.00	83350.15
2	5.53	13.10	53.75	0.86	19.00	10.34	1.00	84245.51
3	1.26	13.47	56.74	1.31	17.04	10.92	0.99	81080.71
4	4.86	14.14	55.35	2.24	16.50	10.70	0.97	78250.96
5	7.55	12.89	54.60	1.26	18.61	10.43	0.96	80212.69
6	2.21	12.57	60.32	0.62	18.05	11.15	0.95	78337.45
7	6.90	11.93	49.20	0.98	18.79	10.13	0.97	80791.59
8	6.76	11.41	46.98	1.37	18.43	10.04	0.97	79812.47
9	8.28	11.85	47.98	1.44	18.38	10.17	0.98	78562.02
10	6.51	11.58	53.02	1.26	17.90	10.30	0.98	80603.13
11	0.26	12.51	54.56	0.89	17.87	10.83	0.99	78661.41
12	0.11	12.34	50.61	1.85	16.18	10.92	0.99	77978.33
13	0.16	11.76	56.32	0.81	18.90	10.35	0.98	79671.03
14	0.14	13.32	58.02	1.90	17.35	10.60	0.98	81058.40
15	0.34	12.19	52.88	0.83	19.47	10.13	0.98	79878.08
16	0.17	11.85	42.22	1.57	18.30	10.18	0.97	82157.89
17	0.10	11.81	51.14	2.61	16.36	10.44	0.97	78029.07
18	0.10	11.90	43.39	2.14	16.95	10.27	0.97	78738.39
19	0.10	11.86	47.70	2.66	15.59	10.65	0.96	76996.83
20	0.10	11.90	47.97	2.38	16.77	10.46	0.97	77805.42
21	0.11	11.34	49.08	1.22	18.68	9.92	0.97	81031.22
22	0.17	12.01	56.83	0.72	18.95	10.29	0.97	83542.79
23	0.30	11.90	48.40	0.65	19.72	10.15	0.99	81744.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	2.51	12.36	51.88	1.38	18.00	10.45	0.98	79919.87
最大值	8.28	14.14	60.32	2.66	19.72	11.15	1.02	84245.51
發生時間	9	4	6	19	23	6		2
最小值	0.10	11.34	42.22	0.62	15.59	9.92	0.94	75536.65
發生時間	17	21	16	6	19	21		0
零點偏移(率)	-0.14 %	0.01 %	-0.03 %	-0.01 %		0.01	-0.01	-0.20 %
全幅偏移(率)	1.62 %	0.47 %	1.76 %	-0.92 %		0.06	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.55	13.59	50.68	2.60	17.92	10.37	1.35	70178.98
1	5.04	12.58	50.03	2.71	19.85	9.83	1.32	74962.90
2	5.12	12.72	54.35	2.73	18.35	10.15	1.31	73024.75
3	8.15	12.32	53.15	2.96	18.49	9.70	1.31	78491.85
4	8.95	12.39	55.10	3.00	19.20	9.62	1.34	77505.13
5	9.80	10.68	41.18	3.10	19.58	9.01	1.37	77142.89
6	7.86	11.10	44.32	2.82	19.40	9.26	1.37	75303.51
7	3.48	10.43	35.65	2.25	18.01	8.91	1.35	78200.41
8	6.69	10.87	46.70	2.52	17.62	9.60	1.36	78255.35
9	9.33	11.06	53.09	2.82	18.21	9.81	1.36	77406.47
10	7.76	11.11	52.46	2.65	16.97	9.97	1.34	76328.41
11	9.41	11.28	57.10	2.71	18.17	9.89	1.35	76559.48
12	6.26	11.11	56.87	2.70	19.16	9.58	1.32	77405.94
13	4.95	11.97	53.59	2.58	19.32	10.37	1.31	70845.52
14	8.12	11.26	41.40	3.11	19.62	9.40	1.31	76690.06
15	8.16	11.52	45.88	2.72	19.32	9.84	1.31	74842.18
16	8.93	11.33	46.99	2.48	19.22	9.75	1.31	77101.53
17	8.32	11.17	42.80	2.58	18.29	9.64	1.30	74328.78
18	8.58	11.46	42.08	2.39	17.72	9.51	1.31	73285.18
19	7.39	11.36	38.37	2.41	16.85	9.53	1.34	72396.42
20	10.64	12.29	42.88	2.81	17.65	9.52	1.33	74742.00
21	10.54	11.41	40.87	2.90	20.07	8.82	1.31	75764.32
22	9.04	11.03	50.86	2.95	19.34	9.48	1.34	76334.37
23	7.58	10.90	50.21	2.92	19.60	9.28	1.35	75108.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.74	11.54	47.78	2.73	18.66	9.62	1.33	75508.55
最大值	10.64	13.59	57.10	3.11	20.07	10.37	1.39	78491.85
發生時間	20	0	11	14	21	0		3
最小值	3.48	10.43	35.65	2.25	16.85	8.82	1.29	70178.98
發生時間	7	7	7	7	19	21		0
零點偏移(率)	-0.03 %	0.01 %	-0.03 %	-0.09 %		-0.03	-0.01	-0.20 %
全幅偏移(率)	1.06 %	1.48 %	2.14 %	0.31 %		0.36	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								