

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年10月25日

報表日期: 114年10月25日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.29	13.61	54.03	2.80	16.05	11.69	1.26	73000.62
1	1.41	13.93	57.32	1.57	18.03	11.18	1.27	75786.14
2	2.41	13.93	53.10	2.31	15.44	11.95	1.26	72134.29
3	6.34	12.05	53.58	2.35	16.35	11.56	1.27	74223.54
4	5.44	12.49	54.92	1.90	17.83	11.17	1.26	75926.96
5	5.28	13.38	51.24	2.11	16.00	11.76	1.27	75320.95
6	4.46	12.92	55.80	2.32	17.87	11.20	1.27	75208.29
7	6.41	13.31	56.22	2.62	16.69	11.65	1.27	73258.35
8	5.15	12.85	54.74	3.02	16.94	11.24	1.28	76055.83
9	10.92	13.79	64.38	2.21	17.97	11.82	1.27	71517.21
10	6.10	12.95	35.23	2.87	17.04	11.17	1.27	76706.59
11	5.67	13.35	45.12	2.81	17.13	11.46	1.27	74024.06
12	3.59	13.65	64.16	2.22	16.64	11.86	1.26	71368.38
13	5.74	12.97	62.75	2.00	17.24	11.25	1.25	75756.01
14	7.79	13.43	54.66	3.12	16.14	11.70	1.26	73533.30
15	7.72	13.69	61.85	2.35	17.10	11.49	1.25	74039.55
16	6.68	13.24	54.35	2.36	17.81	11.24	1.25	75650.16
17	6.72	12.95	50.25	2.79	17.11	11.23	1.25	76465.32
18	7.36	13.03	54.90	2.67	17.23	11.34	1.25	75277.62
19	8.31	13.22	55.82	3.82	16.72	11.59	1.25	75756.25
20	14.17	12.98	57.84	3.97	15.73	11.54	1.25	75743.48
21	10.81	13.74	56.04	2.81	16.74	11.66	1.25	73650.17
22	4.55	13.73	51.52	2.39	16.71	11.94	1.25	70990.94
23	12.72	14.12	46.61	3.94	15.98	12.27	1.25	69620.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.67	13.30	54.43	2.64	16.85	11.54	1.26	74208.93
最 大 值	14.17	14.12	64.38	3.97	18.03	12.27	1.28	76706.59
發生時間	20	23	9	20	1	23		10
最 小 值	1.41	12.05	35.23	1.57	15.44	11.17	1.25	69620.38
發生時間	1	3	10	1	2	4		23
零點偏移(率)	-0.05 %	-0.02 %	-0.01 %	-0.01 %		0.03	-0.01	0.20 %
全幅偏移(率)	-0.16 %	0.39 %	-0.44 %	-0.19 %		0.33	0.04	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年10月25日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.73	12.34	60.00	0.51	19.67	10.42	1.02	85052.05
1	2.38	13.04	44.84	0.91	19.91	10.08	1.02	86908.42
2	2.20	12.54	61.53	0.47	19.44	10.55	1.02	84379.10
3	2.24	13.39	42.30	0.94	19.14	10.23	1.02	88075.22
4	2.10	12.39	51.03	0.84	19.15	10.45	1.02	86144.87
5	2.23	12.69	47.71	0.71	19.30	10.34	1.02	87034.89
6	3.06	12.24	52.32	0.84	18.88	10.48	1.01	84353.54
7	2.99	12.16	51.00	0.54	20.36	10.05	1.02	87821.11
8	3.02	12.34	53.41	1.01	19.78	10.37	1.02	86042.31
9	3.24	12.81	42.40	0.49	21.61	9.74	1.00	88431.60
10	3.23	11.96	54.72	0.34	20.65	10.23	0.99	85244.40
11	3.35	11.84	42.88	0.64	19.70	10.13	0.99	87714.85
12	3.17	12.10	53.94	0.81	18.76	10.57	1.02	84804.67
13	3.27	12.06	50.62	1.02	18.74	10.57	1.02	84885.37
14	2.77	12.13	52.90	0.83	19.35	10.33	1.02	86073.68
15	2.56	12.19	47.67	1.33	17.80	10.61	1.02	85701.47
16	2.61	12.25	50.09	1.03	19.29	10.19	1.02	86977.46
17	2.72	12.80	61.77	0.86	18.88	11.07	1.03	80700.36
18	2.38	12.49	36.68	1.79	18.28	10.65	1.02	84559.80
19	2.51	13.00	30.77	1.02	19.18	9.88	1.02	89362.67
20	2.80	12.55	51.87	0.82	19.49	10.58	1.02	84213.88
21	2.60	11.85	42.63	1.11	19.55	10.23	1.02	86493.33
22	2.51	12.38	38.39	1.35	18.55	10.75	1.02	83658.86
23	2.45	12.48	39.11	1.29	18.71	10.64	1.02	83977.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.71	12.42	48.36	0.90	19.34	10.38	1.02	85775.49
最 大 值	3.35	13.39	61.77	1.79	21.61	11.07	1.05	89362.67
發生時間	11	3	17	18	9	17		19
最 小 值	2.10	11.84	30.77	0.34	17.80	9.74	0.99	80700.36
發生時間	4	11	19	10	15	9		17
零點偏移(率)	-0.08 %	0.00 %	-0.04 %	-0.00 %		0.00	-0.01	-0.10 %
全幅偏移(率)	0.05 %	0.00 %	-0.02 %	0.11 %		-0.15	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

