

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.53	6.09	55.00	1.07	19.75	11.05	1.06	80214.52
1	6.30	5.98	57.12	1.76	19.09	11.42	1.05	78192.84
2	9.04	6.13	66.87	1.72	17.78	12.02	1.05	74444.14
3	10.19	5.66	54.89	1.77	18.08	11.46	1.05	78709.57
4	7.63	7.11	55.54	1.80	17.71	11.71	1.06	76733.01
5	9.31	13.13	46.06	2.44	16.15	11.87	1.06	74416.78
6	8.67	8.76	48.32	2.63	16.27	11.73	1.05	77171.85
7	11.49	6.98	50.56	2.44	17.42	11.45	1.06	78908.49
8	7.83	6.74	55.57	1.78	18.32	11.19	1.07	80208.26
9	8.17	9.33	45.10	2.63	16.35	11.84	1.05	75482.44
10	8.55	7.25	55.66	2.09	18.11	11.17	1.07	80036.83
11	5.34	6.99	51.63	1.75	16.80	11.70	1.07	77548.95
12	7.37	6.58	53.80	1.81	16.69	11.08	1.05	80324.93
13	4.94	10.12	47.33	2.53	15.11	11.92	1.07	73480.28
14	8.02	7.11	47.85	2.09	17.23	11.38	1.07	77151.63
15	6.68	5.99	58.88	2.31	16.26	12.02	1.07	72835.44
16	4.99	5.86	46.23	1.23	17.09	11.52	1.07	79151.88
17	9.15	6.97	48.45	2.03	16.72	11.73	1.07	77285.26
18	5.88	5.29	48.53	1.28	18.08	11.53	1.07	77979.57
19	2.98	6.36	54.01	0.87	18.67	11.39	1.07	78321.47
20	0.87	5.84	67.48	0.88	18.26	11.37	1.08	78853.25
21	0.77	6.91	52.36	1.54	16.72	11.77	1.08	76507.65
22	2.36	8.57	51.18	2.07	16.30	12.02	1.05	75223.98
23	2.67	7.62	56.71	1.82	16.12	12.32	1.07	72825.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.36	7.22	53.13	1.85	17.29	11.61	1.06	77167.01
最大值	11.49	13.13	67.48	2.63	19.75	12.32	1.10	80324.93
發生時間	7	5	20	6	0	23		12
最小值	0.77	5.29	45.10	0.87	15.11	11.05	1.04	72825.32
發生時間	21	18	9	19	13	0		23
零點偏移(率)	-0.01 %	-0.08 %	-0.01 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.03 %	-0.01 %	0.03 %		0.06		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.23	7.17	49.04	1.42	21.07	10.14	0.99	84461.18
1	5.98	4.69	42.74	2.29	19.80	10.17	0.99	85256.30
2	4.52	5.15	54.25	3.26	16.30	10.91	0.99	82483.12
3	5.25	3.51	60.33	2.41	17.66	10.61	0.99	83608.56
4	9.02	4.20	39.83	2.65	17.64	10.41	0.99	85058.47
5	8.53	3.79	56.02	2.42	17.63	10.44	0.99	85541.28
6	8.33	6.12	46.45	2.11	19.00	9.89	1.00	86562.86
7	8.63	7.65	48.31	2.43	17.83	10.31	0.99	85849.35
8	9.27	6.95	51.46	2.45	17.36	10.41	1.00	85477.26
9	8.58	10.09	47.86	2.58	17.58	10.42	1.00	84467.42
10	7.49	6.65	50.41	1.75	18.11	10.15	1.01	86503.27
11	2.18	4.53	55.89	2.38	16.47	10.58	1.00	84652.64
12	3.43	5.54	55.69	2.75	16.29	10.64	1.01	84304.96
13	3.82	5.85	49.45	3.22	16.81	10.59	1.02	83973.60
14	3.61	6.34	40.77	2.19	18.20	10.21	1.01	85977.38
15	3.39	2.47	50.65	2.37	18.01	10.15	1.01	85914.37
16	6.82	2.13	41.43	2.55	18.05	10.37	1.00	84761.24
17	3.37	6.23	52.51	2.44	17.48	10.58	0.99	83455.58
18	0.22	3.97	58.25	1.97	18.41	10.61	0.99	82544.47
19	0.12	4.53	49.43	2.36	18.48	10.50	0.99	83321.09
20	0.12	4.88	50.53	2.70	17.13	10.32	0.99	85226.31
21	0.14	3.75	58.96	2.25	18.11	10.34	0.99	85385.57
22	0.20	4.81	53.44	2.25	17.84	10.41	0.99	84473.02
23	0.13	4.84	52.87	1.80	17.63	10.45	0.99	82076.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.39	5.24	50.69	2.37	17.87	10.40	1.00	84638.97
最大值	9.27	10.09	60.33	3.26	21.07	10.91	1.02	86562.86
發生時間	8	9	3	2	0	2		6
最小值	0.12	2.13	39.83	1.42	16.29	9.89	0.97	82076.05
發生時間	19	16	4	0	12	6		23
零點偏移(率)	-0.04 %	-0.04 %	-0.13 %	-0.07 %		0.00		-0.20 %
全幅偏移(率)	0.04 %	-0.01 %	-0.39 %	0.01 %		-0.24		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年09月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.64	4.58	46.01	1.29	17.18	10.58	1.04	76645.56
1	3.19	5.34	44.38	1.50	16.32	11.19	1.02	73335.65
2	5.83	5.81	47.96	1.48	17.09	10.84	1.02	78707.63
3	10.21	8.63	42.73	1.55	17.44	10.43	1.02	80649.16
4	11.72	7.78	39.48	1.69	18.11	10.20	1.02	83689.38
5	8.62	11.36	39.69	1.67	16.39	10.75	1.03	78911.35
6	6.58	6.02	44.89	1.46	17.71	10.46	1.04	80684.13
7	6.98	9.26	37.69	1.59	16.81	10.49	1.06	82341.28
8	9.54	4.74	38.57	2.18	16.31	10.81	1.04	79400.50
9	9.28	6.45	40.86	1.87	17.11	10.66	1.06	82359.29
10	8.33	6.88	46.50	1.75	16.92	10.55	1.07	83661.87
11	6.50	6.54	42.16	1.42	16.28	10.77	1.06	80922.39
12	9.80	5.78	45.31	1.82	15.82	10.69	1.07	78785.37
13	8.15	6.11	42.31	2.11	15.31	10.67	1.05	76260.25
14	8.74	5.97	33.19	2.27	17.17	10.23	1.05	77795.85
15	0.69	5.60	22.41	1.55	17.12	9.74	1.05	79381.63
16	2.84	4.04	41.15	1.11	16.22	10.57	1.05	72369.97
17	6.38	6.15	51.33	1.00	18.31	10.88	1.05	76431.35
18	2.63	5.47	50.31	0.92	18.29	10.68	1.02	80113.90
19	0.78	7.52	47.96	0.89	18.70	10.52	1.04	80420.51
20	1.16	3.49	42.43	1.40	15.91	10.65	1.07	81346.09
21	1.49	2.83	44.36	1.27	15.51	10.96	1.04	72729.09
22	1.98	10.49	46.62	1.17	16.21	10.87	1.01	73234.60
23	1.80	5.48	38.19	1.06	16.82	10.20	1.01	73714.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.83	6.35	42.35	1.50	16.88	10.60	1.04	78495.45
最大值	11.72	11.36	51.33	2.27	18.70	11.19	1.10	83689.38
發生時間	4	5	17	14	19	1		4
最小值	0.69	2.83	22.41	0.89	15.31	9.74	1.00	72369.97
發生時間	15	21	15	19	13	15		16
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.06 %		0.00		0.00 %
全幅偏移(率)	0.04 %	-0.04 %	-0.20 %	0.09 %		0.36		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								