

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月19日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.04	7.69	54.99	0.67	18.50	11.07	1.10	76549.30
1	2.68	7.96	52.77	0.59	19.20	11.10	1.10	76185.73
2	8.00	14.05	54.44	0.72	21.49	10.48	1.10	78826.80
3	8.61	3.40	42.59	1.55	17.08	11.16	1.09	77006.29
4	9.21	3.74	45.46	1.71	15.96	11.74	1.09	74471.52
5	7.97	6.62	69.23	1.37	17.17	12.19	1.09	70423.26
6	1.74	6.60	53.92	0.63	18.25	11.73	1.10	71707.35
7	9.76	5.36	41.17	1.11	18.75	10.40	1.08	81508.05
8	8.11	5.60	59.14	1.16	17.48	11.24	1.05	76048.73
9	8.54	5.37	52.88	1.30	17.49	11.27	1.08	75456.57
10	9.60	6.62	48.63	1.38	17.17	11.26	1.06	75192.51
11	9.98	6.95	51.38	1.60	17.35	11.40	1.07	73824.83
12	9.92	7.57	49.61	1.71	17.41	11.55	1.08	73187.92
13	9.61	8.70	45.98	1.85	16.69	11.61	1.05	72878.12
14	7.99	7.07	54.51	1.26	17.50	11.63	1.05	72187.23
15	9.17	7.33	45.78	1.13	17.25	11.41	1.05	74492.93
16	9.19	6.97	49.70	1.04	17.41	11.42	1.09	74496.55
17	9.41	6.87	52.48	1.20	17.37	11.50	1.06	73515.14
18	9.78	7.68	51.16	1.56	16.41	11.65	1.05	73590.57
19	7.63	7.01	60.70	1.29	16.67	11.63	1.05	74088.76
20	9.69	6.77	58.48	1.53	16.35	11.42	1.08	75830.00
21	10.29	7.01	55.94	1.02	17.10	11.26	1.09	76759.53
22	9.46	7.51	54.41	0.94	17.25	11.49	1.10	74567.30
23	9.13	6.95	52.72	1.11	16.54	11.59	1.10	74112.04
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.44	6.97	52.42	1.23	17.49	11.38	1.08	74871.13
最大值	10.29	14.05	69.23	1.85	21.49	12.19	1.12	81508.05
發生時間	21	2	5	13	2	5		7
最小值	1.74	3.40	41.17	0.59	15.96	10.40	1.04	70423.26
發生時間	6	3	7	1	4	7		5
零點偏移(率)	0.00 %	0.00 %	-0.01 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.86 %	-0.05 %	-0.02 %		0.10		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月19日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.36	3.92	57.71	1.89	16.40	10.54	1.05	83805.95
1	7.29	3.63	54.81	2.04	16.66	10.02	1.05	87618.30
2	6.26	2.69	56.16	2.54	16.93	10.42	1.05	84352.48
3	5.08	3.51	53.76	2.80	15.95	10.32	1.05	86705.29
4	4.99	3.67	58.44	2.90	15.91	10.71	1.05	83762.15
5	2.28	4.82	53.77	1.16	19.01	9.88	1.06	86896.68
6	9.08	5.84	38.97	2.64	17.34	9.94	1.03	90086.40
7	9.68	4.78	48.09	2.63	16.98	9.95	1.01	87874.29
8	9.06	2.35	53.64	3.12	16.08	10.30	1.01	86057.31
9	10.18	1.66	47.77	2.74	16.28	10.20	1.05	87349.01
10	8.66	3.41	52.83	2.83	16.53	10.18	1.01	86434.80
11	9.07	3.31	52.42	2.34	16.64	10.15	1.04	87169.12
12	9.53	3.25	49.61	2.81	16.48	10.14	1.05	86797.25
13	9.18	7.09	53.50	3.00	15.50	10.53	1.02	84602.27
14	9.77	3.75	55.19	2.86	15.48	10.47	1.01	84785.82
15	8.59	3.54	56.36	2.41	16.12	10.43	1.01	85331.36
16	9.25	4.03	56.47	2.59	16.33	10.48	1.04	84089.71
17	9.15	4.22	53.85	2.36	17.19	10.08	1.01	86651.52
18	9.56	3.93	50.56	2.63	15.88	10.49	0.99	84875.50
19	9.10	4.31	52.58	2.18	16.14	10.44	0.99	84613.03
20	9.39	3.44	53.05	2.77	15.23	10.63	1.01	84095.94
21	10.48	3.39	58.52	2.88	14.68	10.62	1.03	85223.73
22	9.07	4.66	57.02	2.72	14.24	10.92	1.04	82557.48
23	9.21	3.40	57.73	1.65	16.58	10.33	1.04	86109.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.39	3.86	53.45	2.52	16.27	10.34	1.03	85743.54
最大值	10.48	7.09	58.52	3.12	19.01	10.92	1.07	90086.40
發生時間	21	13	21	8	5	22		6
最小值	2.28	1.66	38.97	1.16	14.24	9.88	0.99	82557.48
發生時間	5	9	6	5	22	5		22
零點偏移(率)	-0.07 %	-0.14 %	-0.10 %	-0.03 %		0.07		0.00 %
全幅偏移(率)	0.02 %	0.07 %	0.09 %	-0.17 %		0.08		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月19日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.32	5.29	54.31	1.02	15.31	10.98	1.02	76787.50
1	0.94	6.56	47.11	1.03	15.19	10.93	1.02	75995.22
2	3.37	5.56	50.42	1.18	16.32	10.97	1.02	75176.12
3	2.60	8.31	48.82	1.54	14.43	11.28	1.02	71631.92
4	0.21	5.70	45.69	1.04	14.76	10.98	1.02	73921.09
5	0.72	9.49	47.30	0.71	16.28	10.64	1.02	76161.37
6	0.60	6.52	59.89	0.62	16.14	11.50	1.01	70664.73
7	2.30	7.16	63.81	1.03	15.70	11.65	1.01	76190.92
8	5.04	4.89	51.52	1.04	16.44	10.91	1.02	84459.36
9	8.45	4.79	55.00	2.01	14.60	11.26	1.03	79831.52
10	12.86	5.05	48.01	2.10	16.04	10.58	1.04	82702.95
11	16.78	5.78	46.41	3.00	15.26	10.68	1.02	80228.80
12	12.43	8.82	47.86	3.04	14.49	11.05	1.02	78413.23
13	16.50	5.66	47.08	4.12	14.77	10.96	1.02	78116.22
14	11.16	5.93	44.90	3.14	14.48	10.89	1.02	77792.50
15	12.37	6.42	50.74	2.70	14.08	11.43	1.01	76141.98
16	13.01	4.82	55.27	1.85	16.23	10.67	1.02	82079.52
17	7.60	7.07	42.17	1.42	15.34	10.65	1.02	77492.77
18	2.70	5.26	48.55	1.16	14.61	11.05	1.00	72626.09
19	0.96	4.32	52.72	0.93	14.58	11.02	1.02	73346.96
20	2.39	4.24	62.62	1.02	15.11	10.38	1.02	79539.21
21	12.06	4.33	58.39	3.26	12.85	10.82	0.99	73798.66
22	10.18	6.85	52.41	2.60	12.76	11.34	0.99	70774.31
23	7.35	7.71	52.43	1.54	14.28	10.90	0.99	73641.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.83	6.11	51.39	1.80	15.00	10.98	1.01	76563.10
最大值	16.78	9.49	63.81	4.12	16.44	11.65	1.05	84459.36
發生時間	11	5	7	13	8	7		8
最小值	0.21	4.24	42.17	0.62	12.76	10.38	0.99	70664.73
發生時間	4	20	17	6	22	20		6
零點偏移(率)	-0.04 %	-0.04 %	-0.01 %	-0.06 %		0.03		0.00 %
全幅偏移(率)	0.02 %	-0.04 %	-0.29 %	-0.03 %		0.06		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								