

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.85	3.32	53.37	5.68	15.45	12.04	1.40	70059.01
1	10.77	3.81	59.17	4.58	15.98	12.48	1.44	68490.24
2	8.66	3.22	48.38	4.82	15.88	12.09	1.43	70309.62
3	11.09	2.51	57.74	4.70	15.41	12.49	1.43	68780.97
4	9.99	1.87	57.11	4.40	16.89	11.96	1.42	72273.98
5	8.49	3.84	66.71	4.23	15.17	12.66	1.41	68401.75
6	5.43	2.87	43.64	3.99	15.55	12.40	1.42	69921.12
7	9.74	2.35	42.30	4.36	17.43	11.72	1.42	73798.89
8	6.84	2.49	40.32	4.31	15.54	12.41	1.40	68920.62
9	2.48	2.22	68.02	3.58	15.64	12.40	1.41	69004.87
10	4.48	3.37	59.41	4.78	14.48	12.64	1.36	67823.88
11	4.09	3.15	60.47	4.14	15.32	12.50	1.39	68023.51
12	7.88	9.95	62.91	6.46	13.43	12.94	1.39	65674.05
13	10.13	6.40	57.48	9.16	13.46	12.98	1.36	64935.32
14	9.78	13.34	61.55	11.61	12.68	13.06	1.33	64721.66
15	10.67	17.78	52.25	8.85	12.82	12.86	1.32	63031.22
16	9.96	7.05	58.17	7.90	12.89	13.11	1.32	59257.21
17	9.53	1.57	58.06	6.16	14.14	12.73	1.29	63169.36
18	8.00	2.29	65.60	4.86	15.22	12.39	1.32	68763.08
19	8.53	5.94	50.83	5.73	14.15	12.60	1.33	66429.81
20	2.74	2.20	50.34	3.73	15.51	12.05	1.30	65274.10
21	3.92	4.04	43.75	4.32	14.72	11.86	1.27	62972.94
22	4.09	2.40	55.84	3.99	16.53	11.79	1.23	61487.15
23	8.29	2.38	51.22	4.96	15.30	11.99	1.24	64662.71
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.73	4.60	55.19	5.47	14.98	12.42	1.36	66924.46
最大值	11.09	17.78	68.02	11.61	17.43	13.11	1.47	73798.89
發生時間	3	15	9	14	7	16		7
最小值	2.48	1.57	40.32	3.58	12.68	11.72	1.23	59257.21
發生時間	9	17	8	9	14	7		16
零點偏移(率)	-0.06 %	-0.02 %	-0.02 %	0.00 %		-0.03	0.00	0.00 %
全幅偏移(率)	3.56 %	0.46 %	0.10 %	0.18 %		-0.12	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.69	1.24	67.99	1.36	19.81	9.30	1.40	83787.77
1	10.64	1.63	51.52	2.23	19.14	9.47	1.38	87483.10
2	7.36	1.68	64.46	2.06	18.74	10.22	1.37	78033.08
3	9.17	2.62	46.84	1.67	22.96	8.49	1.36	93674.18
4	8.75	2.59	51.16	2.04	20.34	9.35	1.36	89655.50
5	8.08	3.38	53.69	1.78	20.51	9.52	1.36	86877.81
6	6.67	3.35	54.73	1.38	20.83	10.27	1.38	82909.54
7	4.90	2.70	56.99	1.21	21.18	9.43	1.39	87993.29
8	10.54	1.83	48.81	2.14	19.41	9.70	1.43	88796.84
9	10.66	1.81	59.02	2.08	19.61	9.68	1.42	87918.90
10	11.62	2.53	54.57	2.91	16.83	10.27	1.39	84174.88
11	9.57	2.37	62.32	2.91	15.89	10.32	1.40	82170.36
12	8.16	2.18	55.03	2.08	17.94	9.94	1.40	81306.47
13	5.00	1.97	58.02	1.90	17.43	10.47	1.41	77711.65
14	9.95	6.18	52.37	2.69	16.26	9.84	1.40	84337.11
15	7.54	4.38	44.29	2.26	16.40	9.51	1.39	80409.74
16	9.27	1.93	57.39	2.17	17.76	9.76	1.38	80444.34
17	9.36	4.05	43.77	2.02	18.05	9.15	1.39	86296.25
18	5.42	2.34	63.74	2.01	16.99	10.28	1.41	77196.31
19	5.99	1.90	65.92	1.74	19.91	9.59	1.42	84122.77
20	10.45	3.03	44.87	2.04	19.12	9.43	1.39	85987.32
21	7.43	1.87	58.73	2.00	17.98	10.20	1.38	78772.54
22	2.58	1.86	61.62	1.84	17.09	11.41	1.39	70374.81
23	0.47	1.99	43.23	1.35	19.08	10.42	1.40	81159.26
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.72	2.56	55.04	1.99	18.72	9.83	1.39	83399.74
最大值	11.62	6.18	67.99	2.91	22.96	11.41	1.43	93674.18
發生時間	10	14	0	10	3	22		3
最小值	0.47	1.24	43.23	1.21	15.89	8.49	1.36	70374.81
發生時間	23	0	23	7	11	3		22
零點偏移(率)	-0.05 %	-0.01 %	-0.02 %	-0.02 %		0.00	0.00	0.00 %
全幅偏移(率)	0.75 %	0.60 %	-0.34 %	0.07 %		0.20	-0.03	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年05月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.74	3.03	56.46	2.68	19.10	9.41	1.37	86573.95
1	9.98	4.08	50.62	2.76	16.92	10.02	1.38	84592.54
2	10.69	5.02	48.57	3.46	19.47	8.67	1.38	90187.65
3	10.81	10.42	42.82	2.69	17.99	9.68	1.38	84024.00
4	7.36	3.98	41.00	2.34	20.81	9.21	1.38	85414.65
5	10.22	1.74	59.75	2.87	19.01	9.64	1.38	87793.71
6	7.41	3.47	48.26	2.25	19.23	9.68	1.38	86431.44
7	9.40	2.47	52.25	3.20	19.92	9.32	1.36	88697.42
8	10.20	3.63	45.36	2.84	19.03	9.64	1.38	86854.33
9	9.29	3.13	48.54	2.80	18.06	9.91	1.37	84163.16
10	9.30	2.75	55.12	2.91	18.02	9.72	1.40	84594.74
11	8.99	3.97	56.10	3.01	16.32	10.07	1.36	81283.31
12	5.48	4.13	49.24	2.62	15.31	10.60	1.37	77845.94
13	7.00	3.54	58.05	2.73	17.26	10.07	1.38	84576.12
14	9.66	3.45	56.28	3.22	15.42	10.63	1.38	78297.83
15	7.57	3.86	55.84	2.57	16.40	10.41	1.35	80647.90
16	11.74	5.29	53.65	3.86	14.43	10.70	1.33	78342.21
17	8.62	2.28	58.32	2.76	16.28	10.89	1.36	79572.26
18	3.64	1.94	65.69	2.39	17.56	10.82	1.37	78521.16
19	2.99	2.64	54.65	2.23	18.49	10.01	1.38	83913.87
20	4.09	4.75	52.15	2.70	16.07	10.74	1.41	82949.41
21	3.10	2.89	66.87	2.98	15.22	11.64	1.40	76526.84
22	1.35	1.87	66.57	2.47	17.33	11.31	1.40	76991.41
23	2.33	3.00	57.47	2.69	17.80	11.06	1.39	80402.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.58	3.64	54.15	2.79	17.56	10.16	1.38	82883.26
最大值	11.74	10.42	66.87	3.86	20.81	11.64	1.42	90187.65
發生時間	16	3	21	16	4	21		2
最小值	1.35	1.74	41.00	2.23	14.43	8.67	1.31	76526.84
發生時間	22	5	4	19	16	2		21
零點偏移(率)	-0.01 %	0.00 %	-0.01 %	-0.06 %		-0.03	0.00	0.00 %
全幅偏移(率)	2.80 %	0.53 %	-0.83 %	0.14 %		-0.16	0.02	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								