

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.61	12.61	56.79	2.94	16.64	10.71	1.21	86922.11
1	9.72	13.23	67.48	1.59	19.94	10.40	1.22	85778.81
2	4.74	12.83	55.37	2.10	18.82	11.02	1.20	82224.91
3	13.32	12.57	61.04	2.07	18.17	11.13	1.23	82523.01
4	5.31	12.56	65.69	1.96	18.41	11.04	1.23	82645.98
5	8.39	11.90	55.28	2.10	18.43	11.35	1.20	85974.09
6	8.42	12.14	53.02	2.62	16.77	11.85	1.19	77109.47
7	7.77	11.77	55.64	2.61	17.54	11.45	1.23	80054.15
8	10.36	11.58	57.11	2.19	19.38	11.09	1.21	80748.64
9	7.46	11.42	54.56	2.67	18.52	11.05	1.20	82657.81
10	7.64	11.32	42.58	4.12	16.07	11.17	1.20	83557.30
11	11.00	11.40	50.39	2.60	18.06	11.12	1.20	82070.70
12	8.87	11.99	50.41	2.40	17.61	11.34	1.19	80609.13
13	11.47	13.24	56.26	2.72	18.09	11.40	1.19	79471.83
14	9.82	12.86	49.42	2.85	16.50	11.48	1.19	80619.40
15	10.76	12.69	59.33	2.76	17.36	11.20	1.19	81968.09
16	13.94	12.82	54.47	3.88	17.06	11.12	1.19	82621.39
17	6.66	12.57	54.88	2.10	17.83	10.72	1.18	84778.87
18	7.57	13.23	59.36	2.01	17.25	11.50	1.18	79341.77
19	10.48	12.74	54.38	2.65	17.49	11.25	1.18	81912.06
20	9.92	13.13	60.40	3.04	16.71	11.63	1.19	79126.32
21	4.60	13.04	57.21	2.37	17.79	11.44	1.21	79481.57
22	5.02	12.77	65.29	1.54	18.40	11.19	1.20	81171.87
23	7.16	12.86	61.45	1.82	18.98	11.16	1.21	80890.96
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.71	12.47	56.58	2.49	17.83	11.20	1.20	81844.18
最 大 值	13.94	13.24	67.48	4.12	19.94	11.85	1.25	86922.11
發生時間	16	13	1	10	1	6		0
最 小 值	4.60	11.32	42.58	1.54	16.07	10.40	1.18	77109.47
發生時間	21	10	10	22	10	1		6
零點偏移(率)	-0.04 %	-0.01 %	-0.03 %	-0.00 %		-0.02	-0.01	0.10 %
全幅偏移(率)	2.67 %	0.44 %	-0.18 %	1.70 %		-0.04	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 115年07月03日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月03日

報表日期: 115年07月03日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.79	11.54	57.64	3.16	17.97	9.81	1.30	68628.83
1	3.48	12.60	53.47	3.16	18.09	8.97	1.30	74722.58
2	6.22	10.97	53.18	3.33	18.60	8.86	1.31	76211.30
3	7.44	11.14	51.78	3.58	20.18	8.31	1.32	77468.78
4	8.52	11.13	54.02	3.73	20.45	8.78	1.35	77503.23
5	4.78	10.97	46.68	3.31	19.47	8.67	1.34	75776.63
6	4.31	10.88	49.52	3.49	19.87	8.93	1.34	73614.90
7	2.37	12.37	55.69	3.21	17.66	9.66	1.30	72511.83
8	3.02	10.97	58.40	1.63	19.06	9.29	1.31	72468.97
9	6.62	10.53	57.33	1.64	18.66	9.05	1.32	74058.71
10	7.96	10.56	54.53	1.64	19.03	8.82	1.29	76499.11
11	9.58	10.69	52.10	1.61	18.47	8.79	1.29	76832.49
12	9.30	11.06	56.29	1.54	18.67	9.19	1.31	75534.68
13	9.69	11.97	55.96	1.57	18.67	9.44	1.31	73589.18
14	10.03	12.06	54.20	1.67	17.77	9.44	1.30	74247.68
15	12.08	11.84	58.20	2.90	18.22	9.38	1.28	75543.58
16	6.76	12.35	47.75	3.01	18.29	9.12	1.27	77519.95
17	9.24	12.30	54.13	3.07	16.94	9.76	1.30	73731.22
18	5.64	12.65	59.60	2.98	17.18	10.22	1.30	70023.12
19	8.93	11.92	59.57	3.14	17.48	9.57	1.31	75556.28
20	8.93	12.17	62.05	3.21	17.94	9.77	1.30	73401.84
21	8.68	12.37	64.53	3.37	18.56	9.81	1.30	72186.19
22	8.61	12.10	54.72	3.42	19.43	9.24	1.30	76371.41
23	6.21	12.41	60.86	3.05	18.71	9.81	1.30	71738.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.17	11.65	55.51	2.77	18.56	9.28	1.31	74405.89
最 大 值	12.08	12.65	64.53	3.73	20.45	10.22	1.36	77519.95
發生時間	15	18	21	4	4	18		16
最 小 值	2.37	10.53	46.68	1.54	16.94	8.31	1.27	68628.83
發生時間	7	9	5	12	17	3		0
零點偏移(率)	-0.32 %	-0.00 %	-0.01 %	0.00 %		-0.02	-0.01	-0.10 %
全幅偏移(率)	-1.05 %	-1.31 %	-1.16 %	-0.80 %		0.35	0.00	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								