

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月09日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.72	6.04	54.40	1.39	15.34	11.59	1.06	80283.04
1	9.70	6.66	46.17	2.34	14.56	11.58	1.06	80363.13
2	9.23	5.49	52.43	2.84	13.46	11.77	1.06	79890.78
3	7.53	5.39	56.11	3.78	12.82	12.10	1.06	79770.42
4	11.95	8.03	45.45	2.95	12.31	12.03	1.05	77641.91
5	6.84	1.86	41.13	2.82	13.16	11.06	1.00	71833.32
6	5.71	3.10	50.05	3.01	12.96	11.70	1.01	76379.81
7	6.42	4.47	62.03	1.82	14.40	12.00	1.03	77482.11
8	8.30	7.04	51.78	1.95	14.45	11.74	1.05	82309.47
9	10.35	7.09	59.24	3.18	13.19	11.95	1.05	79926.53
10	9.13	4.42	65.41	1.69	14.17	11.71	1.03	79341.85
11	9.23	7.15	50.63	2.06	13.93	11.66	1.02	81521.26
12	9.66	12.49	54.93	2.75	13.15	11.96	1.02	78753.29
13	9.89	8.35	51.30	3.32	12.79	12.02	1.01	77792.51
14	6.41	8.53	61.63	2.13	13.50	12.18	1.02	76744.06
15	11.11	8.24	55.21	3.28	13.24	11.77	1.02	78913.23
16	8.34	8.12	58.03	1.99	14.21	11.77	1.02	77764.36
17	7.40	6.36	60.82	1.98	14.04	11.90	1.02	77612.54
18	9.03	6.04	60.49	1.29	15.48	11.62	1.02	79661.17
19	8.25	6.30	60.05	1.27	15.45	11.86	1.02	77523.31
20	6.05	5.89	56.54	1.30	14.73	11.73	1.04	80294.18
21	6.66	6.16	57.13	1.51	14.70	12.04	1.03	77764.35
22	6.10	6.36	49.86	1.90	14.47	11.65	1.03	81995.41
23	7.86	7.49	55.55	1.34	15.42	11.69	1.02	81371.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.33	6.54	54.85	2.25	14.00	11.80	1.03	78872.22
最 大 值	11.95	12.49	65.41	3.78	15.48	12.18	1.06	82309.47
發生時間	4	12	10	3	18	14		8
最 小 值	5.71	1.86	41.13	1.27	12.31	11.06	0.99	71833.32
發生時間	6	5	5	19	4	5		5
零點偏移(率)	-0.04 %	-0.00 %	-0.07 %	-0.01 %		0.00		0.30 %
全幅偏移(率)	-0.77 %	-0.41 %	-0.24 %	-0.08 %		0.29		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月09日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年03月09日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.37	5.13	57.20	1.00	15.47	10.49	1.04	76491.01
1	1.93	5.78	59.86	0.60	17.18	10.49	1.06	78221.74
2	6.78	6.71	55.87	1.06	15.52	10.60	1.06	78466.61
3	5.38	5.69	55.80	0.76	16.33	10.18	1.04	79618.21
4	4.88	5.53	56.95	0.82	16.07	10.20	1.04	79198.08
5	2.32	5.27	57.65	0.58	15.68	10.69	1.04	75978.00
6	5.23	5.79	63.65	1.12	14.99	11.31	1.04	71320.06
7	2.59	3.14	59.86	0.97	16.37	11.58	1.12	72388.42
8	4.40	3.75	39.10	0.38	16.94	10.28	1.09	81156.87
9	7.04	5.32	47.50	1.07	15.35	10.39	1.09	80342.28
10	3.78	4.90	54.70	1.29	14.19	10.79	1.05	76423.07
11	1.98	4.59	56.39	0.93	14.55	10.71	1.04	76769.92
12	4.24	8.75	56.48	2.20	13.04	11.04	1.04	77116.23
13	6.88	5.33	63.83	2.56	12.96	11.34	1.04	74565.15
14	7.49	4.50	59.92	1.70	14.18	11.22	1.04	75877.29
15	5.52	6.18	53.62	1.34	15.01	11.24	1.06	77369.67
16	4.80	4.38	42.38	0.89	15.28	10.99	1.06	79237.10
17	1.68	3.89	51.71	0.53	16.12	11.01	1.05	78512.94
18	6.64	4.26	63.55	1.13	15.05	11.35	1.04	76774.11
19	2.40	5.74	62.58	0.95	15.31	11.39	1.07	77587.16
20	3.38	4.04	56.81	1.00	15.19	10.88	1.05	81525.11
21	4.67	4.53	53.92	1.23	14.71	11.06	1.05	80404.98
22	5.73	4.30	62.12	0.82	15.70	10.98	1.06	80259.15
23	3.17	4.84	61.50	0.77	15.62	10.79	1.05	80223.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.39	5.10	56.37	1.07	15.28	10.88	1.05	77742.77
最 大 值	7.49	8.75	63.83	2.56	17.18	11.58	1.31	81525.11
發生時間	14	12	13	13	1	7		20
最 小 值	1.68	3.14	39.10	0.38	12.96	10.18	1.04	71320.06
發生時間	17	7	8	8	13	3		6
零點偏移(率)	-0.69 %	-0.02 %	-0.04 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.02 %	0.13 %	-0.11 %	0.01 %		0.33		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								