

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月04日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.84	6.69	49.31	1.39	18.47	11.37	1.01	73704.87
1	3.93	7.29	50.76	0.94	18.86	12.12	1.00	68059.99
2	7.94	6.50	48.22	1.87	17.72	11.69	0.99	71840.48
3	7.43	2.46	60.01	1.12	18.23	11.71	0.99	71703.80
4	4.68	2.41	64.40	0.76	18.72	11.69	0.99	71537.59
5	1.84	10.59	64.08	0.35	20.83	11.12	0.99	72641.83
6	5.18	6.42	35.93	0.29	22.26	10.42	0.99	78147.95
7	7.06	6.58	47.23	1.12	19.06	11.47	0.99	72238.78
8	1.16	6.61	46.04	0.98	19.51	12.24	1.02	67035.49
9	5.11	8.54	40.32	0.95	20.08	11.40	0.99	72284.83
10	9.89	7.23	39.31	1.08	20.86	10.54	1.00	78114.12
11	9.37	5.78	39.70	1.74	18.86	11.13	1.00	74676.14
12	9.29	6.20	42.37	0.52	21.56	10.60	1.02	76817.03
13	8.92	6.18	48.69	0.82	20.95	10.71	1.02	76759.82
14	8.89	8.11	43.25	1.48	18.45	11.35	1.02	73706.11
15	9.87	7.03	41.93	1.78	19.00	11.32	1.02	73728.85
16	8.39	6.71	48.58	1.00	19.78	11.30	1.02	73229.07
17	3.69	6.13	48.36	0.63	20.15	10.95	1.02	75946.02
18	8.49	6.46	43.21	0.83	21.00	10.75	1.01	76464.77
19	8.73	8.41	45.95	0.76	20.73	10.94	1.01	75957.18
20	9.61	5.82	46.16	0.93	20.04	10.74	1.02	77428.91
21	9.97	6.53	37.02	1.23	19.21	11.01	1.02	75650.39
22	8.58	5.93	40.83	1.58	17.40	11.83	1.02	71432.20
23	8.74	6.19	45.18	1.28	19.17	11.56	1.03	72095.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.28	6.53	46.54	1.06	19.62	11.25	1.01	73800.08
最大值	9.97	10.59	64.40	1.87	22.26	12.24	1.06	78147.95
發生時間	21	5	4	2	6	8		6
最小值	1.16	2.41	35.93	0.29	17.40	10.42	0.96	67035.49
發生時間	8	4	6	6	22	6		8
零點偏移(率)	0.00 %	-0.01 %	-0.00 %	0.00 %		0.01		0.00 %
全幅偏移(率)	0.02 %	1.27 %	-0.16 %	0.26 %		0.07		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月04日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.01	6.01	51.65	1.27	18.25	10.08	1.03	85192.54
1	2.33	5.18	44.59	1.53	19.26	10.02	1.02	84164.18
2	4.45	3.32	44.29	1.81	17.34	10.73	1.02	81072.67
3	7.62	3.60	54.56	1.65	17.81	10.89	1.02	81173.62
4	4.01	7.90	42.48	1.66	18.31	10.34	1.02	85878.74
5	6.31	5.16	40.20	1.56	18.52	10.04	1.04	86188.35
6	8.65	8.07	54.74	2.12	17.82	9.95	1.01	83332.70
7	9.37	3.12	57.07	1.71	18.67	10.10	1.00	84579.24
8	7.90	12.96	45.67	2.06	17.98	9.84	1.01	87194.02
9	5.30	3.53	44.57	2.05	17.30	10.30	1.00	84266.12
10	7.53	4.61	40.80	2.34	17.11	10.26	0.99	84990.08
11	8.72	2.24	55.17	2.53	16.69	10.47	0.99	85162.51
12	9.25	3.50	58.43	1.59	18.45	10.10	0.97	86935.79
13	9.46	8.90	52.93	2.03	17.54	10.31	0.99	85210.65
14	11.51	7.33	49.41	2.64	16.12	10.72	0.97	85117.92
15	10.83	4.62	61.69	2.60	15.83	10.68	0.97	84843.38
16	10.75	9.77	61.05	2.44	15.42	10.85	0.97	84107.19
17	8.62	3.00	53.65	1.39	17.75	10.21	0.99	86334.14
18	7.69	6.71	65.05	1.22	17.51	10.27	0.99	85506.58
19	8.30	11.16	39.81	2.09	16.41	10.58	0.99	83962.81
20	8.89	4.40	48.46	1.59	16.96	10.45	0.97	84372.82
21	9.04	6.71	59.99	1.46	17.26	10.36	0.98	84753.47
22	9.78	6.57	52.27	2.08	16.31	10.77	1.00	81612.31
23	9.15	9.55	58.12	2.29	15.98	10.69	0.98	82119.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.98	6.16	51.53	1.90	17.36	10.38	1.00	84502.99
最大值	11.51	12.96	65.05	2.64	19.26	10.89	1.09	87194.02
發生時間	14	8	18	14	1	3		8
最小值	2.33	2.24	39.81	1.22	15.42	9.84	0.97	81072.67
發生時間	1	11	19	18	16	8		2
零點偏移(率)	-0.02 %	-0.01 %	-0.03 %	0.00 %		0.02		-0.20 %
全幅偏移(率)	0.04 %	0.12 %	-0.38 %	-0.03 %		-0.11		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月04日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.31	5.52	44.09	1.84	16.98	10.43	0.98	77211.83
1	7.08	3.74	46.02	1.41	17.43	11.10	0.97	72907.79
2	6.36	8.84	39.59	2.07	16.17	10.82	0.97	75011.78
3	8.90	6.57	49.33	2.37	15.63	10.94	0.97	73758.86
4	7.00	5.43	52.40	1.70	16.93	10.25	0.97	77442.36
5	8.69	6.51	44.88	1.73	16.46	10.52	0.95	75991.08
6	8.51	5.24	45.96	1.49	17.46	10.44	0.96	76911.88
7	9.42	11.88	36.61	1.64	16.60	10.39	0.99	79262.79
8	5.97	2.13	56.15	1.44	16.58	11.13	0.99	79787.74
9	0.72	1.72	55.99	1.40	15.29	12.25	0.99	72907.91
10	4.84	4.84	51.40	1.24	16.99	11.31	0.99	84088.71
11	5.88	4.86	55.06	1.66	15.73	11.64	1.00	81431.14
12	8.35	9.41	50.04	1.90	15.97	11.29	0.99	82859.22
13	7.99	4.88	49.50	2.04	15.34	11.70	0.99	79840.41
14	7.81	3.91	56.68	2.46	14.51	12.05	0.99	78576.21
15	6.76	10.26	46.65	1.54	16.72	11.23	0.99	81400.84
16	9.84	3.68	45.77	2.46	15.34	11.40	0.99	78707.59
17	8.45	4.05	54.13	1.78	15.72	11.51	1.01	79161.89
18	8.90	7.30	43.74	1.77	16.35	10.60	1.02	81693.11
19	8.20	8.14	45.79	1.52	16.29	10.62	1.00	81166.53
20	6.30	7.53	47.77	1.42	16.32	10.67	0.99	78680.83
21	5.65	9.85	42.11	1.10	17.67	9.97	1.00	82385.61
22	7.65	5.83	50.01	1.77	15.47	10.89	0.99	76579.36
23	10.39	7.99	53.06	2.32	15.46	10.99	1.02	79178.92
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.42	6.25	48.45	1.75	16.23	11.01	0.99	78622.68
最大值	10.39	11.88	56.68	2.46	17.67	12.25	1.03	84088.71
發生時間	23	7	14	14	21	9		10
最小值	0.72	1.72	36.61	1.10	14.51	9.97	0.94	72907.79
發生時間	9	9	7	21	14	21		1
零點偏移(率)	-0.31 %	-0.02 %	-0.07 %	-0.08 %		0.02		0.00 %
全幅偏移(率)	0.00 %	1.18 %	-0.13 %	0.31 %		0.22		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								