

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 113年10月03日

報表日期: 113年10月03日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.45	3.24	50.90	1.62	16.66	11.60	1.02	82656.96
1	9.41	3.43	46.84	1.63	16.57	11.46	1.02	83614.40
2	8.65	3.07	48.62	1.45	16.80	11.78	1.02	81443.61
3	7.18	3.26	63.86	0.59	17.94	11.25	1.02	84847.40
4	7.34	3.66	59.85	1.41	15.88	11.86	1.02	80626.01
5	4.52	5.44	56.14	0.50	17.93	11.45	1.05	87026.75
6	6.97	3.26	62.08	0.54	18.03	11.57	1.06	81572.57
7	8.97	3.58	51.81	0.94	16.85	11.66	1.05	81567.90
8	8.43	3.03	50.50	0.67	18.18	11.44	1.05	82442.65
9	6.95	3.19	46.61	0.60	17.55	11.42	1.07	83157.92
10	9.04	3.02	57.20	0.82	16.81	11.38	1.06	84388.84
11	6.80	3.33	62.06	0.55	17.04	11.87	1.06	79506.56
12	5.48	3.94	55.68	0.38	18.03	11.29	1.05	83717.99
13	7.62	3.39	49.95	0.69	17.39	11.36	1.04	83735.61
14	7.39	3.34	55.93	0.54	17.16	11.65	1.05	81612.74
15	7.77	3.43	55.13	0.48	17.25	11.56	1.06	82074.26
16	8.63	3.32	50.32	0.60	17.87	11.56	1.06	81151.35
17	8.70	3.25	43.15	0.50	18.09	11.17	1.06	84450.02
18	8.32	3.34	39.54	0.78	17.22	11.45	1.06	82728.77
19	8.41	3.89	50.47	0.29	18.34	11.05	1.07	85894.37
20	4.66	6.03	47.53	0.49	18.06	11.16	1.06	85083.78
21	11.48	5.16	40.26	0.78	17.47	11.16	1.07	85494.75
22	8.29	4.16	51.11	0.53	18.84	11.18	1.06	83728.44
23	9.28	3.47	50.21	0.53	18.22	11.25	1.07	83879.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.95	3.68	51.91	0.75	17.51	11.44	1.05	83183.47
最 大 值	11.48	6.03	63.86	1.63	18.84	11.87	1.11	87026.75
發生時間	21	20	3	1	22	11		5
最 小 值	4.52	3.02	39.54	0.29	15.88	11.05	1.02	79506.56
發生時間	5	10	18	19	4	19		11
零點偏移(率)	-0.08 %	0.00 %	-0.03 %	-0.01 %		-0.06		0.00 %
全幅偏移(率)	0.00 %	0.35 %	-0.51 %	0.37 %		0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 113年10月03日

報表日期: 113年10月03日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	13.72	2.46	54.82	2.06	15.70	11.21	1.73	78742.03
1	11.49	2.61	53.32	2.43	14.51	11.53	1.72	77405.44
2	17.19	2.50	52.53	3.09	14.43	11.27	1.70	77351.72
3	6.78	1.92	52.49	2.54	15.32	11.03	1.69	75159.58
4	7.74	2.47	45.78	2.60	15.56	10.96	1.71	75448.07
5	8.21	2.81	50.03	2.11	17.42	10.54	1.74	79214.38
6	8.12	2.40	54.14	1.72	16.77	10.82	1.74	77322.55
7	10.04	3.03	51.95	1.16	16.92	10.72	1.70	79029.52
8	8.58	2.47	54.17	0.96	17.51	10.46	1.70	78106.71
9	10.54	4.79	46.58	1.24	15.85	10.90	1.73	77596.53
10	10.06	3.58	50.19	1.15	15.85	10.90	1.73	76925.79
11	7.08	3.83	59.45	0.85	17.54	10.84	1.72	77594.59
12	7.97	4.39	49.60	0.97	16.23	10.70	1.69	76442.61
13	10.32	4.31	52.24	0.80	18.19	10.34	1.69	77746.29
14	8.42	3.68	59.58	1.01	16.84	10.66	1.69	77945.37
15	10.40	3.79	51.95	1.06	16.46	10.89	1.69	77471.38
16	10.66	3.53	54.95	1.12	16.42	10.85	1.70	77781.73
17	7.10	5.25	52.99	0.65	17.24	10.82	1.70	76647.99
18	10.41	4.09	48.44	1.04	17.10	10.51	1.72	79189.29
19	7.71	1.90	42.97	1.41	14.85	10.89	1.71	73466.25
20	6.63	1.29	50.82	1.35	16.04	10.96	1.69	76996.44
21	7.66	1.91	53.90	0.93	16.10	11.00	1.69	78888.71
22	11.79	2.18	51.54	1.36	15.33	11.31	1.69	75247.81
23	9.84	1.85	56.49	1.03	16.82	10.96	1.72	78457.24
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.52	3.04	52.12	1.44	16.29	10.88	1.71	77340.75
最 大 值	17.19	5.25	59.58	3.09	18.19	11.53	1.76	79214.38
發生時間	2	17	14	2	13	1		5
最 小 值	6.63	1.29	42.97	0.65	14.43	10.34	1.69	73466.25
發生時間	20	20	19	17	2	13		19
零點偏移(率)	-0.16 %	-0.01 %	-0.14 %	-0.00 %		-0.01		-0.10 %
全幅偏移(率)	0.02 %	0.03 %	0.28 %	0.22 %		0.34		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								