

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.94	12.59	59.45	1.36	16.64	10.68	0.97	78256.11
1	2.78	12.96	57.05	2.01	17.22	10.52	0.97	78044.67
2	2.33	12.06	56.56	2.41	15.83	10.59	0.97	78840.50
3	2.39	12.54	58.50	2.30	15.48	11.21	0.97	76326.44
4	2.43	12.69	56.37	2.05	15.82	11.36	0.97	77231.24
5	2.30	12.90	52.65	2.85	14.87	11.47	0.98	76529.09
6	2.59	13.44	53.79	2.81	14.30	11.73	0.98	72709.91
7	2.01	13.08	45.87	3.16	14.58	11.36	0.97	78343.02
8	2.25	12.66	58.90	3.47	14.59	11.35	1.00	80648.41
9	4.33	12.52	55.78	2.54	15.32	11.25	1.02	81436.55
10	2.64	13.01	56.29	2.25	15.41	11.17	1.00	78037.91
11	4.22	14.55	65.61	3.07	13.53	11.44	1.01	81135.92
12	7.92	12.84	64.95	2.86	13.90	11.55	1.01	80083.96
13	4.74	12.64	53.92	2.52	14.68	11.43	0.99	79892.82
14	4.80	12.84	52.67	2.52	14.42	11.50	0.99	79695.87
15	4.34	12.75	59.38	1.94	15.43	11.38	1.00	79368.51
16	3.05	12.38	62.27	1.58	16.63	10.92	0.99	79643.85
17	1.78	12.51	54.42	2.26	15.29	11.03	0.98	75837.17
18	1.90	15.03	59.25	1.86	15.81	11.03	0.99	77486.61
19	1.83	13.11	60.27	2.16	15.37	11.47	0.98	73476.36
20	1.58	15.28	59.41	2.77	14.14	11.41	0.99	77612.58
21	1.51	12.60	61.71	2.62	14.72	11.33	0.99	77934.82
22	1.59	12.67	61.24	2.31	15.25	11.33	0.99	77624.61
23	1.79	12.54	61.12	1.97	16.21	11.11	0.99	79536.25
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.92	13.01	57.81	2.40	15.23	11.23	0.99	78155.55
最 大 值	7.92	15.28	65.61	3.47	17.22	11.73	1.02	81436.55
發生時間	12	20	11	8	1	6		9
最 小 值	1.51	12.06	45.87	1.36	13.53	10.52	0.97	72709.91
發生時間	21	2	7	0	11	1		6
零點偏移(率)	-0.05 %	-0.05 %	-0.03 %	-0.02 %		-0.02		-0.20 %
全幅偏移(率)	0.99 %	0.19 %	2.53 %	-0.14 %		-0.24		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

