

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月15日

報表日期: 114年07月15日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.16	8.75	54.99	2.08	16.94	11.67	1.29	79490.04
1	5.04	12.40	62.80	1.91	18.99	11.60	1.28	78617.63
2	5.19	8.90	53.34	2.14	17.28	11.36	1.27	82676.53
3	4.92	9.93	64.03	1.76	17.97	11.02	1.28	84595.46
4	5.02	8.09	54.38	1.87	17.09	11.63	1.27	80084.19
5	0.04	8.78	50.65	2.14	16.76	11.70	1.26	79485.12
6	0.28	9.37	57.79	1.30	17.55	11.85	1.26	77908.58
7	2.08	9.10	51.36	1.72	17.51	11.30	1.26	82718.53
8	2.37	7.83	52.98	2.33	16.69	11.47	1.26	81908.22
9	2.34	8.02	54.55	2.38	15.67	11.88	1.27	79454.79
10	2.34	7.81	53.59	2.98	15.03	11.93	1.27	79516.96
11	2.11	7.87	61.33	1.39	17.43	11.70	1.25	79557.04
12	1.92	7.76	52.43	2.18	16.08	11.73	1.25	79890.09
13	2.03	8.08	51.74	2.83	14.99	11.92	1.26	79395.21
14	1.95	7.84	61.22	2.02	16.50	11.77	1.25	78905.61
15	2.37	7.90	54.30	2.54	16.17	11.83	1.26	79249.54
16	2.14	7.79	64.12	1.75	17.01	11.71	1.25	79273.29
17	2.52	8.00	49.48	2.70	15.86	11.82	1.25	78896.85
18	4.17	9.23	56.31	2.33	17.02	11.68	1.25	78311.19
19	4.72	9.49	63.00	1.71	17.17	11.50	1.25	79378.28
20	6.50	7.79	60.85	2.24	16.37	11.29	1.25	82418.80
21	5.18	11.42	44.18	2.75	16.62	11.44	1.25	81964.14
22	2.51	7.83	54.35	2.24	16.64	11.61	1.25	80008.69
23	7.12	7.92	51.20	2.83	16.23	11.73	1.24	79676.99
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.33	8.66	55.62	2.17	16.73	11.63	1.26	80140.91
最 大 值	7.12	12.40	64.12	2.98	18.99	11.93	1.29	84595.46
發生時間	23	1	16	10	1	10		3
最 小 值	0.04	7.76	44.18	1.30	14.99	11.02	1.24	77908.58
發生時間	5	12	21	6	13	3		6
零點偏移(率)	-0.08 %	-0.00 %	-0.09 %	-0.02 %		-0.03		0.10 %
全幅偏移(率)	0.00 %	0.16 %	-0.81 %	0.47 %		-0.18		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年07月15日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.83	8.94	53.88	1.75	17.66	10.98	1.02	80825.74
1	8.24	10.43	58.60	2.69	17.07	11.32	1.02	79296.04
2	9.05	9.12	60.03	2.80	18.58	10.88	1.02	82138.61
3	10.39	8.70	60.01	2.03	18.41	10.58	1.01	84811.27
4	7.41	9.19	55.71	2.81	17.07	11.24	1.02	80607.07
5	9.21	9.23	57.54	2.75	17.34	11.23	1.02	80708.41
6	7.04	8.48	51.43	1.87	20.65	9.87	1.04	82918.06
7	8.46	4.43	51.65	1.95	19.42	10.23	1.04	85469.04
8	9.00	7.18	53.04	2.91	17.54	10.86	1.04	82915.92
9	8.00	7.12	63.52	2.51	17.66	11.20	1.05	78841.44
10	8.27	6.83	54.65	2.08	18.52	10.76	1.04	81791.46
11	4.83	7.80	59.97	2.88	17.34	11.44	1.03	76036.27
12	5.95	8.93	54.62	1.77	19.28	10.66	1.02	79821.77
13	6.92	10.98	51.81	3.28	17.01	10.88	1.04	80473.97
14	7.02	8.52	53.66	2.87	17.31	11.06	1.03	77518.69
15	9.81	8.32	62.81	3.01	16.93	11.24	1.02	79093.10
16	9.50	8.16	50.48	2.71	18.12	10.72	1.02	81597.79
17	8.32	8.42	57.22	2.38	18.05	10.92	1.02	80976.56
18	8.91	8.43	54.10	2.37	17.42	11.09	1.02	80692.09
19	8.95	9.29	57.72	2.86	16.47	11.14	1.03	79540.49
20	11.77	8.61	59.21	2.78	17.61	10.13	1.02	83113.61
21	8.26	8.50	51.84	2.69	17.72	10.27	1.02	81696.93
22	8.71	7.98	60.34	2.80	17.15	11.13	1.02	80196.27
23	7.71	8.49	58.43	3.01	16.83	11.10	1.02	81788.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.36	8.42	56.34	2.56	17.80	10.87	1.03	80952.89
最 大 值	11.77	10.98	63.52	3.28	20.65	11.44	1.11	85469.04
發生時間	20	13	9	13	6	11		7
最 小 值	4.83	4.43	50.48	1.75	16.47	9.87	1.00	76036.27
發生時間	11	7	16	0	19	6		11
零點偏移(率)	-0.14 %	-0.00 %	-0.05 %	-0.03 %		-0.07		-0.20 %
全幅偏移(率)	0.13 %	-0.04 %	0.77 %	0.20 %		-0.35		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

