

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.47	12.18	54.03	0.54	19.95	11.01	1.05	75460.80
1	7.34	10.49	62.67	0.44	21.35	10.76	1.05	75852.74
2	7.52	10.75	43.91	1.06	19.69	10.49	1.05	80030.56
3	5.36	11.52	50.41	1.73	16.97	11.17	1.05	76936.09
4	3.38	11.33	68.02	0.78	17.96	11.51	1.05	73540.23
5	9.40	8.76	45.88	2.29	16.29	11.69	1.03	73005.83
6	7.04	6.97	53.76	1.42	17.76	11.24	1.04	75374.29
7	3.81	11.18	53.63	1.37	17.29	11.34	1.05	75503.00
8	2.44	8.15	58.13	0.76	18.41	11.70	1.05	71998.78
9	6.38	7.50	54.44	1.00	17.87	11.28	1.04	75732.03
10	8.77	8.66	43.15	1.67	16.64	11.66	1.04	73538.10
11	7.73	8.33	43.81	2.41	14.77	11.99	1.06	72336.48
12	3.89	10.94	55.00	2.18	15.48	11.99	1.09	72147.12
13	3.67	5.61	54.40	1.83	16.10	11.83	1.07	72683.54
14	5.86	7.12	61.95	1.27	17.13	11.63	1.06	74210.06
15	9.22	7.61	59.12	1.19	17.25	11.53	1.09	74392.43
16	8.53	7.04	56.47	1.59	16.70	11.58	1.09	74580.88
17	6.03	7.22	51.76	1.55	16.06	11.71	1.04	73539.70
18	8.04	6.90	52.19	1.76	15.78	11.67	1.04	74189.43
19	8.37	6.86	54.97	1.91	15.44	11.83	1.07	73159.50
20	9.22	7.12	56.39	1.77	15.57	11.80	1.07	73581.73
21	8.47	6.62	57.68	1.76	16.42	11.56	1.05	76268.81
22	1.52	7.95	57.30	1.77	16.72	11.59	1.05	74698.70
23	9.13	5.48	60.39	0.93	17.32	11.35	1.05	76372.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.57	8.43	54.56	1.46	17.12	11.50	1.06	74547.21
最大值	9.40	12.18	68.02	2.41	21.35	11.99	1.10	80030.56
發生時間	5	0	4	11	1	11		2
最小值	1.52	5.48	43.15	0.44	14.77	10.49	1.02	71998.78
發生時間	22	23	10	1	11	2		8
零點偏移(率)	-0.01 %	0.00 %	-0.04 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	0.01 %	-0.60 %	-0.63 %	0.21 %		0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.13	3.88	56.05	0.95	18.61	10.07	1.06	85146.31
1	0.50	7.34	54.26	1.44	19.65	9.38	1.04	89530.09
2	0.08	7.75	57.07	2.01	16.40	10.31	1.04	86172.44
3	0.09	4.18	50.68	2.21	17.42	9.92	1.05	88174.38
4	0.09	5.29	50.91	2.13	17.58	9.82	1.04	88812.80
5	0.31	7.53	58.77	2.26	16.63	10.19	1.04	87098.02
6	1.97	5.12	48.22	2.83	15.75	10.34	1.03	86182.11
7	4.11	7.83	58.99	2.95	14.84	10.64	1.03	84725.35
8	9.17	2.38	58.34	2.59	16.20	10.29	1.03	86580.79
9	6.88	1.53	61.27	1.55	17.91	10.08	1.05	86331.19
10	5.79	4.08	54.80	2.29	16.54	10.21	1.05	86210.53
11	4.82	3.69	57.57	2.21	16.58	10.14	1.06	87129.03
12	7.56	11.11	59.93	2.91	14.88	10.60	1.06	84805.85
13	8.87	1.81	53.87	1.94	16.76	10.19	1.04	86241.27
14	9.46	2.43	55.70	2.29	16.81	10.29	1.02	85625.32
15	9.34	2.67	55.46	2.12	16.71	10.09	1.03	87086.16
16	8.97	10.14	54.26	2.40	16.05	10.07	1.05	87938.22
17	7.83	1.78	60.08	2.30	16.28	10.13	1.05	87117.15
18	9.86	1.65	53.81	2.32	15.41	10.29	1.02	86876.67
19	9.48	1.59	64.15	2.66	14.75	10.67	1.02	84556.22
20	8.23	1.95	58.22	2.53	14.81	10.56	1.04	85393.94
21	8.81	3.97	59.76	3.61	14.19	10.93	1.07	82997.29
22	4.25	1.93	58.44	2.34	16.25	10.38	1.06	85029.41
23	7.60	4.35	56.13	1.95	16.65	10.28	1.06	86005.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.59	4.42	56.53	2.28	16.40	10.24	1.04	86323.58
最大值	9.86	11.11	64.15	3.61	19.65	10.93	1.07	89530.09
發生時間	18	12	19	21	1	21		1
最小值	0.08	1.53	48.22	0.95	14.19	9.38	1.00	82997.29
發生時間	2	9	6	0	21	1		21
零點偏移(率)	-0.05 %	-0.07 %	-0.07 %	-0.02 %		0.04		-0.20 %
全幅偏移(率)	0.02 %	-0.42 %	0.34 %	0.11 %		0.12		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.89	9.01	47.67	1.09	17.03	10.58	0.99	82748.78
1	2.74	4.29	45.35	1.20	17.73	10.74	1.00	81280.62
2	5.86	6.23	49.09	1.56	16.04	10.78	0.99	82775.55
3	2.80	7.17	55.43	2.13	14.20	11.26	0.99	76793.10
4	5.75	8.47	48.72	1.84	15.28	11.02	1.00	78854.47
5	2.63	7.28	53.53	1.70	15.28	11.03	0.99	79992.91
6	1.74	7.21	46.60	1.30	16.36	10.96	0.99	80603.69
7	1.95	5.13	47.09	1.31	15.98	11.01	0.99	78540.18
8	3.03	3.03	53.98	1.08	17.04	10.85	1.01	81637.01
9	4.32	5.37	58.24	0.96	16.89	11.17	1.02	81334.31
10	3.82	6.60	48.56	1.55	15.14	11.08	1.00	81167.92
11	3.92	6.02	52.84	2.20	13.82	11.41	1.01	77964.70
12	7.45	6.71	49.35	2.13	14.39	11.26	1.00	77493.01
13	5.58	7.13	50.87	2.08	15.73	10.79	1.02	77327.53
14	9.48	6.86	55.26	2.78	15.32	10.90	1.03	82404.71
15	5.56	4.17	52.06	1.71	14.69	11.35	1.02	75140.71
16	5.31	2.95	53.44	1.74	14.68	11.16	1.00	79119.40
17	3.48	3.35	51.54	1.97	13.88	11.09	0.99	76548.86
18	3.33	6.65	47.86	1.93	14.21	10.85	0.98	77349.56
19	5.40	7.01	47.13	2.33	13.64	10.98	0.99	76476.31
20	7.16	4.26	54.39	2.84	12.46	11.40	0.99	74115.12
21	4.05	5.03	47.23	2.85	13.24	11.08	1.00	74342.72
22	5.03	8.86	42.34	3.02	14.11	10.88	1.00	74333.62
23	6.11	4.48	44.60	1.66	14.38	10.85	0.99	75572.38
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.52	5.97	50.13	1.87	15.06	11.02	1.00	78496.55
最大值	9.48	9.01	58.24	3.02	17.73	11.41	1.04	82775.55
發生時間	14	0	9	22	1	11		2
最小值	1.74	2.95	42.34	0.96	12.46	10.58	0.97	74115.12
發生時間	6	16	22	9	20	0		20
零點偏移(率)	0.00 %	-0.02 %	-0.12 %	-0.01 %		0.03		0.00 %
全幅偏移(率)	0.02 %	0.15 %	-0.14 %	0.16 %		0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								