

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月18日

報表日期: 114年03月18日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.85	5.03	52.74	0.52	18.83	11.20	1.34	83002.25
1	4.72	5.32	53.49	0.76	19.25	11.32	1.34	82212.23
2	10.51	4.96	49.68	0.98	17.60	11.28	1.35	83990.60
3	8.55	4.91	53.07	0.87	17.66	11.51	1.35	81438.62
4	11.32	6.11	59.52	0.68	18.62	11.23	1.36	82997.57
5	3.23	3.62	51.98	0.82	17.54	11.28	1.34	83213.76
6	4.53	3.94	59.04	0.81	17.52	11.83	1.34	79174.77
7	8.51	3.71	51.96	0.60	18.35	11.27	1.34	83213.67
8	6.82	3.70	59.48	0.47	18.89	11.28	1.34	80822.55
9	4.59	4.39	46.88	0.60	19.92	9.89	1.34	79442.97
10	6.26	3.65	51.20	0.67	19.14	10.37	1.34	79423.21
11	9.33	3.44	55.13	0.79	18.70	10.41	1.31	82141.40
12	8.91	3.66	50.15	1.31	16.59	10.55	1.29	80307.92
13	7.76	3.58	44.98	1.13	17.64	10.10	1.28	77099.11
14	7.69	2.23	47.04	1.32	17.91	10.22	1.29	76907.36
15	6.44	5.85	47.47	1.21	17.27	10.43	1.29	76313.85
16	8.12	4.33	47.99	1.11	17.44	10.56	1.30	78322.26
17	9.99	11.94	42.77	1.51	16.31	10.81	1.31	75657.66
18	4.17	5.69	46.25	0.96	17.80	10.31	1.34	76934.68
19	10.82	3.39	51.73	0.47	19.94	9.74	1.33	80607.66
20	8.31	4.62	39.73	0.75	18.03	10.01	1.30	79824.39
21	7.31	5.56	42.22	0.77	18.56	10.00	1.29	77738.60
22	12.11	4.51	42.86	0.75	18.70	10.03	1.29	79277.74
23	9.71	5.33	51.69	0.52	18.98	10.21	1.29	79137.77
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.77	4.73	49.96	0.85	18.22	10.66	1.32	79966.78
最 大 值	12.11	11.94	59.52	1.51	19.94	11.83	1.36	83990.60
發生時間	22	17	4	17	19	6		2
最 小 值	3.23	2.23	39.73	0.47	16.31	9.74	1.27	75657.66
發生時間	5	14	20	8	17	19		17
零點偏移(率)	-0.58 %	-0.00 %	-0.03 %	-0.01 %		-0.69		0.30 %
全幅偏移(率)	0.00 %	-0.49 %	-0.06 %	0.61 %		-0.12		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月18日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.66	3.92	55.25	1.51	18.36	10.40	1.16	86586.87
1	8.43	3.17	55.39	1.93	17.77	10.68	1.18	83607.65
2	8.35	4.16	46.93	1.47	17.95	10.52	1.18	82969.88
3	10.31	4.51	52.29	2.11	17.85	10.39	1.17	86319.39
4	9.61	3.20	46.99	2.15	17.50	10.55	1.14	85795.64
5	7.59	3.04	47.96	2.00	16.38	10.93	1.13	80627.69
6	12.72	2.93	49.94	1.78	17.95	10.66	1.14	81002.29
7	7.46	3.01	52.86	1.75	17.69	10.85	1.14	82715.66
8	11.48	2.71	55.37	1.90	17.61	10.61	1.15	85545.56
9	9.54	2.82	49.34	1.90	17.00	10.78	1.14	83491.35
10	9.01	3.27	48.71	2.52	15.69	10.98	1.13	84252.60
11	5.78	2.26	54.50	2.07	15.35	11.16	1.10	81976.04
12	9.96	2.58	55.71	2.85	15.41	10.91	1.10	83176.14
13	9.67	2.75	50.81	3.04	14.93	11.15	1.10	79722.19
14	9.59	2.76	56.36	2.21	15.82	11.07	1.10	81229.91
15	9.54	3.05	57.90	2.33	15.57	11.02	1.10	82942.26
16	8.63	2.57	55.26	2.08	15.90	11.09	1.10	81981.94
17	11.36	2.59	57.58	1.91	16.31	10.64	1.10	81918.05
18	9.16	5.75	56.96	2.39	16.33	9.96	1.10	80639.01
19	7.06	6.05	58.23	1.34	17.43	9.78	1.12	84062.78
20	6.22	1.17	61.21	2.77	14.15	11.47	1.16	82239.81
21	9.91	1.61	59.60	2.56	15.27	11.41	1.13	80275.11
22	9.61	2.36	54.97	2.46	15.78	11.01	1.12	83407.81
23	9.09	4.54	55.21	2.61	15.08	11.15	1.11	83334.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.03	3.20	53.97	2.15	16.46	10.80	1.13	82909.17
最 大 值	12.72	6.05	61.21	3.04	18.36	11.47	1.18	86586.87
發生時間	6	19	20	13	0	20		0
最 小 值	5.78	1.17	46.93	1.34	14.15	9.78	1.09	79722.19
發生時間	11	20	2	19	20	19		13
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	-0.00 %		-0.13		0.20 %
全幅偏移(率)	0.14 %	0.12 %	0.28 %	0.48 %		-0.09		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年03月18日

報表日期: 114年03月18日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.45	6.05	53.22	0.27	18.05	10.14	1.54	84208.50
1	8.92	4.43	59.45	0.71	17.81	10.50	1.53	82136.75
2	7.40	2.49	53.46	0.39	18.13	9.97	1.52	82445.17
3	5.68	2.23	66.29	0.73	16.99	10.89	1.52	80013.43
4	10.36	7.30	60.62	0.89	18.52	9.97	1.52	86302.01
5	6.89	5.82	58.20	0.60	17.37	10.34	1.52	84189.54
6	7.87	7.77	52.86	0.55	17.93	10.24	1.52	83814.16
7	3.87	1.85	59.86	0.46	17.48	10.75	1.52	78619.75
8	3.85	1.56	57.87	0.56	17.26	10.50	1.52	81161.55
9	5.75	5.23	54.39	0.79	16.28	10.51	1.53	81372.13
10	6.53	4.64	49.42	0.62	16.07	10.54	1.53	79409.63
11	3.60	4.67	55.91	1.01	14.66	11.05	1.52	75478.86
12	7.32	5.04	56.11	1.17	14.45	11.05	1.52	76868.80
13	10.03	6.40	60.17	1.35	14.92	11.07	1.52	77290.60
14	6.51	5.61	57.74	0.62	15.86	10.92	1.52	79409.60
15	9.96	9.53	57.27	1.91	14.03	11.12	1.52	76163.63
16	7.57	4.40	56.53	0.95	15.52	10.91	1.52	76865.79
17	5.27	8.49	42.71	0.32	17.73	9.91	1.51	77340.83
18	5.99	8.07	38.47	0.68	16.35	9.79	1.51	76380.86
19	5.68	5.20	44.20	1.05	15.70	10.31	1.52	75727.22
20	1.99	4.72	49.43	0.32	17.54	10.11	1.52	79537.94
21	6.66	3.74	52.41	0.69	16.44	10.46	1.53	82744.94
22	8.79	7.78	51.50	0.64	17.09	10.22	1.56	82214.34
23	6.33	2.59	49.99	0.39	16.71	10.47	1.54	78887.98
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.68	5.23	54.09	0.74	16.62	10.49	1.52	79941.00
最 大 值	10.36	9.53	66.29	1.91	18.52	11.12	1.58	86302.01
發生時間	4	15	3	15	4	15		4
最 小 值	1.99	1.56	38.47	0.27	14.03	9.79	1.49	75478.86
發生時間	20	8	18	0	15	18		11
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	-0.00 %		-0.14		-0.10 %
全幅偏移(率)	0.02 %	-0.31 %	-0.36 %	0.05 %		-0.26		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								