

## P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月04日

| 項目<br>單位<br>小時\限標 | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 7.94     | 13.92    | 57.38    | 2.55     | 14.92    | 12.10    | 1.25     | 68457.56  |
| 1                 | 9.88     | 14.22    | 63.73    | 2.75     | 15.85    | 11.84    | 1.24     | 69690.01  |
| 2                 | 7.27     | 13.89    | 60.60    | 3.24     | 14.26    | 12.12    | 1.25     | 69587.73  |
| 3                 | 4.54     | 13.81    | 58.72    | 2.37     | 14.54    | 12.13    | 1.25     | 69669.24  |
| 4                 | 8.65     | 13.67    | 56.45    | 2.76     | 14.41    | 12.09    | 1.25     | 69838.33  |
| 5                 | 17.37    | 13.58    | 57.16    | 2.35     | 15.16    | 12.05    | 1.27     | 68979.13  |
| 6                 | 11.27    | 13.53    | 55.97    | 2.56     | 14.19    | 11.99    | 1.25     | 70573.37  |
| 7                 | 7.38     | 14.05    | 53.29    | 2.31     | 13.84    | 12.10    | 1.26     | 69917.87  |
| 8                 | 7.01     | 14.59    | 56.02    | 1.92     | 14.43    | 12.14    | 1.25     | 67823.32  |
| 9                 | 11.30    | 13.48    | 47.03    | 2.48     | 14.11    | 11.93    | 1.25     | 68239.25  |
| 10                | 5.88     | 13.54    | 53.75    | 2.49     | 13.71    | 12.06    | 1.25     | 67367.54  |
| 11                | 10.34    | 13.96    | 60.14    | 2.96     | 14.27    | 11.85    | 1.25     | 68770.95  |
| 12                | 9.28     | 13.70    | 58.43    | 3.04     | 13.93    | 12.22    | 1.25     | 66180.90  |
| 13                | 4.09     | 13.80    | 62.10    | 1.88     | 15.23    | 12.17    | 1.25     | 67417.86  |
| 14                | 9.54     | 13.87    | 66.60    | 2.48     | 14.63    | 12.24    | 1.25     | 66826.79  |
| 15                | 12.84    | 14.51    | 56.48    | 3.51     | 13.32    | 12.60    | 1.24     | 65430.84  |
| 16                | 13.63    | 14.12    | 55.64    | 3.06     | 14.03    | 12.03    | 1.24     | 69219.60  |
| 17                | 5.33     | 14.08    | 57.04    | 2.48     | 14.62    | 12.23    | 1.25     | 66540.38  |
| 18                | 8.78     | 13.52    | 60.79    | 2.62     | 14.01    | 12.05    | 1.25     | 69473.65  |
| 19                | 9.06     | 13.81    | 60.39    | 2.42     | 14.71    | 12.48    | 1.25     | 66550.70  |
| 20                | 13.85    | 11.76    | 49.45    | 2.26     | 15.94    | 11.51    | 1.25     | 72651.55  |
| 21                | 4.72     | 12.02    | 57.44    | 1.69     | 15.68    | 11.73    | 1.25     | 70981.17  |
| 22                | 5.49     | 12.80    | 55.48    | 2.44     | 14.08    | 12.09    | 1.25     | 69618.71  |
| 23                | 6.64     | 14.00    | 62.63    | 2.13     | 14.67    | 12.36    | 1.25     | 66733.30  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 8.84     | 13.68    | 57.61    | 2.53     | 14.52    | 12.09    | 1.25     | 68605.82  |
| 最 大 值             | 17.37    | 14.59    | 66.60    | 3.51     | 15.94    | 12.60    | 1.27     | 72651.55  |
| 發生時間              | 5        | 8        | 14       | 15       | 20       | 15       |          | 20        |
| 最 小 值             | 4.09     | 11.76    | 47.03    | 1.69     | 13.32    | 11.51    | 1.20     | 65430.84  |
| 發生時間              | 13       | 20       | 9        | 21       | 15       | 20       |          | 15        |
| 零點偏移(率)           | -0.18 %  | -0.02 %  | -0.08 %  | 0.00 %   |          | -0.04    |          | 0.10 %    |
| 全幅偏移(率)           | 0.00 %   | -0.61 %  | -0.13 %  | 0.73 %   |          | -0.20    |          | 0.10 %    |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月04日

| 項目<br>單位<br>小時\限標 | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|-------------------|----------|----------|----------|----------|----------|----------|----------|-----------|
|                   | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
|                   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0                 | 2.29     | 13.05    | 59.71    | 2.89     | 15.46    | 11.43    | 0.94     | 79222.15  |
| 1                 | 2.96     | 13.54    | 60.30    | 3.38     | 15.70    | 11.51    | 0.94     | 78360.93  |
| 2                 | 3.54     | 15.22    | 59.60    | 2.57     | 15.39    | 11.51    | 0.94     | 78527.67  |
| 3                 | 3.60     | 13.07    | 60.42    | 2.82     | 14.97    | 11.57    | 0.94     | 78353.12  |
| 4                 | 4.23     | 13.00    | 58.38    | 2.02     | 15.72    | 11.50    | 0.94     | 78381.06  |
| 5                 | 3.18     | 12.71    | 56.46    | 2.08     | 15.79    | 11.30    | 0.94     | 77294.74  |
| 6                 | 3.44     | 13.29    | 59.32    | 1.48     | 15.14    | 11.56    | 0.98     | 75588.64  |
| 7                 | 3.04     | 12.90    | 59.08    | 1.97     | 16.19    | 11.39    | 1.01     | 79247.85  |
| 8                 | 2.09     | 13.04    | 54.84    | 2.23     | 15.76    | 11.31    | 1.02     | 77117.61  |
| 9                 | 1.93     | 12.60    | 52.17    | 1.80     | 16.07    | 11.19    | 1.02     | 76960.64  |
| 10                | 1.53     | 12.66    | 53.58    | 2.49     | 14.91    | 11.29    | 1.02     | 76907.09  |
| 11                | 1.95     | 12.98    | 58.84    | 2.28     | 16.08    | 11.43    | 1.02     | 77197.06  |
| 12                | 1.59     | 12.61    | 53.58    | 2.41     | 15.52    | 11.30    | 1.01     | 78682.39  |
| 13                | 1.53     | 12.86    | 58.12    | 2.03     | 15.88    | 11.47    | 1.02     | 77098.62  |
| 14                | 1.54     | 12.89    | 57.69    | 2.10     | 15.69    | 11.52    | 1.02     | 77036.51  |
| 15                | 1.20     | 14.58    | 62.74    | 3.10     | 14.42    | 12.08    | 1.00     | 71519.61  |
| 16                | 2.08     | 12.50    | 56.51    | 1.98     | 16.61    | 11.07    | 0.99     | 79294.27  |
| 17                | 2.45     | 12.56    | 63.18    | 1.55     | 17.22    | 11.06    | 1.02     | 78720.06  |
| 18                | 2.03     | 12.24    | 57.42    | 2.43     | 16.42    | 10.98    | 1.02     | 79826.83  |
| 19                | 2.02     | 12.79    | 64.22    | 1.76     | 17.64    | 11.04    | 1.01     | 77987.92  |
| 20                | 1.90     | 12.56    | 49.52    | 1.73     | 16.90    | 10.84    | 0.99     | 81857.44  |
| 21                | 1.98     | 12.30    | 49.18    | 1.40     | 17.51    | 10.76    | 0.99     | 81053.84  |
| 22                | 2.02     | 12.41    | 48.63    | 1.97     | 16.32    | 11.10    | 1.00     | 80212.54  |
| 23                | 2.22     | 13.66    | 55.44    | 1.14     | 17.29    | 11.16    | 1.01     | 77749.58  |
| 監測時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數              | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數              | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平 均 值             | 2.35     | 13.00    | 57.04    | 2.15     | 16.02    | 11.31    | 0.99     | 78091.59  |
| 最 大 值             | 4.23     | 15.22    | 64.22    | 3.38     | 17.64    | 12.08    | 1.03     | 81857.44  |
| 發生時間              | 4        | 2        | 19       | 1        | 19       | 15       |          | 20        |
| 最 小 值             | 1.20     | 12.24    | 48.63    | 1.14     | 14.42    | 10.76    | 0.94     | 71519.61  |
| 發生時間              | 15       | 18       | 22       | 23       | 15       | 21       |          | 15        |
| 零點偏移(率)           | -0.02 %  | -0.00 %  | -0.04 %  | -0.00 %  |          | -0.07    |          | -0.20 %   |
| 全幅偏移(率)           | 0.71 %   | -0.01 %  | -0.01 %  | 0.13 %   |          | -0.11    |          | -0.20 %   |
| 有效比率              | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註                |          |          |          |          |          |          |          |           |

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月04日

報表日期: 114年09月04日

[illegible]