

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.12	7.82	50.75	1.23	16.30	11.97	1.04	79467.83
1	8.86	7.90	52.48	1.22	16.11	12.18	1.03	77100.13
2	10.02	7.82	53.79	1.12	16.09	11.65	1.02	82507.31
3	9.45	7.48	48.81	2.05	14.45	11.85	1.00	81928.92
4	9.83	7.77	43.94	1.81	15.18	11.75	1.00	82207.15
5	7.20	7.15	56.66	0.92	15.87	12.38	1.03	71551.73
6	10.95	5.18	39.07	1.37	15.54	11.65	1.03	83097.20
7	6.18	5.56	57.50	1.24	16.10	11.96	1.06	79519.71
8	9.53	5.00	42.25	1.54	15.77	11.34	1.06	86036.69
9	8.55	5.60	52.51	1.93	14.32	12.25	1.06	78961.89
10	8.57	5.72	50.90	1.51	15.06	11.69	1.06	83387.34
11	10.97	7.45	44.08	2.50	14.29	12.08	1.06	80610.55
12	8.65	6.99	59.46	2.22	13.55	12.37	1.06	78979.65
13	8.35	8.42	47.07	3.11	12.39	12.37	1.05	79681.38
14	10.44	6.26	46.60	2.75	13.77	11.97	1.04	82071.02
15	11.11	11.28	44.46	3.69	12.16	12.43	1.04	79129.89
16	9.31	6.70	50.13	2.48	12.51	12.59	1.03	78169.60
17	11.51	5.61	52.78	2.00	14.42	11.97	1.02	82109.86
18	9.69	6.13	50.03	2.06	14.11	12.15	1.05	80915.84
19	10.84	5.40	49.66	1.64	14.63	11.87	1.06	82800.30
20	9.17	6.79	50.24	2.57	14.01	12.31	1.06	79303.83
21	6.43	6.75	56.66	1.55	14.72	12.36	1.06	78267.37
22	10.83	5.50	54.71	1.02	16.29	11.46	1.04	84602.26
23	11.78	5.98	50.51	1.47	15.44	11.78	1.02	82672.20
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.43	6.76	50.21	1.88	14.71	12.02	1.04	80628.32
最 大 值	11.78	11.28	59.46	3.69	16.30	12.59	1.10	86036.69
發生時間	23	15	12	15	0	16		8
最 小 值	6.18	5.00	39.07	0.92	12.16	11.34	0.99	71551.73
發生時間	7	8	6	5	15	8		5
零點偏移(率)	-0.69 %	-0.00 %	-0.03 %	-0.00 %		-0.03		0.10 %
全幅偏移(率)	-0.97 %	0.13 %	-0.34 %	-0.25 %		-0.23		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月05日

[illegible]

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 113年02月05日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.39	6.46	60.73	1.47	15.99	10.92	1.04	79283.32
1	3.82	7.41	53.03	1.60	15.04	11.34	1.04	75869.25
2	8.86	5.51	59.64	1.99	14.94	10.93	1.04	77793.95
3	10.03	5.01	60.30	1.81	15.68	10.72	1.04	79787.12
4	12.97	6.27	52.32	2.42	14.24	11.03	1.04	77785.32
5	7.25	6.26	68.32	1.49	15.68	11.03	1.04	76621.28
6	8.53	7.51	59.13	2.19	13.84	11.46	1.04	76446.33
7	10.41	3.32	60.71	2.04	14.47	10.90	1.04	76705.48
8	10.49	2.65	66.57	1.69	15.07	10.76	1.04	79182.09
9	7.92	2.73	63.25	1.61	14.53	10.90	1.04	76796.83
10	6.03	3.10	61.01	2.01	13.46	11.31	1.04	77945.97
11	6.97	4.41	57.16	3.40	12.11	11.72	1.04	74231.52
12	9.59	4.67	62.89	4.15	11.55	11.89	1.03	75349.46
13	11.77	6.53	61.37	3.16	11.05	11.98	1.02	75949.80
14	9.82	5.15	59.70	3.16	10.36	12.09	1.02	73653.84
15	8.27	4.95	62.08	3.35	10.90	11.97	1.02	72896.12
16	8.57	6.60	60.57	2.73	12.79	11.37	1.02	75884.23
17	6.91	4.06	68.55	2.24	13.23	11.67	1.04	74793.94
18	9.45	5.43	57.40	2.27	13.49	11.22	1.02	79290.25
19	8.43	6.85	62.87	2.37	12.82	11.50	1.03	75682.23
20	8.79	6.30	61.10	2.24	13.59	11.01	1.04	79989.77
21	9.18	4.71	64.81	1.64	14.25	11.27	1.04	75935.94
22	8.31	3.99	61.20	1.93	14.22	10.98	1.04	77947.89
23	8.47	4.77	58.29	1.60	15.37	10.69	1.04	81646.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.59	5.19	60.96	2.27	13.69	11.28	1.03	76977.83
最 大 值	12.97	7.51	68.55	4.15	15.99	12.09	1.06	81646.10
發生時間	4	6	17	12	0	14		23
最 小 值	3.82	2.65	52.32	1.47	10.36	10.69	1.01	72896.12
發生時間	1	8	4	0	14	23		15
零點偏移(率)	0.00 %	-0.04 %	-0.01 %	0.00 %		0.02		0.30 %
全幅偏移(率)	0.08 %	-0.48 %	-0.47 %	0.08 %		-0.22		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								