

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.90	13.24	51.53	2.21	17.48	11.50	1.28	79219.64
1	7.71	12.94	54.24	2.40	19.94	10.93	1.27	81775.28
2	11.59	12.66	45.44	2.90	16.74	11.11	1.25	83059.78
3	9.60	13.29	49.74	2.46	15.16	11.82	1.25	77581.71
4	10.45	13.28	53.58	2.22	15.65	11.73	1.25	78153.25
5	7.48	13.64	48.34	2.33	14.82	11.90	1.25	78743.76
6	8.46	13.35	53.86	2.10	16.31	11.72	1.27	78789.48
7	11.56	13.25	52.63	2.34	16.33	11.71	1.28	78213.28
8	11.89	13.03	45.44	3.89	16.57	11.45	1.26	79712.80
9	7.77	13.04	46.87	3.61	15.76	11.55	1.25	79243.20
10	5.80	13.25	45.18	3.01	15.66	11.56	1.25	79610.75
11	7.90	13.23	49.21	3.62	15.27	11.70	1.27	77324.03
12	9.37	13.50	53.21	3.59	15.07	11.89	1.29	76973.97
13	11.60	12.76	54.37	2.32	17.94	11.04	1.29	82738.90
14	13.68	13.30	53.89	3.02	17.43	11.42	1.29	80062.28
15	7.66	14.70	63.18	4.16	16.76	11.96	1.29	75811.68
16	9.64	13.13	41.09	2.09	16.73	11.20	1.28	80656.13
17	9.45	13.33	44.03	1.83	15.99	11.45	1.27	79156.27
18	8.56	12.93	45.34	3.10	15.80	11.40	1.27	79177.71
19	10.44	12.77	47.74	2.46	17.57	11.13	1.27	80554.64
20	8.93	13.06	53.47	2.68	16.33	11.43	1.27	80447.25
21	8.76	13.03	54.19	2.19	17.34	11.29	1.26	81039.92
22	8.98	13.02	44.94	2.90	16.27	11.37	1.25	78631.91
23	8.96	12.80	47.22	1.99	17.73	10.92	1.25	81730.91
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.46	13.19	49.95	2.73	16.53	11.47	1.27	79517.02
最大值	13.68	14.70	63.18	4.16	19.94	11.96	1.29	83059.78
發生時間	14	15	15	15	1	15		2
最小值	5.80	12.66	41.09	1.83	14.82	10.92	1.24	75811.68
發生時間	10	2	16	17	5	23		15
零點偏移(率)	-0.04 %	0.01 %	-0.02 %	-0.00 %		-0.18	-0.01	0.30 %
全幅偏移(率)	-0.09 %	0.79 %	0.58 %	0.79 %		-0.07	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.97	11.28	48.20	0.80	18.16	11.12	0.81	80803.93
1	8.30	11.91	60.56	1.40	19.14	11.32	0.83	78124.78
2	11.54	11.52	47.34	1.43	17.64	11.35	0.82	79824.47
3	7.86	10.07	52.29	1.08	18.22	11.21	0.80	80784.46
4	10.48	9.20	43.91	1.38	17.83	11.01	0.79	82757.03
5	10.94	9.80	44.21	1.25	17.35	11.20	0.79	81673.87
6	3.70	12.49	41.75	1.71	16.35	11.84	0.79	76304.13
7	8.45	14.37	38.04	1.64	16.49	11.87	0.80	71162.20
8	13.14	10.66	66.45	1.48	17.35	11.19	0.80	81931.75
9	9.19	8.22	62.37	1.37	16.69	11.49	0.79	79179.81
10	9.56	8.37	65.97	1.79	15.69	11.55	0.80	80119.48
11	13.43	9.56	57.89	2.25	15.76	11.47	0.82	79728.35
12	10.13	8.93	71.93	1.93	16.48	11.49	0.82	79456.42
13	10.07	7.91	57.56	1.30	16.17	11.53	0.79	78948.63
14	9.66	8.48	63.98	1.85	16.02	11.53	0.79	78704.92
15	8.35	9.64	63.13	1.17	16.62	11.40	0.81	79188.74
16	6.81	9.85	53.14	1.23	16.53	11.39	0.81	76564.88
17	11.17	8.09	56.74	1.44	16.37	11.32	0.82	77613.73
18	8.58	8.67	50.78	0.86	17.42	10.75	0.83	77029.46
19	11.29	8.40	51.86	1.01	17.47	10.45	0.81	76895.09
20	10.80	10.07	50.86	1.33	16.32	11.39	0.82	77952.11
21	8.27	9.36	52.27	0.96	16.66	11.37	0.82	76275.41
22	9.58	10.11	60.62	0.59	18.10	11.26	0.81	77856.16
23	8.91	8.77	58.50	0.69	18.48	10.62	0.81	83139.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.51	9.82	55.01	1.33	17.05	11.30	0.81	78834.14
最大值	13.43	14.37	71.93	2.25	19.14	11.87	0.83	83139.66
發生時間	11	7	12	11	1	7		23
最小值	3.70	7.91	38.04	0.59	15.69	10.45	0.79	71162.20
發生時間	6	13	7	22	10	19		7
零點偏移(率)	-0.04 %	-0.00 %	-0.06 %	-0.01 %		-0.07	-0.06	0.00 %
全幅偏移(率)	-0.36 %	-1.49 %	-0.35 %	-0.02 %		-0.04	0.31	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.67	11.22	51.51	2.27	17.43	9.92	1.37	73530.45
1	7.93	11.48	51.28	2.48	20.31	9.77	1.36	76403.90
2	10.80	12.04	46.76	2.72	18.64	9.76	1.36	77287.64
3	8.15	12.40	50.28	2.45	17.03	10.18	1.36	75025.49
4	10.19	12.72	48.51	2.77	16.66	10.19	1.36	75173.46
5	10.06	12.84	51.03	3.05	15.50	10.31	1.36	73354.65
6	8.39	12.05	50.63	2.57	16.06	10.21	1.36	73806.42
7	10.68	11.36	47.19	2.98	17.78	9.81	1.36	76166.04
8	12.47	11.44	57.58	3.02	16.42	10.62	1.36	77044.69
9	8.51	12.14	59.28	2.88	16.16	10.81	1.36	77330.31
10	7.80	14.02	57.38	2.90	15.96	10.77	1.36	77353.99
11	8.90	16.36	55.98	3.11	15.48	10.74	1.36	76275.78
12	9.89	12.25	58.96	3.08	15.66	11.03	1.36	75689.86
13	6.24	12.75	61.13	3.01	15.26	11.00	1.35	75565.53
14	9.62	11.90	64.12	2.82	16.77	10.74	1.35	76247.64
15	9.19	11.60	56.51	2.76	16.51	10.50	1.35	76762.70
16	8.77	11.71	60.60	2.54	17.83	10.48	1.36	78371.34
17	12.32	11.55	59.76	3.01	17.44	10.38	1.36	78602.52
18	6.95	12.30	53.39	2.46	17.33	10.38	1.36	76971.26
19	9.11	12.60	55.80	2.56	17.62	10.37	1.36	77334.91
20	9.42	12.55	51.24	2.44	16.60	10.27	1.36	73638.21
21	9.29	12.36	53.27	2.44	17.09	10.15	1.36	75797.14
22	9.37	12.30	56.80	2.65	17.76	10.04	1.36	77177.99
23	9.65	12.19	57.47	2.80	18.66	10.05	1.36	77435.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.22	12.34	54.85	2.74	17.00	10.35	1.36	76181.13
最大值	12.47	16.36	64.12	3.11	20.31	11.03	1.39	78602.52
發生時間	8	11	14	11	1	12		17
最小值	6.24	11.22	46.76	2.27	15.26	9.76	1.34	73354.65
發生時間	13	0	2	0	13	2		5
零點偏移(率)	-0.01 %	-0.02 %	-0.03 %	-0.00 %		-0.10	-0.01	0.20 %
全幅偏移(率)	-0.60 %	1.32 %	1.40 %	1.07 %		-0.10	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								