

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月16日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.08	12.55	47.59	2.08	17.99	10.94	1.33	81670.47
1	12.10	12.89	59.22	1.90	19.67	10.29	1.32	86784.42
2	7.32	11.85	47.79	1.82	17.12	11.37	1.31	80142.46
3	12.40	12.52	45.70	3.72	15.98	11.48	1.29	79910.30
4	8.86	11.85	44.70	2.10	16.15	11.53	1.29	79129.55
5	9.84	11.97	45.46	1.84	17.20	11.43	1.31	82244.59
6	10.86	11.91	43.93	2.38	14.76	11.76	1.34	79131.33
7	8.54	12.42	51.10	1.31	16.90	11.90	1.35	74976.63
8	10.72	11.74	43.06	2.14	15.53	11.51	1.33	80773.65
9	8.05	12.02	46.83	1.61	17.15	11.30	1.35	80915.04
10	9.36	11.95	45.30	2.19	16.25	11.43	1.34	81084.38
11	7.79	11.90	54.88	1.69	16.25	11.65	1.33	77840.62
12	8.36	12.25	48.93	2.38	15.44	11.95	1.30	72117.76
13	11.76	11.62	53.43	1.87	16.63	11.34	1.30	78676.57
14	8.19	12.14	57.31	1.91	15.94	11.86	1.30	76303.89
15	8.94	12.04	54.94	1.94	16.24	11.72	1.30	76432.63
16	9.37	11.56	51.32	2.34	15.89	11.40	1.31	80855.13
17	9.02	11.61	54.60	2.33	15.60	11.47	1.34	80783.94
18	11.37	12.18	50.52	2.18	15.97	11.36	1.34	80992.28
19	9.52	11.43	41.80	2.29	16.30	11.11	1.32	80764.11
20	13.46	11.34	50.47	2.16	17.11	10.93	1.34	82645.09
21	7.07	11.62	39.95	2.54	17.36	10.82	1.34	84115.58
22	7.85	13.62	38.52	3.33	16.14	11.25	1.34	80285.24
23	12.41	11.83	47.47	2.89	15.94	11.44	1.34	78469.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.68	12.03	48.53	2.21	16.48	11.39	1.32	79876.88
最大值	13.46	13.62	59.22	3.72	19.67	11.95	1.36	86784.42
發生時間	20	22	1	3	1	12		1
最小值	7.07	11.34	38.52	1.31	14.76	10.29	1.29	72117.76
發生時間	21	20	22	7	6	1		12
零點偏移(率)	-0.04 %	-0.00 %	-0.01 %	-0.00 %		-0.07	-0.01	0.30 %
全幅偏移(率)	-0.64 %	-1.08 %	0.66 %	-0.18 %		0.13	-0.06	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月16日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.37	11.34	52.24	1.07	18.21	9.86	1.06	82256.57
1	9.78	11.43	58.89	1.33	18.55	10.06	1.06	81055.52
2	7.53	12.02	57.88	1.65	17.16	10.23	1.06	78482.31
3	10.73	11.55	56.18	1.96	16.96	9.93	1.03	79301.79
4	7.88	11.85	51.57	1.30	18.01	9.79	1.03	74861.80
5	8.33	13.07	50.44	1.59	17.96	9.71	1.04	77057.87
6	12.86	11.45	49.10	1.81	18.31	10.00	1.04	82342.63
7	8.33	11.75	47.18	1.64	17.39	10.35	1.04	80922.79
8	8.60	11.73	54.19	1.29	17.39	10.45	1.04	80579.34
9	11.23	11.71	51.40	1.76	17.17	10.42	1.04	80744.04
10	7.15	12.15	55.89	1.24	18.36	10.06	1.05	83191.76
11	8.01	11.92	57.91	0.95	18.13	10.46	1.06	79876.54
12	9.71	11.79	51.59	1.22	18.62	10.28	1.06	81500.80
13	10.06	11.98	53.55	1.53	17.15	10.63	1.05	80011.51
14	10.80	11.88	53.91	2.12	16.20	10.70	1.04	78941.41
15	9.45	11.88	52.12	1.93	16.28	10.64	1.04	79113.14
16	14.20	11.66	46.44	2.70	16.79	9.98	1.06	79163.98
17	6.04	12.93	42.48	2.21	17.19	9.90	1.06	78421.53
18	10.58	10.86	32.49	1.42	18.76	9.23	1.05	79436.79
19	10.13	11.09	39.60	1.61	18.34	9.32	1.17	79093.94
20	8.21	10.97	48.88	1.91	18.36	9.38	1.02	78620.68
21	10.34	12.02	57.10	2.90	17.03	9.83	1.02	79162.15
22	10.17	11.54	58.46	2.01	17.76	9.93	1.02	79247.16
23	8.64	11.22	50.21	1.73	18.55	9.45	1.02	80242.87
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.59	11.74	51.24	1.70	17.69	10.02	1.05	79734.54
最大值	14.20	13.07	58.89	2.90	18.76	10.70	2.15	83191.76
發生時間	16	5	1	21	18	14		10
最小值	6.04	10.86	32.49	0.95	16.20	9.23	1.02	74861.80
發生時間	17	18	18	11	14	18		4
零點偏移(率)	-0.06 %	-0.02 %	-0.05 %	-0.01 %		-0.05	-0.01	0.10 %
全幅偏移(率)	0.34 %	-0.61 %	0.05 %	-0.17 %		0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月16日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.49	13.59	51.14	2.82	15.69	9.83	1.38	71473.83
1	8.30	11.15	46.92	1.42	17.30	9.75	1.38	72528.97
2	9.55	11.56	49.55	1.69	17.30	9.81	1.40	72695.09
3	9.21	11.23	55.68	1.63	16.29	10.17	1.39	71319.72
4	9.85	11.24	53.85	1.65	16.94	9.95	1.38	74156.69
5	7.51	11.33	48.41	1.63	15.83	10.02	1.38	74122.86
6	9.74	11.48	50.29	1.85	15.99	9.98	1.40	74247.49
7	7.87	11.13	45.66	2.19	16.49	9.64	1.41	72820.02
8	9.43	11.63	45.62	2.08	16.87	9.64	1.40	73785.45
9	9.85	11.26	55.73	2.09	18.16	9.69	1.40	75246.99
10	8.04	11.32	53.86	2.67	16.52	10.13	1.39	76172.26
11	8.31	12.20	56.73	3.22	15.56	10.64	1.40	72380.91
12	3.41	12.77	66.44	3.00	16.89	11.30	1.38	67308.18
13	6.70	13.94	53.64	2.63	15.98	10.09	1.40	73739.86
14	9.38	11.11	46.85	2.03	18.28	9.17	1.40	73975.96
15	8.10	12.44	44.05	1.91	18.23	8.58	1.37	75186.85
16	9.12	12.20	43.10	3.05	17.58	9.02	1.36	72624.61
17	8.25	10.92	41.69	2.62	17.50	9.37	1.36	73874.51
18	9.75	11.35	41.01	2.68	17.27	9.49	1.38	73893.33
19	9.49	11.30	43.84	2.79	16.92	9.52	1.37	73718.21
20	8.04	13.23	48.29	3.95	16.95	9.35	1.36	77234.02
21	9.24	10.88	40.57	0.62	17.31	9.03	1.36	74844.52
22	10.02	11.71	36.17	0.96	17.67	9.04	1.37	74588.36
23	10.61	11.42	39.42	1.45	18.17	9.02	1.39	75339.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.76	11.77	48.27	2.19	16.99	9.68	1.38	73636.58
最大值	10.61	13.94	66.44	3.95	18.28	11.30	1.42	77234.02
發生時間	23	13	12	20	14	12		20
最小值	3.41	10.88	36.17	0.62	15.56	8.58	1.35	67308.18
發生時間	12	21	22	21	11	15		12
零點偏移(率)	0.00 %	-0.01 %	-0.26 %	-0.04 %		-0.07	-0.01	0.00 %
全幅偏移(率)	-1.96 %	0.39 %	1.67 %	0.65 %		0.10	0.00	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								