

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.21	12.01	50.92	1.54	18.93	11.20	1.31	80377.61
1	8.75	11.93	44.37	1.87	19.64	10.86	1.30	82620.92
2	9.42	11.52	52.88	2.43	20.44	10.58	1.32	84008.64
3	7.93	12.48	43.49	3.30	18.07	10.94	1.31	83328.82
4	10.05	11.97	50.56	2.55	17.74	11.36	1.33	78745.63
5	11.39	16.86	38.06	2.82	16.94	11.17	1.32	82740.27
6	9.62	13.45	51.77	1.81	16.98	11.26	1.30	81188.89
7	10.00	13.14	58.05	2.83	15.51	11.57	1.31	79673.54
8	10.69	13.30	58.76	2.67	15.81	11.64	1.31	79507.12
9	10.61	13.25	54.29	2.14	16.29	11.60	1.31	79772.34
10	7.14	13.13	49.51	2.13	15.97	11.50	1.32	80308.26
11	9.09	14.71	38.32	3.34	14.64	12.47	1.29	68371.75
12	9.09	13.79	38.76	2.18	16.69	11.82	1.29	72592.19
13	12.14	13.06	44.87	1.84	16.87	11.34	1.29	81145.52
14	9.62	13.19	51.69	1.67	17.44	11.23	1.28	81595.27
15	15.25	13.29	47.10	2.84	15.22	11.63	1.29	78738.94
16	4.45	13.39	35.56	1.97	18.19	10.92	1.30	83010.51
17	11.18	12.75	47.43	3.00	16.26	11.22	1.32	81913.92
18	11.98	12.77	46.80	2.86	16.34	11.21	1.29	81084.36
19	7.18	12.61	48.88	2.39	16.66	11.06	1.30	82767.16
20	13.89	12.56	58.14	4.00	15.62	11.29	1.31	81629.79
21	7.51	13.11	55.57	3.01	16.17	11.25	1.30	82456.36
22	8.54	13.00	57.50	2.96	15.46	11.63	1.29	79455.37
23	10.34	12.32	50.09	2.49	15.28	11.62	1.29	79145.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.84	13.07	48.89	2.53	16.80	11.35	1.30	80257.45
最大值	15.25	16.86	58.76	4.00	20.44	12.47	1.34	84008.64
發生時間	15	5	8	20	2	11		2
最小值	4.45	11.52	35.56	1.54	14.64	10.58	1.27	68371.75
發生時間	16	2	16	0	11	2		11
零點偏移(率)	-0.09 %	0.00 %	-0.03 %	0.00 %		-0.17	-0.01	0.30 %
全幅偏移(率)	0.17 %	1.65 %	0.33 %	1.71 %		-0.01	0.04	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.24	8.96	57.21	1.05	17.77	11.19	0.83	79907.41
1	9.71	9.18	59.56	1.09	19.17	11.08	0.83	79454.06
2	10.03	8.75	61.19	0.79	18.84	10.80	0.83	82260.69
3	8.72	7.50	58.51	0.73	18.02	11.13	0.82	80862.24
4	14.72	7.59	54.46	1.61	16.59	11.40	0.81	79519.42
5	12.62	8.01	57.35	1.98	16.45	11.49	0.81	78891.90
6	11.68	7.97	50.88	2.31	16.00	11.46	0.83	82641.43
7	14.44	7.73	50.18	1.34	17.04	11.31	0.83	79165.68
8	11.17	7.76	51.51	1.88	16.34	11.23	0.83	81194.91
9	8.99	8.16	49.61	1.51	16.23	11.61	0.82	76906.56
10	8.81	8.49	53.44	1.41	15.94	12.02	0.83	75563.70
11	8.32	8.12	51.88	1.15	16.98	11.56	0.83	77525.25
12	10.01	7.53	59.38	1.07	17.22	11.54	0.83	77544.91
13	8.26	7.44	51.52	1.39	16.88	11.35	0.83	78830.52
14	10.72	7.05	53.52	1.23	16.54	11.47	0.83	76992.43
15	7.83	7.62	50.47	2.23	14.72	12.50	0.83	73080.03
16	9.97	8.12	47.78	1.00	17.26	11.46	0.82	74086.81
17	9.63	8.72	46.13	1.39	17.08	11.30	0.81	75250.49
18	8.27	8.12	48.23	0.87	17.57	11.25	0.79	73788.04
19	11.37	7.34	46.75	1.22	17.31	11.26	0.81	75112.42
20	7.15	7.32	40.29	1.11	17.01	11.22	0.81	76304.33
21	10.14	7.70	39.90	1.24	16.85	11.31	0.80	75488.94
22	9.30	7.82	40.86	1.39	16.34	11.28	0.79	75283.18
23	10.69	27.19	49.01	1.80	15.29	11.44	0.79	75258.39
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.07	8.76	51.23	1.37	16.89	11.40	0.82	77538.07
最大值	14.72	27.19	61.19	2.31	19.17	12.50	0.83	82641.43
發生時間	4	23	2	6	1	15		6
最小值	7.15	7.05	39.90	0.73	14.72	10.80	0.79	73080.03
發生時間	20	14	21	3	15	2		15
零點偏移(率)	-0.14 %	-0.05 %	-0.05 %	-0.00 %		-0.09	-0.06	-0.10 %
全幅偏移(率)	-0.37 %	0.98 %	0.04 %	1.02 %		-0.15	0.31	-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年03月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.09	11.84	43.37	2.92	17.57	10.03	1.34	78355.61
1	8.90	11.80	50.27	2.93	19.42	10.14	1.34	78435.58
2	9.23	11.78	59.87	3.17	18.43	10.32	1.33	78701.54
3	10.02	11.83	54.18	3.38	17.78	10.26	1.32	76466.41
4	7.94	12.28	51.13	3.01	16.98	10.44	1.31	74469.22
5	9.97	12.84	58.40	3.63	15.71	11.10	1.32	71721.00
6	8.17	12.58	57.62	3.38	15.26	11.25	1.34	74294.86
7	13.05	11.77	57.06	3.69	16.19	11.20	1.36	72116.13
8	8.84	12.27	50.64	3.43	15.71	11.12	1.36	75270.13
9	10.73	13.37	47.32	3.90	15.79	10.52	1.36	71931.08
10	8.68	10.99	45.61	2.90	17.95	9.67	1.33	73320.59
11	8.91	11.79	45.72	3.19	16.59	9.72	1.31	71491.78
12	9.76	11.15	40.04	2.73	18.77	9.28	1.31	73576.05
13	10.76	10.90	43.67	2.98	17.31	9.45	1.34	73111.64
14	7.07	10.93	44.12	2.50	16.53	9.66	1.30	72293.02
15	9.24	10.99	45.77	2.61	17.10	9.65	1.31	72694.69
16	9.12	11.21	38.78	1.89	16.82	9.49	1.34	72123.47
17	10.25	11.06	41.21	1.84	19.15	9.12	1.32	76522.83
18	10.16	10.93	42.47	1.92	18.69	9.38	1.32	76317.36
19	9.48	11.57	43.24	2.29	15.84	9.79	1.31	78262.58
20	10.39	11.47	47.14	2.19	16.21	10.10	1.32	77572.54
21	9.19	12.29	48.17	2.25	15.97	9.99	1.32	77065.60
22	6.68	12.58	47.27	2.46	15.31	9.96	1.32	75002.35
23	8.99	11.78	45.20	2.01	16.63	10.11	1.32	72496.10
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.40	11.75	47.84	2.80	16.99	10.07	1.33	74733.84
最大值	13.05	13.37	59.87	3.90	19.42	11.25	1.36	78701.54
發生時間	7	9	2	9	1	6		2
最小值	6.68	10.90	38.78	1.84	15.26	9.12	1.29	71491.78
發生時間	22	13	16	17	6	17		11
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	0.00 %		-0.07	-0.01	0.00 %
全幅偏移(率)	0.74 %	0.24 %	0.25 %	0.09 %		0.03	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								