

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月27日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.66	7.29	54.13	2.45	16.53	11.77	1.05	78977.59
1	18.09	13.70	58.57	5.49	16.27	11.85	1.05	78890.22
2	10.77	12.06	49.82	7.27	15.18	12.19	1.05	75706.22
3	8.49	6.89	55.29	1.33	18.62	11.42	1.06	82312.97
4	9.23	9.94	43.55	2.37	16.30	11.48	1.07	79517.06
5	4.72	11.58	45.42	2.18	16.23	11.81	1.05	76091.67
6	8.21	9.09	52.55	1.56	17.07	11.86	1.05	78196.93
7	8.50	8.53	54.72	1.35	17.55	11.80	1.05	78636.79
8	9.20	8.58	45.25	1.86	16.76	11.67	1.05	78084.43
9	5.01	10.02	58.47	0.97	18.35	12.02	1.05	75147.59
10	7.06	10.17	53.19	1.19	18.39	11.36	1.05	81126.50
11	9.72	13.42	52.24	2.27	16.34	11.85	1.06	77703.65
12	14.37	11.69	50.00	4.98	14.55	12.04	1.07	76872.77
13	8.36	9.58	63.46	1.86	16.64	12.12	1.07	75653.09
14	9.83	10.63	47.52	1.87	15.90	11.89	1.05	75987.66
15	9.41	12.01	56.28	1.69	16.99	11.75	1.06	77795.97
16	9.11	11.01	53.23	1.63	17.17	11.67	1.07	79458.46
17	9.12	12.00	55.00	2.24	16.58	11.65	1.07	80354.18
18	6.92	11.32	66.09	1.06	17.74	11.62	1.08	80335.12
19	3.50	12.70	63.67	0.58	18.94	11.35	1.07	81672.05
20	6.11	12.32	47.42	1.60	17.43	11.31	1.07	82447.87
21	4.50	7.78	48.10	1.12	17.99	11.21	1.07	82440.91
22	10.71	13.55	54.28	1.68	17.55	11.50	1.08	81344.79
23	6.90	10.37	52.38	1.60	16.90	11.65	1.07	80642.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.73	10.68	53.36	2.17	17.00	11.70	1.06	78974.88
最大值	18.09	13.70	66.09	7.27	18.94	12.19	1.10	82447.87
發生時間	1	1	18	2	19	2		20
最小值	3.50	6.89	43.55	0.58	14.55	11.21	1.03	75147.59
發生時間	19	3	4	19	12	21		9
零點偏移(率)	-0.11 %	0.00 %	-0.03 %	-0.00 %		-0.01		0.00 %
全幅偏移(率)	0.04 %	0.81 %	0.46 %	-0.05 %		-0.10		0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月27日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.83	12.44	54.01	2.82	16.34	10.38	1.19	79113.68
1	9.39	6.49	62.22	2.13	18.55	10.09	1.20	84456.02
2	7.96	6.03	70.35	1.15	19.48	9.62	1.20	86786.95
3	9.71	9.14	54.54	1.74	18.01	10.00	1.20	84880.70
4	9.44	10.75	51.46	1.72	19.21	9.76	1.20	86888.81
5	8.96	14.23	50.51	1.89	19.18	9.96	1.20	85140.22
6	7.53	6.59	49.25	1.75	18.53	9.76	1.23	86560.30
7	10.37	6.57	58.03	2.08	18.14	10.01	1.23	84788.60
8	7.92	5.65	47.84	1.57	19.19	9.70	1.23	84905.00
9	9.58	9.33	47.37	1.50	19.45	9.36	1.23	85244.15
10	9.40	9.08	46.69	2.06	17.80	9.79	1.23	81700.24
11	6.22	6.21	50.59	1.41	18.41	10.04	1.23	80926.27
12	6.81	9.17	52.24	1.06	19.03	10.05	1.24	81542.67
13	9.42	7.89	44.47	1.79	17.96	9.78	1.23	83740.57
14	7.33	4.27	54.38	1.46	17.80	10.18	1.23	79167.05
15	8.80	10.57	52.56	1.69	17.65	10.10	1.23	80356.66
16	8.26	11.78	48.94	1.88	16.95	10.21	1.23	81144.10
17	5.91	4.46	55.01	1.69	17.38	10.04	1.25	83127.67
18	5.63	5.40	49.26	1.53	17.75	10.02	1.25	82788.85
19	7.83	6.87	50.68	1.99	17.52	9.88	1.25	84731.44
20	7.40	5.56	59.92	1.40	18.44	9.64	1.27	86689.83
21	8.92	6.70	55.04	1.68	18.14	9.83	1.26	83044.98
22	8.94	14.07	56.07	2.06	18.49	9.75	1.25	85670.41
23	7.31	8.57	46.57	1.91	18.04	9.76	1.24	84082.32
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.41	8.24	52.83	1.75	18.23	9.90	1.23	83644.90
最大值	12.83	14.23	70.35	2.82	19.48	10.38	1.31	86888.81
發生時間	0	5	2	0	2	0		4
最小值	5.63	4.27	44.47	1.06	16.34	9.36	1.19	79113.68
發生時間	18	14	13	12	0	9		0
零點偏移(率)	-0.09 %	-0.01 %	-0.02 %	-0.06 %		0.02		0.00 %
全幅偏移(率)	0.04 %	1.12 %	0.04 %	0.30 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月27日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.15	13.52	65.06	2.37	15.07	11.54	1.01	79044.22
1	16.40	11.07	64.68	3.25	17.28	11.35	1.01	79838.62
2	16.40	5.02	61.15	3.20	16.52	10.41	1.00	85493.94
3	8.56	7.36	57.72	3.20	13.63	11.18	1.00	79617.18
4	5.13	12.17	56.59	1.74	15.42	11.12	1.01	77857.43
5	2.23	7.09	61.24	1.42	16.03	10.72	1.01	81764.06
6	3.22	7.17	61.07	1.49	15.47	11.09	1.00	78966.64
7	3.95	7.18	69.01	0.93	16.85	10.28	0.97	77999.33
8	2.29	7.76	53.63	1.14	16.04	10.66	0.97	80540.59
9	1.03	6.89	66.97	0.93	16.54	10.50	0.95	80747.63
10	3.20	9.18	52.76	1.06	16.69	10.35	0.95	80896.01
11	11.06	12.17	48.93	3.38	15.14	10.82	0.94	76832.74
12	4.56	9.28	58.63	1.35	15.98	10.73	0.96	74724.93
13	0.52	8.87	54.97	0.96	16.00	10.24	0.97	79593.19
14	0.44	7.42	59.83	1.15	15.33	10.70	0.95	75660.43
15	0.01	9.84	53.40	0.93	15.66	10.77	0.97	75909.82
16	1.14	11.07	53.52	1.88	14.05	11.06	0.97	74377.75
17	15.52	6.70	56.50	2.25	15.04	10.75	0.99	77081.00
18	8.76	7.34	55.93	1.58	15.51	10.61	0.99	78372.29
19	8.24	10.40	55.14	1.50	16.11	10.69	0.99	78765.92
20	14.58	15.41	56.27	1.31	16.67	10.87	1.01	80341.69
21	3.84	5.52	55.18	0.96	16.95	10.75	1.02	82136.67
22	1.04	6.06	57.75	1.04	16.26	10.97	1.00	81546.56
23	0.76	8.00	59.15	1.15	15.96	11.00	0.97	80766.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.92	8.85	58.13	1.67	15.84	10.80	0.98	79119.81
最大值	16.40	15.41	69.01	3.38	17.28	11.54	1.04	85493.94
發生時間	1	20	7	11	1	0		2
最小值	0.01	5.02	48.93	0.93	13.63	10.24	0.94	74377.75
發生時間	15	2	11	7	3	13		16
零點偏移(率)	-0.02 %	0.00 %	-0.03 %	-0.04 %		0.00		0.00 %
全幅偏移(率)	-0.33 %	1.58 %	-0.28 %	0.49 %		0.00		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								