

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月01日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	13.27	1.76	55.34	2.69	16.43	10.79	1.08	83436.83
1	8.15	0.98	55.31	2.41	17.58	10.85	1.06	82491.49
2	9.82	2.57	46.70	2.57	16.34	10.55	1.06	83870.63
3	9.54	1.38	52.04	1.93	17.00	10.88	1.06	80533.52
4	10.35	1.44	48.80	1.36	18.85	10.34	1.06	83009.98
5	14.71	3.85	56.40	1.81	18.63	10.39	1.06	83138.42
6	10.04	2.88	57.20	2.75	16.26	10.92	1.06	85451.90
7	4.47	1.65	59.12	2.05	17.37	10.93	1.05	83170.23
8	12.27	2.17	50.04	2.92	16.43	10.91	1.06	82118.40
9	8.48	2.39	54.17	2.36	16.07	11.16	1.08	79944.60
10	9.09	2.29	51.56	3.32	14.98	10.97	1.06	84668.27
11	10.76	4.19	58.71	3.97	14.24	11.17	1.09	84284.26
12	11.81	2.21	61.95	3.09	15.49	11.36	1.10	80559.16
13	8.33	1.85	64.39	2.63	15.94	11.60	1.09	78460.36
14	10.46	2.82	67.02	2.70	15.99	11.67	1.09	77686.93
15	15.32	3.03	63.61	3.67	15.89	10.81	1.06	85428.84
16	11.76	1.86	57.01	3.02	16.24	10.74	1.06	84943.14
17	9.22	9.48	58.56	3.30	15.78	10.74	1.06	79088.69
18	9.12	1.06	59.13	2.29	16.76	10.70	1.08	83671.44
19	6.96	2.55	67.87	2.08	16.41	11.45	1.10	78469.90
20	10.31	3.42	55.31	1.86	17.90	10.37	1.09	85959.67
21	9.89	2.30	66.84	1.89	17.08	10.60	1.06	84380.81
22	8.48	2.48	66.44	1.14	18.05	10.71	1.07	82695.49
23	8.73	3.47	53.33	2.04	17.26	10.48	1.07	84018.56
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	10.06	2.67	57.79	2.49	16.62	10.88	1.07	82561.73
最 大 值	15.32	9.48	67.87	3.97	18.85	11.67	1.10	85959.67
發生時間	15	17	19	11	4	14		20
最 小 值	4.47	0.98	46.70	1.14	14.24	10.34	1.04	77686.93
發生時間	7	1	2	22	11	4		14
零點偏移(率)	-0.08 %	-0.00 %	-0.04 %	0.00 %		-0.05		0.00 %
全幅偏移(率)	0.00 %	-0.03 %	-0.20 %	0.24 %		-0.09		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年05月01日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.85	5.66	55.33	1.71	16.14	9.99	1.46	77532.36
1	1.50	5.39	57.11	1.45	17.62	9.92	1.43	78553.36
2	0.59	4.40	44.63	1.35	17.77	9.08	1.43	75698.21
3	1.32	5.11	49.83	1.49	18.12	9.14	1.43	76680.71
4	2.14	1.28	49.80	1.26	19.72	9.15	1.43	75128.18
5	3.23	6.49	39.36	2.59	20.56	8.16	1.46	84233.55
6	7.94	6.96	51.21	1.96	18.29	9.03	1.46	80798.73
7	6.69	10.38	50.71	2.90	14.77	9.77	1.43	80952.03
8	3.60	1.35	61.30	2.13	16.30	10.07	1.43	78264.23
9	8.79	2.86	64.49	2.30	17.34	9.90	1.44	82730.98
10	5.86	1.41	62.81	2.18	17.33	9.89	1.43	83932.92
11	6.80	2.69	61.65	2.31	17.70	9.49	1.42	81431.65
12	6.78	2.70	60.03	2.15	17.15	9.58	1.42	81669.22
13	3.69	5.75	63.58	1.90	17.75	9.59	1.43	82901.56
14	4.48	2.57	68.39	2.37	15.29	10.78	1.43	77662.44
15	6.85	3.01	66.66	2.23	16.43	10.07	1.43	83616.50
16	5.49	1.30	67.39	2.17	15.85	10.30	1.45	81679.33
17	5.83	3.67	64.39	2.08	17.23	9.62	1.46	80122.77
18	0.30	1.31	64.55	1.58	16.96	10.41	1.45	72844.90
19	0.96	6.54	67.71	5.13	17.84	10.03	1.43	82784.85
20	2.21	2.10	56.61	1.35	18.07	9.56	1.41	80359.30
21	4.39	5.63	62.44	2.01	17.96	9.50	1.43	84016.26
22	6.57	2.22	62.74	2.05	17.99	9.70	1.43	80966.58
23	2.62	1.15	58.89	1.75	17.90	10.30	1.44	75882.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.19	3.83	58.82	2.10	17.42	9.71	1.44	80018.45
最 大 值	8.79	10.38	68.39	5.13	20.56	10.78	1.49	84233.55
發生時間	9	7	14	19	5	14		5
最 小 值	0.30	1.15	39.36	1.26	14.77	8.16	1.39	72844.90
發生時間	18	23	5	4	7	5		18
零點偏移(率)	-0.06 %	0.00 %	-0.07 %	-0.04 %		-0.02		-0.10 %
全幅偏移(率)	-0.01 %	-0.05 %	-1.12 %	0.15 %		0.11		-0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								