

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月29日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.09	7.91	46.54	0.82	18.22	11.35	1.10	74587.85
1	5.65	8.13	51.32	0.89	19.94	10.94	1.10	76211.52
2	8.07	8.28	63.44	1.10	17.77	11.32	1.10	75204.54
3	8.54	8.42	49.56	1.21	17.60	11.35	1.09	74898.52
4	8.17	8.31	69.86	0.94	17.64	11.63	1.10	72730.22
5	10.00	11.84	62.02	1.27	17.36	11.56	1.07	75811.08
6	7.05	7.57	49.57	1.31	16.88	11.43	1.05	74476.27
7	8.38	7.39	51.46	1.75	16.44	11.56	1.06	73882.43
8	8.79	7.12	50.65	2.28	15.69	11.64	1.07	73608.08
9	9.27	6.86	52.28	1.79	16.43	11.57	1.03	73560.71
10	8.77	8.65	46.52	2.09	14.82	12.03	1.04	70807.53
11	7.65	9.39	53.89	2.17	15.07	12.04	1.07	70318.77
12	8.53	8.29	58.65	2.02	15.79	11.91	1.05	70967.29
13	4.30	7.59	62.24	1.01	16.94	11.69	1.06	72052.86
14	遺失	遺失	遺失	遺失	遺失	遺失	1.04	遺失
15	10.23	8.08	54.31	1.32	18.05	11.09	1.04	74855.37
16	8.98	8.82	62.33	1.10	18.66	11.32	1.07	73912.02
17	9.78	1.69	50.67	0.79	19.14	11.05	1.06	75251.90
18	13.08	1.48	35.52	1.42	18.82	10.72	1.05	77725.06
19	10.77	3.33	44.85	1.88	17.87	11.33	1.05	73398.80
20	10.47	3.72	48.81	1.47	18.23	11.19	1.05	74959.86
21	11.21	3.78	48.41	1.41	17.99	11.08	1.05	76088.82
22	9.85	4.01	48.96	1.47	17.68	11.34	1.05	74114.65
23	9.10	5.59	48.66	1.13	16.84	12.13	1.03	68785.84
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	23
平均值	8.86	6.79	52.63	1.42	17.39	11.45	1.06	73835.22
最大值	13.08	11.84	69.86	2.28	19.94	12.13	1.10	77725.06
發生時間	18	5	4	8	1	23		18
最小值	4.30	1.48	35.52	0.79	14.82	10.72	1.01	68785.84
發生時間	13	18	18	17	10	18		23
零點偏移(率)	-0.06 %	-0.01 %	-0.01 %	-0.04 %		-0.30		0.00 %
全幅偏移(率)	0.57 %	-0.18 %	-0.01 %	0.52 %		0.24		0.20 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	95.83 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月29日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.63	9.70	47.80	2.19	17.94	9.58	1.02	88703.99
1	8.59	9.53	55.31	1.98	18.45	9.61	1.02	88486.82
2	8.99	3.69	53.04	2.00	18.27	9.44	1.02	89513.89
3	8.01	4.41	50.83	2.10	17.78	9.67	1.02	88258.55
4	8.50	10.02	55.84	2.46	17.34	9.70	1.02	88735.80
5	8.94	5.04	56.48	2.84	17.14	9.87	1.01	87426.04
6	9.24	9.44	58.13	4.00	15.54	10.27	0.99	89348.03
7	8.91	3.34	58.53	3.15	15.28	10.52	0.99	84401.44
8	9.28	2.83	55.77	2.26	15.85	10.50	0.99	84315.59
9	7.75	6.22	58.22	1.66	16.20	10.25	0.99	85719.50
10	8.08	3.72	55.66	1.98	15.72	10.50	1.01	84202.65
11	6.62	3.20	53.41	2.19	15.70	10.22	1.00	84820.45
12	2.88	3.73	54.98	1.87	15.87	10.32	0.99	82302.80
13	3.01	4.97	48.91	1.14	17.83	9.73	0.99	83175.80
14	遺失	遺失	遺失	遺失	遺失	遺失	0.99	遺失
15	9.70	4.40	57.65	2.51	15.32	10.44	0.99	84628.04
16	9.74	3.20	57.49	2.82	14.34	10.46	0.99	86207.64
17	9.32	9.55	36.04	2.80	15.55	10.09	0.99	87719.50
18	11.26	3.47	53.46	1.93	15.61	10.14	0.99	87277.39
19	9.91	3.00	52.71	1.42	16.07	10.24	0.99	85462.24
20	14.34	4.52	63.36	1.85	16.38	10.04	1.02	86644.71
21	8.71	4.44	68.59	1.49	15.87	11.65	1.02	74544.42
22	8.91	12.90	57.27	1.93	14.19	12.17	1.02	72204.69
23	10.85	3.84	43.52	2.33	16.29	10.10	1.01	86917.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	24	23
平均值	8.70	5.62	54.48	2.21	16.28	10.24	1.00	85261.62
最大值	14.34	12.90	68.59	4.00	18.45	12.17	1.03	89513.89
發生時間	20	22	21	6	1	22		2
最小值	2.88	2.83	36.04	1.14	14.19	9.44	0.97	72204.69
發生時間	12	8	17	13	22	2		22
零點偏移(率)	-0.01 %	0.00 %	-0.02 %	-0.01 %		0.03		-0.10 %
全幅偏移(率)	-0.13 %	1.23 %	-1.00 %	0.40 %		-0.13		0.00 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	95.83 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月29日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.69	5.20	63.13	1.04	16.69	11.27	0.98	74657.35
1	8.71	11.83	54.12	1.66	16.28	10.97	0.98	82382.65
2	8.21	6.70	64.28	1.49	15.77	11.19	0.98	78902.12
3	5.92	5.55	51.27	1.73	15.04	11.02	0.98	78180.51
4	6.31	5.93	58.71	1.79	15.03	11.25	0.98	76966.72
5	7.67	6.23	57.17	1.59	15.42	11.12	0.97	77396.88
6	6.63	7.42	51.33	1.74	15.64	10.70	0.97	81026.79
7	4.90	3.71	56.32	1.81	14.40	11.26	0.99	70957.29
8	7.27	3.35	55.71	2.09	14.31	11.04	0.99	77924.56
9	7.77	4.72	55.20	2.29	14.32	10.95	0.99	77146.92
10	6.30	7.38	46.94	2.11	13.90	10.73	0.99	75380.14
11	4.58	2.92	48.08	1.64	14.32	10.79	1.00	76159.05
12	4.58	2.46	49.08	1.71	14.45	10.83	0.99	76048.84
13	5.56	2.14	62.56	1.28	15.56	10.89	1.00	77944.31
14	遺失	遺失	遺失	遺失	遺失	10.91	0.99	遺失
15	11.03	5.20	50.07	2.04	15.64	10.32	0.98	78967.76
16	9.11	6.87	48.32	2.89	13.43	11.06	0.98	73420.44
17	12.49	6.88	43.59	3.28	14.18	10.64	0.98	75344.49
18	10.97	2.09	60.04	2.07	15.02	10.75	0.99	74287.26
19	10.76	1.77	37.47	2.35	15.07	10.19	0.99	77733.25
20	10.29	2.01	66.87	2.49	14.52	10.37	0.97	75876.96
21	12.70	7.16	57.57	3.18	12.89	10.89	0.98	73910.26
22	12.49	8.06	40.26	2.38	14.18	11.12	0.99	75172.78
23	8.22	3.96	41.41	1.94	14.12	11.52	0.99	70737.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	24	24	23
平均值	8.01	5.20	53.02	2.03	14.79	10.91	0.98	76370.66
最大值	12.70	11.83	66.87	3.28	16.69	11.52	1.02	82382.65
發生時間	21	1	20	17	0	23		1
最小值	1.69	1.77	37.47	1.04	12.89	10.19	0.97	70737.80
發生時間	0	19	19	0	21	19		23
零點偏移(率)	-0.15 %	0.00 %	-0.01 %	-0.02 %		0.05		0.00 %
全幅偏移(率)	0.32 %	-0.05 %	-0.63 %	0.13 %		0.21		0.10 %
有效比率	95.83 %	95.83 %	95.83 %	95.83 %	95.83 %	100.00 %	100.00 %	95.83 %
備註								