

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月31日

| 項目      | #1-HCl_C | #1-CO_C  | #1-NOx_C | #1-SO2_C | #1-H2O   | #1-O2_C  | #1-OPAC  | #1-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 9.25     | 12.71    | 59.00    | 2.89     | 16.55    | 11.22    | 1.21     | 83218.08  |
| 1       | 9.31     | 12.68    | 59.55    | 2.76     | 17.01    | 11.15    | 1.22     | 83231.42  |
| 2       | 11.82    | 12.63    | 56.23    | 3.63     | 15.08    | 11.28    | 1.23     | 84012.31  |
| 3       | 7.01     | 12.91    | 61.82    | 2.67     | 15.57    | 11.25    | 1.23     | 83771.53  |
| 4       | 11.48    | 12.52    | 51.83    | 2.88     | 16.64    | 11.02    | 1.23     | 84754.88  |
| 5       | 1.04     | 12.81    | 56.22    | 1.97     | 16.19    | 11.21    | 1.25     | 79554.35  |
| 6       | 7.62     | 13.11    | 59.95    | 3.29     | 14.66    | 11.70    | 1.25     | 80378.03  |
| 7       | 6.01     | 12.99    | 60.30    | 2.34     | 15.23    | 11.54    | 1.25     | 81720.22  |
| 8       | 8.13     | 13.43    | 62.28    | 2.18     | 15.44    | 11.52    | 1.24     | 81662.87  |
| 9       | 9.92     | 13.00    | 61.27    | 2.13     | 14.87    | 11.63    | 1.24     | 81357.41  |
| 10      | 9.02     | 12.37    | 50.58    | 1.34     | 18.52    | 10.62    | 1.25     | 85874.60  |
| 11      | 12.52    | 12.34    | 47.27    | 1.59     | 17.86    | 10.71    | 1.24     | 85991.84  |
| 12      | 6.42     | 12.53    | 42.18    | 1.69     | 16.97    | 10.83    | 1.21     | 84952.45  |
| 13      | 10.44    | 12.38    | 56.68    | 1.91     | 16.77    | 10.82    | 1.22     | 85620.51  |
| 14      | 10.16    | 12.73    | 57.73    | 2.00     | 16.78    | 11.00    | 1.23     | 84090.46  |
| 15      | 9.02     | 13.05    | 52.93    | 2.10     | 15.76    | 11.16    | 1.21     | 83848.48  |
| 16      | 10.06    | 12.88    | 62.88    | 1.93     | 15.90    | 11.39    | 1.22     | 81806.56  |
| 17      | 8.02     | 13.01    | 60.06    | 1.91     | 15.63    | 11.35    | 1.23     | 82382.05  |
| 18      | 9.10     | 14.02    | 57.56    | 2.06     | 16.19    | 11.40    | 1.23     | 81356.12  |
| 19      | 6.32     | 12.72    | 60.30    | 1.42     | 17.11    | 11.37    | 1.23     | 81116.71  |
| 20      | 11.95    | 12.61    | 57.37    | 1.67     | 17.21    | 10.83    | 1.21     | 85509.22  |
| 21      | 7.51     | 12.30    | 50.23    | 2.07     | 15.61    | 10.98    | 1.21     | 84537.92  |
| 22      | 9.76     | 12.84    | 54.98    | 1.75     | 16.84    | 10.99    | 1.23     | 82315.48  |
| 23      | 8.59     | 12.60    | 47.95    | 2.24     | 15.39    | 11.21    | 1.23     | 83410.70  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.77     | 12.80    | 56.13    | 2.18     | 16.24    | 11.17    | 1.23     | 83186.42  |
| 最大值     | 12.52    | 14.02    | 62.88    | 3.63     | 18.52    | 11.70    | 1.25     | 85991.84  |
| 發生時間    | 11       | 18       | 16       | 2        | 10       | 6        |          | 11        |
| 最小值     | 1.04     | 12.30    | 42.18    | 1.34     | 14.66    | 10.62    | 1.20     | 79554.35  |
| 發生時間    | 5        | 21       | 12       | 10       | 6        | 10       |          | 5         |
| 零點偏移(率) | -0.06 %  | 0.00 %   | -0.07 %  | -0.00 %  |          | -0.01    | -0.01    | 0.10 %    |
| 全幅偏移(率) | -1.27 %  | -1.26 %  | 0.68 %   | -0.22 %  |          | 0.22     | 0.00     | 0.10 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月31日

| 項目      | #2-HCl_C | #2-CO_C  | #2-NOx_C | #2-SO2_C | #2-H2O   | #2-O2_C  | #2-OPAC  | #2-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 3.35     | 12.70    | 53.23    | 1.48     | 17.64    | 11.16    | 0.94     | 79731.06  |
| 1       | 8.22     | 12.35    | 58.29    | 2.20     | 17.18    | 10.93    | 0.94     | 79912.83  |
| 2       | 5.58     | 12.65    | 54.00    | 2.66     | 16.50    | 10.47    | 0.94     | 80065.22  |
| 3       | 7.60     | 11.99    | 57.70    | 2.26     | 16.82    | 10.68    | 0.94     | 77203.00  |
| 4       | 7.61     | 11.97    | 50.33    | 2.14     | 16.88    | 10.32    | 0.92     | 80218.77  |
| 5       | 8.84     | 12.15    | 60.50    | 2.72     | 16.38    | 10.91    | 0.93     | 80805.52  |
| 6       | 9.48     | 12.01    | 56.56    | 1.28     | 18.13    | 10.60    | 0.94     | 78260.55  |
| 7       | 7.64     | 12.11    | 52.63    | 1.18     | 18.30    | 10.65    | 0.94     | 81343.92  |
| 8       | 3.95     | 12.03    | 60.40    | 1.22     | 17.74    | 10.65    | 0.94     | 82287.01  |
| 9       | 11.13    | 11.93    | 63.39    | 1.79     | 17.19    | 10.67    | 0.94     | 81778.84  |
| 10      | 5.41     | 12.99    | 51.97    | 2.16     | 16.32    | 10.48    | 0.97     | 81749.81  |
| 11      | 14.49    | 12.06    | 64.22    | 1.46     | 18.22    | 10.48    | 0.96     | 83122.29  |
| 12      | 4.63     | 12.29    | 56.64    | 0.87     | 19.03    | 10.28    | 0.97     | 85156.80  |
| 13      | 15.49    | 12.24    | 64.38    | 1.55     | 17.13    | 10.93    | 0.97     | 81569.53  |
| 14      | 8.77     | 11.94    | 52.12    | 1.11     | 17.28    | 10.65    | 0.95     | 81894.65  |
| 15      | 8.32     | 12.19    | 65.61    | 1.36     | 16.76    | 10.47    | 0.95     | 83918.38  |
| 16      | 7.55     | 13.03    | 61.22    | 1.38     | 17.64    | 11.05    | 0.97     | 77300.17  |
| 17      | 13.97    | 12.15    | 60.20    | 1.23     | 17.51    | 10.58    | 0.96     | 82180.88  |
| 18      | 6.27     | 12.04    | 59.02    | 1.69     | 17.27    | 10.66    | 0.96     | 81933.38  |
| 19      | 6.57     | 11.45    | 60.39    | 0.79     | 18.75    | 9.94     | 0.95     | 83003.00  |
| 20      | 8.69     | 11.83    | 55.12    | 0.64     | 19.13    | 10.24    | 0.94     | 82041.92  |
| 21      | 7.98     | 11.62    | 46.77    | 0.98     | 18.29    | 9.97     | 0.94     | 83425.36  |
| 22      | 7.24     | 11.29    | 55.90    | 0.95     | 18.65    | 9.80     | 0.94     | 83925.32  |
| 23      | 8.42     | 12.02    | 52.35    | 1.33     | 17.28    | 10.30    | 0.94     | 78426.25  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 8.22     | 12.13    | 57.21    | 1.52     | 17.58    | 10.54    | 0.95     | 81302.27  |
| 最大值     | 15.49    | 13.03    | 65.61    | 2.72     | 19.13    | 11.16    | 1.02     | 85156.80  |
| 發生時間    | 13       | 16       | 15       | 5        | 20       | 0        |          | 12        |
| 最小值     | 3.35     | 11.29    | 46.77    | 0.64     | 16.32    | 9.80     | 0.92     | 77203.00  |
| 發生時間    | 0        | 22       | 21       | 20       | 10       | 22       |          | 3         |
| 零點偏移(率) | -0.08 %  | -0.00 %  | -0.03 %  | -0.00 %  |          | 0.00     | -0.01    | -0.10 %   |
| 全幅偏移(率) | 2.03 %   | -0.79 %  | 1.27 %   | -0.91 %  |          | 0.11     | 0.00     | 0.00 %    |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 115年05月31日

| 項目      | #3-HCl_C | #3-CO_C  | #3-NOx_C | #3-SO2_C | #3-H2O   | #3-O2_C  | #3-OPAC  | #3-FLOW_C |
|---------|----------|----------|----------|----------|----------|----------|----------|-----------|
| 單位      | ppm      | ppm      | ppm      | ppm      | %        | %        | %        | m3/Hour   |
| 小時\限標   | 60.00    | 150.00   | 220.00   | 150.00   | 100.00   | 25.00    | 10.00    | 999999.00 |
| 0       | 4.83     | 11.00    | 57.96    | 3.10     | 19.45    | 9.48     | 1.37     | 75128.11  |
| 1       | 4.38     | 11.06    | 53.83    | 2.75     | 20.03    | 9.43     | 1.39     | 76078.46  |
| 2       | 5.22     | 10.80    | 48.63    | 2.90     | 18.34    | 9.21     | 1.36     | 73695.97  |
| 3       | 6.05     | 11.01    | 48.66    | 2.85     | 17.68    | 9.57     | 1.36     | 72664.97  |
| 4       | 6.40     | 11.00    | 51.43    | 2.96     | 16.68    | 9.75     | 1.37     | 72160.56  |
| 5       | 6.97     | 10.95    | 49.95    | 2.96     | 17.56    | 9.63     | 1.38     | 72898.91  |
| 6       | 4.95     | 11.22    | 49.34    | 2.85     | 17.02    | 9.63     | 1.39     | 73939.59  |
| 7       | 6.66     | 11.49    | 59.07    | 3.33     | 18.02    | 9.66     | 1.37     | 72707.80  |
| 8       | 5.31     | 10.99    | 57.79    | 3.07     | 17.28    | 9.85     | 1.33     | 74104.66  |
| 9       | 6.95     | 10.84    | 54.76    | 3.08     | 18.26    | 9.58     | 1.36     | 74123.84  |
| 10      | 7.14     | 10.89    | 49.55    | 2.93     | 17.64    | 9.72     | 1.38     | 73604.88  |
| 11      | 9.92     | 10.82    | 51.74    | 3.02     | 17.77    | 9.63     | 1.32     | 74641.63  |
| 12      | 8.48     | 10.91    | 54.52    | 3.10     | 18.61    | 9.58     | 1.35     | 75052.72  |
| 13      | 5.51     | 10.98    | 52.14    | 2.90     | 17.55    | 9.81     | 1.36     | 74938.70  |
| 14      | 9.37     | 11.01    | 55.42    | 3.14     | 19.09    | 9.63     | 1.36     | 77508.12  |
| 15      | 6.86     | 11.19    | 51.17    | 3.05     | 18.19    | 9.91     | 1.35     | 71069.99  |
| 16      | 9.27     | 10.75    | 47.66    | 3.21     | 19.48    | 8.65     | 1.31     | 78115.46  |
| 17      | 9.95     | 11.12    | 63.37    | 3.55     | 17.45    | 9.93     | 1.34     | 76027.36  |
| 18      | 7.62     | 11.42    | 56.96    | 3.01     | 17.19    | 10.31    | 1.37     | 74285.20  |
| 19      | 5.00     | 11.37    | 51.71    | 2.95     | 17.54    | 10.07    | 1.35     | 69762.64  |
| 20      | 9.16     | 10.78    | 46.03    | 2.86     | 17.79    | 9.20     | 1.32     | 74918.50  |
| 21      | 10.15    | 10.85    | 44.19    | 2.92     | 18.54    | 8.53     | 1.35     | 73223.57  |
| 22      | 10.32    | 13.19    | 45.30    | 1.55     | 19.73    | 7.53     | 1.36     | 75158.61  |
| 23      | 10.42    | 11.43    | 45.49    | 2.10     | 19.11    | 7.42     | 1.36     | 73468.24  |
| 監測時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 超限次數    | 0        | 0        | 0        | 0        | 0        | 0        | 0        | 0         |
| 有效時數    | 24       | 24       | 24       | 24       | 24       | 24       | 24       | 24        |
| 平均值     | 7.37     | 11.13    | 51.94    | 2.92     | 18.17    | 9.40     | 1.36     | 74136.60  |
| 最大值     | 10.42    | 13.19    | 63.37    | 3.55     | 20.03    | 10.31    | 1.41     | 78115.46  |
| 發生時間    | 23       | 22       | 17       | 17       | 1        | 18       |          | 16        |
| 最小值     | 4.38     | 10.75    | 44.19    | 1.55     | 16.68    | 7.42     | 1.31     | 69762.64  |
| 發生時間    | 1        | 16       | 21       | 22       | 4        | 23       |          | 19        |
| 零點偏移(率) | -0.13 %  | 0.01 %   | -0.18 %  | -0.01 %  |          | -0.04    | -0.01    | -0.20 %   |
| 全幅偏移(率) | 1.18 %   | 0.84 %   | 1.54 %   | 0.10 %   |          | 0.29     | 0.00     | -0.20 %   |
| 有效比率    | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 % | 100.00 %  |
| 備註      |          |          |          |          |          |          |          |           |