

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.26	6.19	52.32	3.98	13.43	12.51	1.46	69870.86
1	10.91	11.40	55.50	4.30	13.01	12.75	1.45	68483.60
2	9.33	6.09	60.40	2.69	15.90	12.18	1.46	71120.40
3	7.93	6.04	52.76	3.31	14.24	12.37	1.46	71245.40
4	9.30	11.77	56.45	3.70	13.84	12.56	1.46	69475.49
5	4.70	4.83	63.30	2.53	15.62	12.21	1.46	69963.81
6	6.03	3.53	55.49	2.49	15.32	12.22	1.46	71178.21
7	5.20	3.22	54.35	2.44	15.30	12.07	1.46	72709.96
8	5.81	4.23	48.87	3.33	13.66	12.41	1.46	71143.81
9	3.73	4.04	54.29	2.70	14.83	12.07	1.46	72845.28
10	4.61	3.73	52.33	3.09	14.02	12.35	1.46	71243.42
11	7.98	4.43	55.67	3.42	13.83	12.38	1.47	71277.47
12	9.79	8.31	49.94	4.16	12.29	12.55	1.46	71447.92
13	12.00	5.40	52.64	4.61	12.37	12.65	1.46	70097.53
14	12.39	3.47	50.63	4.26	12.33	12.50	1.46	71381.41
15	10.25	6.66	50.91	4.44	12.13	12.76	1.45	69794.55
16	10.04	6.24	59.67	3.84	13.05	12.56	1.44	71185.60
17	8.86	6.90	50.95	3.73	13.16	12.54	1.43	71307.67
18	8.80	3.80	59.49	3.31	13.71	12.36	1.41	72441.17
19	9.48	4.85	63.45	3.46	13.91	12.54	1.39	70500.22
20	6.20	5.74	60.98	3.08	13.91	12.55	1.39	70765.84
21	11.11	10.36	48.66	3.74	13.15	12.48	1.41	71343.47
22	10.17	3.74	65.08	3.60	13.20	12.51	1.42	71973.48
23	11.60	13.16	46.42	4.54	11.48	12.74	1.41	70823.83
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.60	6.17	55.02	3.53	13.65	12.45	1.44	70984.18
最大值	12.39	13.16	65.08	4.61	15.90	12.76	1.48	72845.28
發生時間	14	23	22	13	2	15		9
最小值	3.73	3.22	46.42	2.44	11.48	12.07	1.39	68483.60
發生時間	9	7	23	7	23	7		1
零點偏移(率)	0.00 %	-0.02 %	-0.12 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	-1.03 %	-0.19 %	-0.04 %	0.02 %		0.28	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.67	6.26	49.37	2.06	16.92	10.41	1.38	80354.55
1	9.34	6.62	49.50	1.88	17.29	10.38	1.38	82905.78
2	9.98	8.51	55.55	2.28	17.46	10.57	1.37	80737.34
3	10.12	6.15	47.19	2.38	18.70	9.76	1.38	84893.03
4	9.21	6.08	47.20	2.34	17.27	10.20	1.38	82063.24
5	10.91	6.50	52.57	2.21	17.78	10.29	1.38	84376.87
6	13.11	4.93	57.97	2.81	18.90	10.23	1.39	86040.15
7	9.84	4.08	49.29	1.87	17.66	10.33	1.41	87398.63
8	6.66	3.91	59.44	1.85	16.52	10.92	1.42	83067.51
9	2.73	3.86	42.46	1.73	16.50	10.98	1.42	69488.73
10	5.24	1.44	48.22	1.76	16.81	10.66	1.40	85348.35
11	5.69	2.73	57.85	1.97	15.79	11.60	1.40	73420.52
12	11.20	4.65	50.43	2.68	14.53	11.12	1.40	83464.48
13	9.25	5.50	54.97	2.81	13.49	11.39	1.43	81211.79
14	10.62	1.32	51.63	2.25	15.09	10.55	1.42	84484.77
15	11.67	2.22	50.63	2.62	15.16	10.32	1.41	80088.49
16	9.40	1.43	49.73	1.95	17.17	10.38	1.43	83026.75
17	8.97	2.17	50.68	2.03	15.71	10.85	1.45	80632.94
18	8.35	4.29	45.59	2.17	16.70	10.37	1.45	80293.90
19	7.98	2.27	44.15	1.67	17.33	10.26	1.45	80346.90
20	10.30	2.27	47.20	1.75	17.45	10.24	1.45	82172.04
21	8.71	4.84	46.90	1.73	17.21	10.30	1.46	81851.21
22	10.28	4.23	45.63	2.37	15.60	10.25	1.46	81024.32
23	9.64	3.54	49.65	2.07	16.55	10.29	1.46	82121.31
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.12	4.16	50.16	2.13	16.65	10.53	1.42	81700.57
最大值	13.11	8.51	59.44	2.81	18.90	11.60	1.52	87398.63
發生時間	6	2	8	6	6	11		7
最小值	2.73	1.32	42.46	1.67	13.49	9.76	1.36	69488.73
發生時間	9	14	9	19	13	3		9
零點偏移(率)	-0.02 %	0.00 %	-0.13 %	0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	0.31 %	-0.69 %	-0.25 %	-0.10 %		0.14	-0.06	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年02月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.77	4.68	63.18	2.00	16.40	10.62	1.80	82989.03
1	3.26	3.93	64.16	1.72	16.72	11.18	1.78	80603.90
2	2.56	6.69	56.06	1.48	17.66	10.67	1.77	83996.76
3	4.38	5.41	64.16	1.89	16.22	10.80	1.79	84467.63
4	8.90	6.74	57.95	2.02	17.40	10.30	1.80	87913.38
5	9.99	4.62	58.26	2.16	16.73	10.53	1.80	86166.35
6	9.99	6.25	61.75	2.19	16.69	10.61	1.80	86009.49
7	8.05	5.48	57.47	1.45	16.93	10.50	1.79	84138.43
8	7.90	3.49	62.32	1.80	15.10	11.13	1.78	82915.98
9	7.48	1.53	56.80	1.61	15.42	10.97	1.80	83621.34
10	9.12	3.24	53.35	1.99	15.84	10.66	1.80	85405.80
11	8.31	1.28	62.11	1.58	15.78	10.95	1.80	83819.90
12	9.83	2.68	60.29	2.20	14.34	11.28	1.78	82351.95
13	12.99	4.11	57.75	3.95	13.95	11.43	1.77	81443.14
14	10.64	3.54	54.94	3.46	12.94	11.93	1.76	80370.04
15	10.96	4.99	60.52	3.50	12.22	11.80	1.75	81465.93
16	9.19	3.47	57.52	2.71	13.73	11.65	1.73	81281.35
17	10.88	5.44	60.51	2.25	14.28	11.15	1.72	82899.51
18	8.98	5.02	66.50	2.48	13.76	11.82	1.72	77459.61
19	6.96	6.32	54.13	1.46	17.35	10.18	1.72	82500.41
20	10.24	6.12	52.05	1.86	15.17	10.64	1.72	80650.81
21	10.61	5.56	66.88	1.94	16.02	10.44	1.72	83026.89
22	13.47	7.68	56.96	3.34	13.51	10.98	1.72	78224.40
23	8.00	2.50	56.31	2.34	14.01	11.43	1.72	80060.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.77	4.62	59.25	2.22	15.34	10.99	1.76	82657.61
最大值	13.47	7.68	66.88	3.95	17.66	11.93	1.81	87913.38
發生時間	22	22	21	13	2	14		4
最小值	2.56	1.28	52.05	1.45	12.22	10.18	1.72	77459.61
發生時間	2	11	20	7	15	19		18
零點偏移(率)	-0.04 %	-0.04 %	-0.13 %	0.00 %		0.02	0.00	0.00 %
全幅偏移(率)	0.23 %	0.04 %	-0.36 %	0.00 %		0.35	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								