

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月30日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.36	0.95	55.44	0.68	21.06	11.01	1.41	76216.43
1	0.15	0.98	51.97	0.80	20.74	11.20	1.41	74741.22
2	0.12	4.90	45.23	0.67	21.31	11.08	1.43	75052.20
3	0.17	0.95	51.18	0.97	20.58	11.08	1.43	76255.79
4	0.12	1.41	48.31	1.00	19.83	10.94	1.44	78792.50
5	0.05	2.67	53.05	1.29	19.64	11.37	1.46	75552.14
6	0.08	2.99	47.17	1.20	19.61	11.11	1.46	78021.45
7	0.24	2.81	46.22	1.33	19.75	11.31	1.46	76229.57
8	3.66	1.04	57.33	0.72	21.39	10.32	1.44	82084.66
9	6.85	1.29	48.62	1.74	18.66	11.50	1.44	74826.67
10	5.70	1.72	45.79	1.41	19.92	11.16	1.45	76290.05
11	5.06	1.99	46.34	1.28	19.74	10.99	1.41	77660.22
12	4.35	2.01	44.58	1.58	18.49	11.59	1.45	73774.64
13	7.27	1.24	53.61	1.48	18.86	11.54	1.46	74700.84
14	1.76	1.75	47.96	1.32	19.14	11.46	1.42	73953.87
15	4.23	2.45	51.29	1.44	18.91	11.58	1.47	73713.90
16	4.11	2.77	45.35	1.51	18.59	11.47	1.46	75265.97
17	7.14	3.17	55.75	1.59	18.78	11.80	1.42	72216.03
18	3.79	9.53	69.65	1.78	17.72	12.64	1.48	66630.07
19	9.70	6.14	48.51	1.83	17.75	11.71	1.47	73800.15
20	4.79	4.71	60.13	1.35	19.48	11.25	1.46	76130.09
21	5.83	5.14	59.85	1.82	17.48	12.35	1.46	69053.92
22	4.38	7.39	59.16	1.64	18.49	11.91	1.48	72003.93
23	6.30	4.21	60.97	1.54	18.97	12.00	1.46	70840.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.63	3.09	52.23	1.33	19.37	11.43	1.45	74741.95
最大值	9.70	9.53	69.65	1.83	21.39	12.64	1.53	82084.66
發生時間	19	18	18	19	8	18		8
最小值	0.05	0.95	44.58	0.67	17.48	10.32	1.40	66630.07
發生時間	5	0	12	2	21	8		18
零點偏移(率)	-0.01 %	-0.01 %	-0.01 %	-0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	1.25 %	-0.12 %	-0.51 %	0.03 %		0.44	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月30日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.57	0.30	49.76	1.42	17.50	10.35	1.44	62672.08
1	1.10	0.63	51.71	1.13	18.08	10.03	1.44	65373.70
2	0.44	0.66	51.38	0.97	18.84	10.15	1.45	63477.00
3	0.20	1.41	46.72	1.18	17.51	10.01	1.45	65025.66
4	0.24	1.30	49.81	1.13	17.80	10.09	1.46	64481.40
5	0.67	1.18	50.17	1.47	16.78	10.63	1.48	63807.54
6	0.10	1.54	49.82	1.08	17.93	10.44	1.47	64799.80
7	0.06	2.34	47.64	1.07	17.46	10.17	1.46	63256.39
8	3.37	4.88	59.84	1.36	17.33	10.24	1.46	65481.77
9	7.36	0.99	59.01	1.48	17.89	9.95	1.49	66403.51
10	6.36	1.81	61.00	1.56	16.45	10.18	1.45	65019.56
11	4.57	1.96	55.46	1.43	16.49	10.01	1.43	63550.85
12	5.05	0.99	55.50	1.55	15.97	10.40	1.46	62087.09
13	6.11	0.62	63.60	1.73	15.75	10.74	1.48	63618.77
14	8.24	0.83	58.23	2.03	15.39	11.02	1.46	63439.61
15	3.85	0.77	64.37	1.27	17.02	10.28	1.48	64373.06
16	7.86	1.10	54.42	1.52	16.62	10.39	1.47	64237.22
17	9.99	1.28	70.64	1.52	16.74	10.78	1.45	62430.65
18	1.94	3.76	64.11	1.76	15.65	12.09	1.43	54648.21
19	9.84	2.35	49.71	1.61	16.70	10.54	1.45	64318.62
20	4.04	2.53	53.35	1.57	15.93	10.30	1.48	62963.10
21	5.34	1.41	68.92	1.44	16.89	10.55	1.49	62491.23
22	9.91	2.14	59.20	1.77	16.60	10.44	1.49	67236.89
23	5.17	0.75	65.53	1.19	17.80	10.45	1.49	64885.12
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.39	1.56	56.66	1.43	16.96	10.43	1.46	63753.28
最大值	9.99	4.88	70.64	2.03	18.84	12.09	1.50	67236.89
發生時間	17	8	17	14	2	18		22
最小值	0.06	0.30	46.72	0.97	15.39	9.95	1.42	54648.21
發生時間	7	0	3	2	14	9		18
零點偏移(率)	-0.06 %	-0.00 %	-0.01 %	-0.03 %		-0.04	0.00	0.00 %
全幅偏移(率)	1.04 %	-0.13 %	-0.21 %	0.30 %		0.23	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年01月30日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.54	6.54	45.13	2.64	15.92	10.37	1.81	84503.17
1	1.47	2.04	42.42	0.74	15.65	10.65	1.83	80518.03
2	0.97	0.58	52.45	0.62	16.54	11.01	1.85	82856.90
3	0.75	0.90	54.89	0.57	16.62	10.89	1.85	85157.41
4	3.47	1.53	56.19	1.29	15.12	11.18	1.85	86390.28
5	6.09	0.95	57.10	1.42	15.08	11.21	1.84	85670.78
6	3.41	1.66	59.91	1.03	15.27	11.33	1.83	84220.63
7	4.06	3.99	54.92	1.23	14.43	11.39	1.82	79441.42
8	6.23	1.32	53.59	1.23	15.58	10.78	1.82	88424.43
9	6.81	4.33	59.11	1.65	14.46	11.39	1.81	84390.52
10	4.58	3.19	54.20	1.54	13.82	11.26	1.81	82697.57
11	4.50	1.34	65.26	1.37	14.47	11.29	1.80	83658.39
12	5.01	1.25	57.55	1.18	14.68	11.15	1.83	81619.85
13	5.55	3.40	64.89	1.59	14.15	11.23	1.80	80603.47
14	5.64	5.44	59.89	1.54	14.25	11.21	1.80	81516.92
15	5.06	4.63	61.50	1.33	14.25	11.28	1.80	81840.82
16	6.93	6.12	61.63	1.66	14.04	11.15	1.83	81468.90
17	5.99	4.03	62.74	1.59	13.87	11.28	1.80	80294.97
18	3.83	13.53	75.60	1.34	15.10	11.71	1.78	79075.98
19	3.92	6.60	62.06	0.87	15.85	10.88	1.81	84284.70
20	7.77	5.70	54.53	1.36	14.54	11.09	1.82	84761.51
21	13.23	4.35	68.54	1.20	15.95	11.15	1.82	83858.04
22	6.55	4.46	58.35	0.94	15.58	10.83	1.82	85105.93
23	3.06	4.80	58.56	0.89	15.37	10.96	1.82	84054.11
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.06	3.86	58.38	1.28	15.02	11.11	1.82	83183.95
最大值	13.23	13.53	75.60	2.64	16.62	11.71	1.86	88424.43
發生時間	21	18	18	0	3	18		8
最小值	0.75	0.58	42.42	0.57	13.82	10.37	1.77	79075.98
發生時間	3	2	1	3	10	0		18
零點偏移(率)	-0.40 %	0.00 %	-0.05 %	-0.04 %		-0.34	0.00	0.00 %
全幅偏移(率)	3.57 %	-0.13 %	-0.26 %	0.32 %		0.24	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								