

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月06日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.00	11.70	59.71	0.69	18.78	11.38	1.05	78393.73
1	5.07	11.22	67.29	0.71	19.79	10.90	1.05	81577.35
2	9.79	13.47	48.30	1.18	18.13	11.14	1.05	82024.51
3	7.09	14.54	62.88	1.05	17.90	11.99	1.05	75220.21
4	5.01	14.82	64.99	0.66	18.28	12.13	1.05	74100.00
5	3.69	12.33	60.66	0.38	19.57	11.92	1.06	76580.12
6	6.51	12.65	61.41	0.95	18.61	11.91	1.05	75256.97
7	5.35	12.99	60.75	0.41	20.00	11.30	1.06	78944.80
8	6.21	12.94	62.95	0.52	20.11	11.39	1.06	77595.45
9	6.17	14.06	45.67	1.10	18.14	11.33	1.08	78823.70
10	6.82	12.16	50.17	1.97	17.65	11.50	1.08	76909.09
11	7.25	12.18	57.13	1.29	18.39	11.50	1.06	76623.63
12	2.81	11.64	65.16	0.44	19.05	11.80	1.07	74353.41
13	8.91	10.23	42.07	1.15	18.33	11.02	1.07	78212.69
14	8.53	11.98	46.28	1.81	17.64	11.31	1.05	74825.81
15	7.47	8.45	50.55	1.53	19.20	11.13	1.05	77793.00
16	9.70	11.46	49.64	1.53	18.69	11.15	1.05	78121.81
17	7.07	14.29	55.46	1.21	18.93	11.41	1.06	76397.96
18	7.53	12.48	65.73	0.59	20.02	11.22	1.07	78619.43
19	7.72	13.19	51.94	0.81	19.14	11.08	1.06	79763.27
20	9.74	14.28	57.67	1.02	19.00	11.44	1.05	77907.45
21	7.08	12.28	48.65	1.00	19.49	11.03	1.06	80481.01
22	9.02	11.84	52.61	1.08	19.07	11.17	1.07	79915.52
23	8.93	12.14	53.60	1.24	18.41	11.41	1.07	77302.75
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.06	12.47	55.89	1.01	18.85	11.40	1.06	77739.32
最大值	9.79	14.82	67.29	1.97	20.11	12.13	1.10	82024.51
發生時間	2	4	1	10	8	4		2
最小值	2.81	8.45	42.07	0.38	17.64	10.90	1.03	74100.00
發生時間	12	15	13	5	14	1		4
零點偏移(率)	-0.02 %	-0.02 %	-0.02 %	-0.01 %		-0.03		0.00 %
全幅偏移(率)	0.02 %	0.48 %	0.06 %	0.60 %		-0.12		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月06日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.27	9.56	61.94	1.43	18.09	11.09	1.15	76550.79
1	0.09	11.31	53.34	1.69	19.25	10.38	1.15	81384.41
2	0.13	10.52	64.29	1.87	17.33	11.49	1.15	74574.94
3	0.95	8.22	51.17	1.26	20.09	9.47	1.15	87746.48
4	5.87	7.84	58.34	1.25	19.72	9.82	1.15	84902.09
5	3.09	7.62	62.51	0.82	20.52	10.18	1.15	81869.82
6	0.06	8.19	59.75	0.63	19.99	10.99	1.11	69758.24
7	0.42	8.88	43.73	0.90	20.90	9.53	1.10	85614.39
8	6.77	6.93	46.23	3.02	16.68	10.18	1.11	84854.63
9	9.98	6.73	54.02	2.66	17.09	10.17	1.10	80805.70
10	5.61	6.29	60.01	1.70	18.36	10.27	1.11	78949.57
11	6.55	8.47	56.20	0.93	21.45	9.69	1.13	84264.04
12	9.23	10.23	39.94	2.05	19.58	9.75	1.12	85459.62
13	9.34	4.80	46.01	2.44	17.18	10.38	1.11	82828.27
14	9.30	7.97	49.35	2.34	17.69	10.28	1.12	82732.00
15	9.47	6.80	57.37	2.16	17.92	10.24	1.12	82576.03
16	8.14	5.80	49.90	1.32	19.78	9.91	1.12	84501.38
17	8.22	5.63	54.91	1.06	20.65	9.45	1.11	86850.32
18	9.22	5.90	46.89	2.32	18.26	10.38	1.11	81314.15
19	9.43	5.53	47.33	1.51	19.09	10.00	1.12	83845.26
20	9.19	6.86	50.92	1.75	18.62	10.10	1.11	83525.79
21	9.25	4.58	51.44	1.49	19.06	10.09	1.10	83539.90
22	9.24	7.32	49.04	2.07	18.30	10.05	1.10	83793.39
23	8.60	12.46	54.29	1.64	18.65	10.23	1.10	83404.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.18	7.69	52.87	1.68	18.93	10.17	1.12	82318.58
最大值	9.98	12.46	64.29	3.02	21.45	11.49	1.17	87746.48
發生時間	9	23	2	8	11	2		3
最小值	0.06	4.58	39.94	0.63	16.68	9.45	1.10	69758.24
發生時間	6	21	12	6	8	17		6
零點偏移(率)	-0.06 %	-0.11 %	-0.11 %	-0.00 %		-0.06		0.00 %
全幅偏移(率)	0.02 %	0.72 %	-0.04 %	0.62 %		-0.25		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年08月06日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.01	11.87	59.39	0.75	16.38	11.11	1.07	81147.87
1	0.15	11.62	52.79	0.98	16.22	11.33	1.07	80213.80
2	1.01	8.63	56.13	0.85	16.35	11.03	1.07	84542.90
3	0.71	12.19	55.45	1.15	15.57	11.29	1.07	81988.26
4	1.22	8.89	56.05	1.54	15.04	11.39	1.07	79603.23
5	0.82	11.13	62.32	0.96	16.40	11.33	1.07	81490.97
6	3.23	12.55	53.28	1.07	16.35	11.28	1.08	82317.85
7	5.38	12.32	53.66	1.45	15.58	10.95	1.07	77592.58
8	2.09	9.06	47.18	0.85	17.38	10.57	1.05	80126.02
9	2.54	10.09	53.55	0.66	18.38	10.34	1.07	81569.28
10	7.55	12.02	44.17	1.46	15.47	10.81	1.07	77019.77
11	2.83	7.98	51.41	0.72	16.97	10.63	1.03	75157.63
12	2.90	11.05	53.92	0.72	16.81	10.86	1.06	82371.64
13	1.53	5.94	56.63	0.80	16.47	10.91	1.09	80987.61
14	1.74	9.56	53.97	1.19	15.59	11.18	1.08	78543.34
15	9.54	7.76	59.69	1.15	16.75	10.97	1.05	81095.34
16	13.98	7.08	57.33	1.19	16.58	11.07	1.06	78303.64
17	1.10	11.13	50.33	0.82	15.73	11.10	1.07	78609.23
18	1.52	9.22	53.63	0.93	16.53	10.99	1.05	79737.20
19	2.52	15.83	53.38	0.76	17.59	10.73	1.04	81084.88
20	6.76	8.31	49.02	1.00	17.37	10.53	1.07	82112.24
21	5.45	5.12	52.92	1.15	16.31	10.88	1.05	80471.60
22	4.37	5.52	55.18	0.88	17.06	10.78	1.03	80054.04
23	2.02	8.15	53.06	0.81	16.55	10.92	1.02	78881.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.37	9.71	53.94	0.99	16.48	10.96	1.06	80209.27
最大值	13.98	15.83	62.32	1.54	18.38	11.39	1.10	84542.90
發生時間	16	19	5	4	9	4		2
最小值	0.01	5.12	44.17	0.66	15.04	10.34	1.01	75157.63
發生時間	0	21	10	9	4	9		11
零點偏移(率)	-0.02 %	0.00 %	-0.01 %	-0.08 %		-0.03		0.00 %
全幅偏移(率)	0.04 %	0.06 %	-1.00 %	0.50 %		0.04		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								