

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月22日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.28	7.18	47.44	1.25	19.32	10.95	1.07	83312.33
1	9.29	8.30	47.71	1.25	19.95	10.70	1.05	84205.96
2	9.69	6.38	52.58	1.44	20.20	11.05	1.04	80823.56
3	9.93	5.34	69.13	0.86	21.21	10.48	1.05	85174.48
4	10.17	7.62	44.65	2.01	17.06	11.66	1.04	78629.99
5	6.51	13.42	56.33	1.84	18.07	11.38	1.02	80890.04
6	9.92	12.47	54.68	2.10	18.07	11.16	1.02	82894.11
7	10.28	11.53	53.00	1.89	18.19	11.10	1.02	82763.61
8	10.39	13.74	58.46	1.58	18.68	11.44	1.05	79494.27
9	9.33	11.48	53.28	1.42	19.51	10.81	1.06	83794.73
10	10.14	14.86	49.45	2.25	17.21	11.49	1.05	79850.99
11	11.14	16.34	50.99	2.57	16.09	11.72	1.02	78126.30
12	8.26	12.59	49.44	2.63	15.58	11.74	1.04	77435.35
13	9.69	8.26	59.50	2.11	17.59	11.70	1.05	77755.37
14	10.10	8.76	52.86	2.16	18.00	11.23	1.05	81655.98
15	7.46	11.46	58.69	2.73	15.95	12.25	1.03	75044.53
16	7.48	8.18	54.27	1.94	17.18	11.72	1.05	78168.28
17	10.66	7.97	58.41	1.82	17.02	11.68	1.04	79481.98
18	9.20	11.65	54.51	2.02	16.72	11.56	1.02	79799.08
19	8.21	9.95	66.12	1.58	17.46	11.72	1.02	78000.28
20	11.27	13.53	53.35	2.00	17.84	11.36	1.02	81054.14
21	9.94	13.02	59.03	1.69	18.18	11.47	1.02	79726.65
22	9.32	12.33	69.57	1.24	18.68	11.47	1.05	79233.82
23	9.22	13.54	51.90	1.39	17.97	11.62	1.05	78811.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.41	10.83	55.22	1.82	17.99	11.39	1.04	80255.29
最大值	11.27	16.34	69.57	2.73	21.21	12.25	1.07	85174.48
發生時間	20	11	22	15	3	15		3
最小值	6.51	5.34	44.65	0.86	15.58	10.48	1.01	75044.53
發生時間	5	3	4	3	12	3		15
零點偏移(率)	-0.04 %	0.00 %	-0.02 %	-0.00 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-0.13 %	-0.37 %	0.03 %		0.05		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月22日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.35	5.39	47.41	1.46	19.46	10.29	1.20	81330.96
1	9.54	8.66	44.17	1.71	19.71	9.99	1.20	83357.32
2	10.49	9.54	47.79	1.84	21.29	9.74	1.20	83538.72
3	8.74	8.48	53.09	2.62	18.40	10.27	1.20	82179.29
4	7.77	4.07	54.79	2.70	17.49	10.78	1.20	75030.06
5	8.47	7.49	52.41	2.53	18.36	9.95	1.20	81673.27
6	8.44	7.49	53.44	1.74	18.70	10.01	1.23	86818.72
7	8.10	9.48	53.11	3.02	17.71	9.87	1.23	83423.10
8	9.45	9.52	48.39	2.12	18.30	10.14	1.21	81317.41
9	9.40	7.23	53.51	1.95	18.48	10.00	1.22	84479.15
10	9.68	10.98	52.87	2.45	16.62	10.31	1.21	82415.85
11	8.71	7.43	60.12	2.69	16.50	10.48	1.23	80093.76
12	10.05	6.40	57.77	2.86	16.62	10.51	1.23	81209.32
13	8.68	8.91	54.67	2.67	16.44	10.44	1.23	79009.97
14	10.35	4.57	52.97	2.16	18.62	9.85	1.23	84097.81
15	8.32	5.37	54.47	2.52	16.78	10.59	1.19	77591.87
16	8.37	10.74	56.23	2.18	18.41	10.10	1.21	82623.86
17	8.52	4.63	55.87	2.50	16.72	10.37	1.21	81123.95
18	9.54	3.76	60.68	2.03	17.31	10.23	1.20	83126.94
19	8.67	5.54	48.29	1.73	17.99	10.07	1.20	81499.55
20	9.36	7.28	47.52	2.18	17.29	10.07	1.20	81032.45
21	8.82	7.85	55.43	1.67	18.63	9.94	1.20	81121.83
22	5.14	6.95	51.11	1.20	19.28	10.14	1.21	77642.35
23	4.47	7.64	45.02	1.52	19.06	9.75	1.21	83901.63
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.60	7.31	52.55	2.17	18.09	10.16	1.21	81651.63
最大值	10.49	10.98	60.68	3.02	21.29	10.78	1.25	86818.72
發生時間	2	10	18	7	2	4		6
最小值	4.47	3.76	44.17	1.20	16.44	9.74	1.18	75030.06
發生時間	23	18	1	22	13	2		4
零點偏移(率)	-0.01 %	-0.01 %	-0.05 %	-0.09 %		0.05		0.00 %
全幅偏移(率)	0.04 %	0.04 %	0.22 %	0.12 %		-0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年07月22日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.19	6.10	49.05	1.27	18.27	10.42	0.98	76835.20
1	4.35	33.10	37.07	1.62	16.81	10.44	0.97	78366.32
2	4.73	3.26	51.18	1.39	18.48	10.61	0.98	80256.26
3	5.59	3.88	58.75	1.69	17.28	10.86	0.99	78133.85
4	6.39	6.61	50.19	1.78	17.23	10.39	0.99	81581.58
5	7.39	6.30	54.51	1.91	16.52	10.78	0.99	78894.14
6	8.91	5.40	58.13	1.97	16.28	10.78	0.99	78887.72
7	11.83	15.47	52.24	2.22	15.39	11.06	1.04	78837.11
8	13.16	13.07	54.04	1.85	16.95	10.58	1.03	79766.93
9	11.35	7.44	49.41	2.15	16.47	10.49	1.06	80747.49
10	0.35	7.13	54.56	1.46	15.59	10.87	1.06	77810.11
11	0.53	12.85	54.33	1.40	15.91	10.72	1.05	78579.53
12	10.61	12.13	52.10	3.23	15.28	10.84	1.05	76403.42
13	4.28	11.42	54.86	2.89	15.58	11.00	1.01	77680.16
14	0.96	9.05	55.78	1.28	16.76	10.85	1.01	78664.45
15	0.51	9.65	58.95	1.31	16.37	11.29	1.02	74414.99
16	0.59	5.31	58.50	1.16	16.46	10.89	0.99	78664.31
17	0.63	8.80	56.53	1.51	15.49	10.88	0.99	77917.77
18	0.80	9.94	53.10	1.31	16.16	10.76	1.01	78699.49
19	0.56	9.40	55.88	1.39	15.71	10.92	1.01	78098.31
20	1.71	13.16	55.72	1.34	16.55	10.75	0.99	78905.07
21	7.05	15.40	56.41	1.82	15.94	10.78	0.99	77399.52
22	6.73	14.70	52.54	1.41	17.91	10.27	1.01	80571.59
23	3.63	15.16	55.71	1.30	17.74	10.25	1.01	80901.05
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.74	10.61	53.73	1.69	16.55	10.73	1.01	78625.68
最大值	13.16	33.10	58.95	3.23	18.48	11.29	1.07	81581.58
發生時間	8	1	15	12	2	15		4
最小值	0.35	3.26	37.07	1.16	15.28	10.25	0.97	74414.99
發生時間	10	2	1	16	12	23		15
零點偏移(率)	0.00 %	0.00 %	-0.09 %	-0.11 %		0.01		0.00 %
全幅偏移(率)	-4.66 %	0.04 %	-0.49 %	0.03 %		0.30		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								