

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月18日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.77	12.02	44.77	2.77	16.03	11.68	1.23	78441.64
1	8.66	13.10	55.05	2.77	14.47	12.66	1.23	71729.72
2	10.36	11.39	46.04	2.25	16.14	11.21	1.22	82745.47
3	9.81	11.71	47.93	3.12	14.21	11.71	1.24	79021.09
4	8.95	11.90	54.94	2.54	15.83	11.65	1.25	79171.54
5	13.20	11.80	47.91	2.59	14.20	11.79	1.29	79571.90
6	8.47	11.92	55.75	1.88	15.59	11.71	1.29	79283.48
7	12.90	11.81	46.54	3.34	14.07	11.81	1.28	79919.15
8	9.06	12.02	50.32	2.12	15.41	11.76	1.29	79486.11
9	11.66	11.65	48.41	2.58	14.55	11.50	1.29	82011.79
10	9.02	12.26	51.92	2.07	15.03	12.00	1.29	77639.77
11	13.70	11.70	55.73	2.55	15.62	11.24	1.29	83265.33
12	8.22	12.47	50.90	3.10	13.37	12.11	1.27	76969.53
13	7.35	12.82	51.20	2.20	13.98	12.42	1.27	74710.95
14	8.54	12.54	56.45	1.70	15.37	12.09	1.27	75994.32
15	9.37	12.29	53.22	2.16	15.26	11.94	1.25	77665.36
16	8.74	13.17	58.94	2.68	14.54	12.59	1.27	72847.16
17	11.55	11.91	44.47	2.34	15.82	11.50	1.29	80839.19
18	9.06	12.92	65.60	1.87	15.98	12.27	1.31	74466.93
19	9.18	11.62	47.88	2.10	16.44	11.21	1.29	82514.80
20	8.91	12.25	55.56	1.95	16.57	11.76	1.29	78315.36
21	8.96	11.81	52.70	2.86	15.16	11.59	1.29	80356.13
22	12.21	12.26	50.34	3.65	15.04	11.91	1.29	77842.84
23	8.51	12.23	61.02	2.32	16.02	11.85	1.29	77967.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.84	12.15	52.23	2.48	15.20	11.83	1.27	78449.04
最大值	13.70	13.17	65.60	3.65	16.57	12.66	1.34	83265.33
發生時間	11	16	18	22	20	1		11
最小值	7.35	11.39	44.47	1.70	13.37	11.21	1.21	71729.72
發生時間	13	2	17	14	12	2		1
零點偏移(率)	-0.06 %	0.00 %	-0.01 %	-0.02 %		-0.04	-0.01	0.40 %
全幅偏移(率)	-2.59 %	-2.02 %	-0.52 %	-1.42 %		0.11	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月18日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	11.43	11.73	59.29	1.83	16.04	10.58	1.02	77969.28
1	8.01	11.68	60.12	2.05	16.51	10.53	1.02	77751.42
2	14.00	11.20	59.50	2.55	15.93	10.17	1.02	80228.05
3	11.69	11.41	47.28	2.30	15.91	10.22	1.02	75200.65
4	8.40	11.07	50.11	1.93	16.68	9.88	1.02	78424.10
5	12.72	11.49	55.27	2.82	15.36	10.42	1.03	77946.38
6	9.97	11.34	38.56	3.23	16.08	10.17	1.06	76751.21
7	9.88	11.43	45.34	2.17	16.02	10.35	1.07	78776.50
8	10.26	12.02	46.51	2.11	14.82	10.95	1.07	77027.23
9	11.47	11.59	49.16	2.33	14.89	10.55	1.06	79254.75
10	8.51	12.07	53.32	1.83	14.43	11.09	1.05	77398.45
11	7.77	12.11	52.30	1.54	15.07	11.01	1.05	78470.93
12	12.45	12.05	47.83	2.24	14.77	10.99	1.04	79174.05
13	6.64	12.76	52.94	1.70	14.33	11.62	1.06	79662.31
14	12.89	12.30	61.77	1.78	15.67	11.09	1.06	80933.93
15	7.42	12.61	55.27	1.33	14.76	11.40	1.06	75498.19
16	7.05	12.50	54.45	1.33	14.77	11.33	1.06	80923.73
17	7.71	12.74	42.82	1.32	15.87	11.34	1.06	80531.98
18	7.23	12.81	49.20	1.47	15.97	11.32	1.06	78604.92
19	11.42	12.28	62.02	1.91	16.23	10.89	1.06	84256.18
20	4.98	12.63	53.09	2.28	15.40	11.19	1.07	78584.73
21	9.88	12.44	69.09	2.51	15.32	11.18	1.09	80419.92
22	9.51	12.32	46.59	2.05	14.43	11.14	1.08	79206.70
23	11.13	11.89	54.53	1.50	14.47	10.91	1.09	80022.58
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.68	12.02	52.76	2.00	15.41	10.85	1.05	78875.76
最大值	14.00	12.81	69.09	3.23	16.68	11.62	1.10	84256.18
發生時間	2	18	21	6	4	13		19
最小值	4.98	11.07	38.56	1.32	14.33	9.88	1.02	75200.65
發生時間	20	4	6	17	13	4		3
零點偏移(率)	-0.03 %	0.01 %	-0.02 %	-0.01 %		-0.06	-0.01	0.00 %
全幅偏移(率)	-2.39 %	-2.01 %	0.26 %	-0.29 %		0.10	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年02月18日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.84	12.20	58.74	2.98	14.66	10.82	1.46	72669.49
1	9.52	12.90	53.55	1.83	16.02	10.53	1.46	71141.16
2	10.34	13.08	52.77	2.29	14.28	10.24	1.46	72345.31
3	10.13	13.37	51.01	2.37	13.93	10.35	1.46	71062.32
4	8.38	12.85	49.82	2.17	14.07	10.30	1.46	70810.76
5	11.04	12.69	52.16	2.26	14.26	10.17	1.43	70923.85
6	7.98	12.83	54.51	2.22	13.92	10.48	1.43	70531.48
7	3.82	11.66	49.05	2.40	13.98	10.36	1.43	70568.39
8	10.31	12.21	51.57	2.68	13.43	10.62	1.43	70265.99
9	8.81	11.95	52.91	2.11	13.90	10.39	1.44	71726.70
10	9.52	12.37	57.33	2.45	13.34	10.72	1.44	71743.33
11	10.11	11.81	55.23	2.12	14.09	10.59	1.43	72112.40
12	8.57	11.81	56.79	1.86	14.73	10.60	1.44	71786.06
13	8.66	11.75	59.29	2.17	15.51	10.52	1.44	73013.48
14	9.98	11.89	56.57	2.51	15.59	10.62	1.45	72397.55
15	9.25	11.92	54.63	2.74	14.72	10.70	1.46	71602.37
16	9.49	12.18	49.82	2.75	15.46	10.00	1.44	76122.12
17	7.05	11.78	56.75	2.57	15.50	10.41	1.43	71109.77
18	9.68	11.71	54.43	2.36	16.74	10.06	1.45	75657.54
19	8.87	11.31	51.20	2.37	15.79	10.00	1.45	72179.06
20	9.99	11.28	54.08	2.60	15.20	10.08	1.45	71943.86
21	9.43	11.77	49.60	2.60	15.38	9.69	1.43	72679.47
22	9.64	12.06	46.27	2.99	15.42	9.28	1.43	71185.16
23	8.67	11.97	47.10	2.68	15.09	9.30	1.43	70933.48
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.13	12.14	53.13	2.42	14.79	10.28	1.44	71937.96
最大值	11.04	13.37	59.29	2.99	16.74	10.82	1.47	76122.12
發生時間	5	3	13	22	18	0		16
最小值	3.82	11.28	46.27	1.83	13.34	9.28	1.43	70265.99
發生時間	7	20	22	1	10	22		8
零點偏移(率)	-0.09 %	0.00 %	-0.04 %	-0.01 %		-0.13	-0.01	0.10 %
全幅偏移(率)	1.01 %	2.45 %	1.03 %	0.40 %		0.19	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								