

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年08月13日

報表日期: 115年08月13日

[illegible]

報表日期: 115年08月13日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	9.23	12.63	50.52	1.43	18.43	11.11	0.94	80488.87
1	7.69	12.70	54.96	1.56	18.64	11.11	0.94	80747.93
2	5.97	12.82	50.43	1.41	17.32	11.32	0.93	80932.21
3	8.85	12.93	50.92	1.52	17.02	11.44	0.92	79429.17
4	7.45	12.75	54.67	1.40	17.37	11.31	0.92	80227.81
5	11.01	12.93	52.24	1.34	17.28	11.40	0.93	80001.55
6	12.08	12.70	57.86	0.72	18.60	11.20	0.94	77184.03
7	7.89	12.60	59.08	1.26	17.89	11.19	0.94	80850.79
8	8.48	12.78	56.49	1.08	17.89	11.28	0.94	79354.46
9	8.64	12.92	57.27	0.93	18.38	11.25	0.94	79563.19
10	10.47	12.64	51.56	1.05	17.98	11.10	0.94	81094.34
11	9.76	12.81	48.71	1.54	16.97	11.39	0.93	79602.71
12	13.38	12.67	59.64	1.83	16.80	11.33	0.93	80580.85
13	8.27	12.41	65.28	1.05	18.19	11.01	0.94	82192.74
14	11.18	12.79	52.97	0.97	17.85	11.30	0.94	79461.39
15	9.68	13.20	48.15	1.59	17.18	11.40	0.92	79167.83
16	5.73	13.05	54.04	1.26	17.80	11.16	0.93	80802.26
17	7.65	12.53	53.08	1.13	18.54	10.98	0.94	81615.01
18	3.45	12.55	47.45	1.31	18.10	11.08	0.94	81122.09
19	6.51	12.63	55.44	0.55	18.95	11.07	0.94	80578.15
20	4.80	13.08	60.13	0.38	18.86	11.43	0.95	77485.35
21	9.57	13.12	51.91	1.67	17.79	11.32	0.94	79362.90
22	7.59	13.41	57.96	1.59	18.40	10.86	0.94	82803.60
23	10.00	12.56	61.35	0.91	18.95	10.90	0.93	82119.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.56	12.80	54.67	1.23	17.97	11.21	0.94	80282.01
最 大 值	13.38	13.41	65.28	1.83	18.95	11.44	0.97	82803.60
發生時間	12	22	13	12	19	3		22
最 小 值	3.45	12.41	47.45	0.38	16.80	10.86	0.90	77184.03
發生時間	18	13	18	20	12	22		6
零點偏移(率)	-0.11 %	-0.14 %	-0.06 %	-0.01 %		-0.01	-0.01	-0.10 %
全幅偏移(率)	0.61 %	-0.04 %	0.08 %	0.27 %		-0.09	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年08月13日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.68	11.24	45.93	2.49	18.99	9.67	1.27	72487.40
1	5.37	11.42	46.91	2.36	20.07	9.38	1.26	73253.17
2	8.81	13.24	44.65	2.72	19.82	9.10	1.27	74582.16
3	6.94	12.26	45.91	2.51	19.33	9.49	1.28	72421.40
4	10.95	12.68	43.80	3.49	20.34	8.59	1.31	77278.68
5	5.65	11.15	47.48	2.51	20.98	8.89	1.31	74790.61
6	10.90	11.70	41.57	3.17	21.19	8.23	1.31	77480.15
7	9.57	11.94	45.70	2.77	19.78	8.91	1.29	76131.46
8	10.30	11.18	57.71	2.93	19.79	9.16	1.31	74375.22
9	6.50	11.03	54.07	2.41	18.51	9.36	1.27	72722.53
10	8.60	11.01	51.08	2.42	18.49	9.50	1.30	72664.89
11	7.08	11.00	49.39	2.30	18.61	9.51	1.31	71921.02
12	4.73	11.31	49.19	2.12	19.03	9.76	1.32	70635.78
13	5.66	11.52	49.51	2.13	18.10	9.98	1.30	72116.50
14	3.45	11.78	51.19	2.20	17.59	10.20	1.30	71019.01
15	6.48	11.46	57.12	2.37	18.69	10.04	1.29	72824.19
16	6.35	11.44	51.05	2.22	16.87	10.12	1.28	72427.82
17	6.20	12.35	45.50	1.72	18.12	9.92	1.31	73986.01
18	6.42	12.65	51.60	1.60	19.11	10.06	1.31	73005.57
19	6.23	12.20	49.13	1.66	19.60	9.51	1.31	79474.38
20	3.76	13.24	55.32	1.48	19.09	10.03	1.30	76391.06
21	9.90	13.35	60.53	1.84	17.85	10.42	1.27	78695.81
22	9.83	13.18	55.59	1.74	17.60	10.70	1.28	75582.85
23	7.78	12.19	54.24	2.24	18.20	10.19	1.31	74262.52
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.34	11.94	50.17	2.31	18.99	9.61	1.29	74188.76
最 大 值	10.95	13.35	60.53	3.49	21.19	10.70	1.34	79474.38
發生時間	4	21	21	4	6	22		19
最 小 值	3.45	11.00	41.57	1.48	16.87	8.23	1.25	70635.78
發生時間	14	11	6	20	16	6		12
零點偏移(率)	-0.09 %	-0.02 %	-0.01 %	0.00 %		-0.06	-0.01	0.20 %
全幅偏移(率)	0.03 %	0.06 %	0.92 %	0.09 %		0.06	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								