

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月05日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	2.94	10.89	67.07	2.99	14.31	12.39	1.25	67304.24
1	7.30	10.12	58.89	2.88	15.79	11.68	1.25	71441.17
2	5.27	10.54	56.13	3.01	15.15	12.22	1.26	67684.24
3	10.11	10.52	40.09	3.82	13.79	11.72	1.26	73014.10
4	8.67	5.06	40.40	3.43	14.10	11.74	1.27	72448.80
5	2.46	6.49	54.69	4.15	15.23	11.95	1.25	70176.27
6	2.76	6.32	50.36	4.29	15.21	11.89	1.25	70581.03
7	5.57	6.26	48.15	3.84	14.69	11.83	1.25	70951.45
8	8.66	6.30	48.06	2.72	14.85	11.91	1.25	70416.78
9	5.38	6.12	58.21	2.10	15.62	11.61	1.25	71807.11
10	7.58	6.01	56.66	2.76	14.00	11.76	1.25	70669.97
11	9.01	6.12	58.90	2.36	15.67	11.61	1.25	72314.11
12	6.96	6.47	58.37	2.39	14.98	12.26	1.24	67260.31
13	8.52	6.25	56.25	2.36	15.31	11.82	1.23	71098.24
14	8.67	6.48	57.72	2.97	13.74	12.22	1.24	69735.72
15	2.16	6.89	54.42	3.08	12.74	12.97	1.22	65885.34
16	8.26	6.02	53.63	2.94	13.73	11.94	1.23	71520.03
17	8.46	7.25	51.54	3.11	13.35	12.30	1.23	68272.34
18	9.90	7.47	55.30	2.93	14.21	11.91	1.24	71688.45
19	6.79	6.36	59.63	1.93	16.08	11.73	1.23	70939.16
20	9.26	6.35	56.23	2.40	14.94	11.87	1.23	70753.70
21	8.43	6.61	54.63	2.19	15.38	12.16	1.23	68236.99
22	10.26	12.17	55.55	2.20	15.74	11.76	1.23	71529.70
23	8.87	14.09	58.04	2.43	14.73	11.93	1.24	70412.50
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.18	7.63	54.54	2.89	14.72	11.97	1.24	70255.91
最 大 值	10.26	14.09	67.07	4.29	16.08	12.97	1.27	73014.10
發生時間	22	23	0	6	19	15		3
最 小 值	2.16	5.06	40.09	1.93	12.74	11.61	1.20	65885.34
發生時間	15	4	3	19	15	9		15
零點偏移(率)	-0.43 %	-0.00 %	-0.27 %	-0.01 %		0.00		0.00 %
全幅偏移(率)	-1.31 %	-0.74 %	0.15 %	-0.43 %		0.28		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月05日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.76	8.63	55.37	1.00	18.60	10.31	0.97	79794.33
1	0.97	9.62	57.07	1.87	18.32	11.29	0.97	72622.24
2	0.90	8.83	50.37	1.45	17.98	10.53	0.97	79887.21
3	4.74	9.43	54.92	2.05	17.13	10.58	0.97	78760.27
4	5.64	9.02	58.02	2.32	17.91	10.76	0.98	83007.60
5	9.02	9.17	55.73	2.80	16.22	10.97	0.98	82306.95
6	7.34	6.78	64.94	1.52	17.82	10.91	0.98	78164.90
7	5.48	6.73	56.15	2.55	17.30	10.94	0.99	81497.51
8	7.68	7.89	53.67	2.80	17.31	10.76	0.98	82440.47
9	5.72	6.86	58.21	2.57	16.99	10.91	0.98	82139.79
10	7.67	6.71	57.13	3.00	16.82	10.93	0.98	81483.57
11	6.48	6.81	51.58	2.71	15.63	11.26	0.97	78093.05
12	4.07	6.92	53.13	2.85	16.24	11.18	0.97	78470.93
13	8.03	6.63	47.16	3.02	16.27	10.97	0.95	81154.58
14	7.20	7.14	52.05	3.38	15.31	11.50	0.95	77798.66
15	4.25	8.46	53.37	3.82	13.99	12.10	0.96	77718.24
16	8.31	6.50	59.11	2.32	16.70	10.75	0.97	84185.08
17	9.62	6.55	60.88	2.36	17.16	10.69	0.97	83805.04
18	8.55	6.61	61.74	1.91	17.84	10.60	0.97	83956.87
19	8.88	7.32	56.47	2.39	17.93	10.51	0.97	84555.66
20	9.16	6.67	60.40	1.89	17.97	10.65	0.97	83142.66
21	9.07	6.67	50.35	2.07	17.21	10.59	0.97	84911.98
22	9.23	10.43	53.97	2.31	16.84	10.88	0.97	82441.31
23	9.00	11.45	55.65	1.92	17.30	10.82	0.97	82587.66
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.74	7.83	55.73	2.37	17.03	10.89	0.97	81038.61
最 大 值	9.62	11.45	64.94	3.82	18.60	12.10	0.99	84911.98
發生時間	17	23	6	15	0	15		21
最 小 值	0.90	6.50	47.16	1.00	13.99	10.31	0.94	72622.24
發生時間	2	16	13	0	15	0		1
零點偏移(率)	-0.12 %	-0.12 %	-0.02 %	-0.01 %		-0.08		-0.10 %
全幅偏移(率)	0.14 %	1.20 %	0.29 %	0.09 %		-0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年08月05日

[illegible]