

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月20日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.76	13.07	50.13	0.38	20.14	10.72	0.96	82241.80
1	6.20	12.65	53.21	0.38	19.68	10.68	0.97	83419.76
2	8.08	12.67	49.70	0.78	19.17	10.58	0.97	84992.82
3	8.40	12.45	63.75	1.53	18.22	10.85	0.97	83431.45
4	9.47	12.34	48.92	1.00	17.70	10.91	0.96	84085.86
5	4.17	11.92	56.18	0.69	20.39	10.18	0.95	86497.52
6	1.69	12.82	39.33	0.66	18.99	10.78	0.94	84400.34
7	6.52	12.13	60.68	1.08	20.07	10.46	0.94	84459.57
8	6.95	12.03	58.59	1.03	19.99	10.41	0.94	85522.67
9	3.77	12.64	53.01	0.99	18.48	11.13	0.94	80941.30
10	4.39	13.45	59.43	2.00	16.45	11.93	0.94	76398.64
11	8.12	12.95	45.29	2.26	17.54	10.91	0.94	83900.61
12	7.90	12.44	64.16	1.38	17.62	10.92	0.94	83443.33
13	9.37	12.54	61.51	1.54	17.14	11.25	0.94	80686.80
14	7.78	13.31	63.58	2.20	16.38	11.68	0.94	77932.07
15	8.39	12.59	42.25	1.60	17.66	11.08	0.95	81671.23
16	9.31	12.14	62.42	0.86	19.96	10.47	0.94	84797.04
17	8.71	12.23	45.28	0.86	19.24	10.60	0.94	84039.16
18	7.42	12.73	58.30	1.81	17.99	11.19	0.94	80894.97
19	3.84	12.67	56.94	1.51	18.16	11.18	0.94	81330.61
20	6.68	12.55	45.72	1.12	18.87	10.82	0.94	83171.60
21	5.82	13.09	50.95	1.28	19.34	10.59	0.94	84464.71
22	5.91	12.63	55.75	1.09	19.30	10.69	0.94	83720.98
23	7.86	12.61	54.53	0.62	19.48	10.73	0.94	83531.73
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.85	12.61	54.15	1.19	18.67	10.86	0.95	82915.69
最 大 值	9.47	13.45	64.16	2.26	20.39	11.93	0.98	86497.52
發生時間	4	10	12	11	5	10		5
最 小 值	1.69	11.92	39.33	0.38	16.38	10.18	0.92	76398.64
發生時間	6	5	6	0	14	5		10
零點偏移(率)	-0.06 %	-0.01 %	-0.05 %	-0.00 %		-0.06	-0.01	-0.10 %
全幅偏移(率)	-1.41 %	-0.03 %	0.34 %	0.62 %		-0.28	0.00	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

