

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月02日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.51	3.36	67.04	1.59	18.08	11.83	1.49	71570.37
1	4.51	3.46	59.17	1.65	18.26	11.73	1.49	72324.81
2	4.79	3.72	59.74	1.78	17.59	11.95	1.48	70835.07
3	1.10	3.95	68.63	2.01	16.49	12.54	1.52	67802.58
4	1.60	3.46	54.67	1.65	17.91	11.25	1.51	76334.94
5	3.25	4.09	61.56	2.03	17.56	11.70	1.51	77211.32
6	2.36	3.44	56.12	2.19	16.88	11.85	1.51	72312.71
7	3.70	6.26	50.45	2.10	17.71	11.51	1.51	73688.92
8	3.47	4.03	51.78	2.01	17.76	11.58	1.51	73656.08
9	7.71	4.40	45.42	2.96	15.71	12.08	1.51	71628.57
10	5.44	6.56	48.58	2.75	16.13	12.11	1.51	71007.92
11	3.63	5.89	43.52	2.32	17.19	11.57	1.47	73870.58
12	1.33	1.40	49.29	2.18	16.77	12.10	1.49	70404.67
13	0.37	1.41	49.48	2.00	16.99	11.85	1.51	71760.03
14	0.16	1.25	55.93	1.83	17.36	12.00	1.47	70994.52
15	0.08	1.76	56.54	1.89	17.14	11.56	1.46	74451.28
16	0.11	3.98	60.09	1.83	17.75	12.10	1.49	69984.43
17	0.15	5.01	53.86	1.64	18.32	11.69	1.52	72732.68
18	1.61	9.29	46.43	2.48	16.03	12.08	1.48	71695.00
19	6.31	1.81	57.45	2.36	16.78	11.95	1.46	72290.53
20	10.26	2.93	54.46	2.91	15.71	12.08	1.47	72113.33
21	9.82	1.84	53.29	3.03	15.36	12.11	1.50	72563.47
22	11.00	3.20	52.97	2.61	16.18	11.98	1.51	72561.22
23	11.24	4.11	54.12	2.57	16.59	11.88	1.51	72992.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.10	3.78	54.61	2.18	17.01	11.88	1.49	72366.16
最大值	11.24	9.29	68.63	3.03	18.32	12.54	1.59	77211.32
發生時間	23	18	3	21	17	3		5
最小值	0.08	1.25	43.52	1.59	15.36	11.25	1.45	67802.58
發生時間	15	14	11	0	21	4		3
零點偏移(率)	-0.01 %	-0.04 %	-0.02 %	-0.00 %		-0.02	0.00	0.00 %
全幅偏移(率)	0.03 %	0.29 %	-0.36 %	0.00 %		0.09	0.00	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月02日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.65	4.37	52.67	0.86	19.59	10.40	1.52	84053.11
1	2.56	4.04	52.70	0.66	21.11	9.99	1.52	86105.30
2	2.01	4.21	50.09	1.39	17.72	10.71	1.51	83253.77
3	1.78	3.91	60.68	1.24	18.81	10.59	1.51	83477.78
4	3.30	6.49	48.20	1.56	19.16	9.93	1.51	87202.91
5	1.22	2.75	44.74	1.17	18.68	10.10	1.50	85392.78
6	3.22	5.28	47.81	1.71	17.74	10.33	1.51	85727.17
7	6.46	7.35	43.55	2.14	18.02	10.35	1.51	83461.61
8	5.96	7.14	48.10	2.39	16.24	10.91	1.50	79314.89
9	7.94	2.65	50.90	2.32	17.18	10.74	1.50	82660.30
10	8.53	1.96	51.72	2.73	16.40	10.97	1.47	80120.94
11	6.06	1.44	60.35	2.00	16.93	10.85	1.48	80373.94
12	1.98	1.80	45.49	1.87	16.49	10.61	1.51	80879.50
13	4.91	2.02	52.79	2.45	16.37	10.59	1.50	81116.63
14	5.79	1.35	52.38	2.05	17.39	10.57	1.46	82236.82
15	6.69	1.59	53.68	1.79	18.71	10.44	1.46	82977.18
16	8.82	5.82	44.63	2.46	16.72	10.63	1.47	82418.78
17	10.64	3.73	55.00	2.76	16.54	10.66	1.51	81683.34
18	9.13	3.38	58.06	2.14	18.73	10.19	1.51	84775.58
19	9.15	3.01	62.27	1.87	20.39	9.74	1.49	88114.03
20	6.75	2.99	46.96	1.67	19.20	10.26	1.46	86125.02
21	8.71	2.98	55.07	1.70	19.35	10.34	1.47	85000.86
22	8.48	3.64	52.39	1.76	19.07	10.12	1.49	86887.27
23	8.84	3.47	46.35	1.79	19.27	10.33	1.50	85145.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.86	3.64	51.52	1.85	18.16	10.43	1.49	83687.70
最大值	10.64	7.35	62.27	2.76	21.11	10.97	1.54	88114.03
發生時間	17	7	19	17	1	10		19
最小值	1.22	1.35	43.55	0.66	16.24	9.74	1.46	79314.89
發生時間	5	14	7	1	8	19		8
零點偏移(率)	0.00 %	-0.00 %	-0.02 %	0.00 %		-0.09	0.00	0.00 %
全幅偏移(率)	1.04 %	0.40 %	-0.59 %	0.02 %		-0.11	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月02日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.20	7.46	58.94	1.14	18.86	10.43	1.43	89686.93
1	4.44	3.78	54.00	1.19	18.95	10.48	1.43	89852.87
2	8.86	6.63	59.27	1.82	18.08	10.66	1.43	89397.16
3	9.20	2.36	57.75	1.70	18.82	10.44	1.43	91335.40
4	5.67	8.81	48.95	3.85	17.87	10.44	1.43	90966.87
5	3.12	7.00	48.42	1.47	17.54	10.52	1.43	88652.31
6	7.32	2.72	53.62	1.69	18.60	10.34	1.43	88614.78
7	2.77	8.58	50.55	1.29	19.07	10.08	1.41	92711.77
8	2.63	8.06	47.26	1.36	16.26	10.89	1.39	81675.79
9	3.17	7.17	47.06	1.51	16.47	10.63	1.38	81686.92
10	6.29	4.94	48.50	1.98	16.63	10.50	1.40	82378.54
11	4.70	2.69	50.42	1.51	18.12	10.26	1.43	85948.26
12	1.83	2.38	55.05	1.37	17.69	10.47	1.42	84151.58
13	3.12	2.08	51.15	1.44	16.92	10.66	1.42	83176.74
14	8.15	2.35	50.66	2.06	16.79	10.34	1.42	85273.99
15	5.25	2.05	61.72	1.68	17.80	10.71	1.41	80800.10
16	3.00	5.75	59.73	1.46	17.98	10.85	1.42	81194.84
17	7.51	5.42	61.57	1.92	17.26	10.54	1.43	86543.64
18	8.63	8.20	47.48	2.10	15.97	10.65	1.41	82350.07
19	7.09	2.52	52.18	1.85	17.32	10.54	1.42	83182.45
20	8.55	2.68	56.63	1.84	19.00	10.19	1.43	88794.35
21	10.84	2.79	52.50	1.81	17.56	10.54	1.42	85868.82
22	7.62	5.53	57.68	1.75	18.39	10.34	1.41	84418.58
23	6.05	5.04	54.29	1.52	17.79	10.46	1.39	84272.15
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.79	4.87	53.56	1.72	17.74	10.50	1.42	85955.62
最大值	10.84	8.81	61.72	3.85	19.07	10.89	1.44	92711.77
發生時間	21	4	15	4	7	8		7
最小值	1.83	2.05	47.06	1.14	15.97	10.08	1.38	80800.10
發生時間	12	15	9	0	18	7		15
零點偏移(率)	0.00 %	-0.05 %	-0.01 %	-0.01 %		-0.01	0.00	0.00 %
全幅偏移(率)	1.77 %	0.53 %	-0.86 %	0.30 %		0.11	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								