

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.48	6.94	60.82	0.81	19.53	11.38	1.05	73044.99
1	6.53	6.70	56.82	0.95	20.13	11.08	1.05	75114.02
2	8.96	8.04	48.31	1.12	18.49	10.92	1.05	77786.72
3	7.55	8.12	57.13	0.68	19.47	11.12	1.05	75484.58
4	4.17	5.79	58.15	0.51	19.46	11.14	1.05	75449.66
5	4.88	11.57	64.77	0.52	19.27	11.42	1.05	81035.04
6	2.43	7.61	42.72	0.88	18.80	10.82	1.05	73909.88
7	2.83	7.04	51.94	0.87	18.40	10.94	1.05	69773.96
8	1.31	7.49	49.49	0.91	17.98	11.38	1.06	64191.37
9	0.10	7.25	51.09	0.53	19.05	10.74	1.08	62265.65
10	0.15	8.48	40.59	0.87	17.46	10.41	1.08	61810.54
11	0.12	7.91	40.65	0.97	17.36	10.96	1.04	56625.92
12	6.22	7.47	46.49	1.75	16.95	10.95	1.05	66450.85
13	8.81	7.57	49.31	1.00	18.16	10.83	1.08	72761.38
14	7.46	7.70	54.56	0.90	17.63	11.19	1.09	74932.51
15	7.97	8.23	50.99	1.14	17.77	11.17	1.06	77683.35
16	8.46	8.28	49.35	1.08	17.45	11.24	1.05	76861.67
17	7.21	10.35	49.88	1.56	16.39	11.82	1.09	73193.70
18	5.13	9.29	69.82	0.88	18.50	11.48	1.10	73638.97
19	8.44	7.64	41.88	0.85	19.43	10.60	1.07	79652.76
20	9.16	7.72	59.17	1.12	18.54	10.64	1.08	79947.97
21	8.41	8.50	54.26	1.52	16.81	11.51	1.08	74673.53
22	8.98	7.93	58.21	0.84	18.18	11.20	1.08	76168.17
23	9.43	7.70	57.73	0.89	17.99	11.22	1.10	75542.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.92	7.97	52.67	0.96	18.30	11.09	1.07	72833.31
最大值	9.43	11.57	69.82	1.75	20.13	11.82	1.14	81035.04
發生時間	23	5	18	12	1	17		5
最小值	0.10	5.79	40.59	0.51	16.39	10.41	1.02	56625.92
發生時間	9	4	10	4	17	10		11
零點偏移(率)	-0.27 %	-0.05 %	-0.01 %	0.00 %		-0.15		0.00 %
全幅偏移(率)	0.02 %	0.02 %	0.40 %	0.25 %		0.02		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.38	4.18	50.62	1.69	18.43	10.07	1.02	84814.71
1	4.83	3.15	49.45	1.70	18.70	9.63	1.03	87710.75
2	8.50	5.53	49.37	1.79	18.04	9.79	1.03	87519.42
3	6.07	9.85	46.86	1.46	18.70	9.52	1.04	88707.93
4	4.60	11.05	46.44	1.21	19.14	9.23	1.03	90297.68
5	6.61	5.10	46.11	1.33	18.47	9.68	1.02	87225.76
6	0.11	7.09	55.03	1.14	18.50	9.75	0.99	94359.78
7	0.56	4.43	41.00	1.93	17.41	9.71	1.00	86309.40
8	0.74	2.34	47.84	1.97	16.99	9.87	1.03	84153.09
9	0.33	4.51	45.25	2.59	15.43	9.94	1.02	83113.24
10	5.71	4.98	57.19	3.68	14.90	10.07	0.99	85392.32
11	7.92	4.12	52.81	2.44	15.78	10.32	0.99	86522.13
12	6.87	2.19	46.13	1.65	17.00	9.98	1.00	87740.54
13	8.51	5.21	50.37	1.79	17.11	9.94	1.03	87572.64
14	6.20	6.60	59.03	2.04	15.99	10.04	1.01	87197.90
15	8.80	3.40	49.16	1.82	16.85	10.02	0.99	86719.66
16	8.64	5.05	54.75	2.73	15.58	10.26	0.97	86154.71
17	9.47	4.08	45.78	2.14	17.48	9.59	0.99	89276.45
18	8.03	3.93	46.62	1.73	17.64	9.74	1.02	88000.87
19	8.52	5.07	51.40	2.01	17.39	9.77	1.02	87897.16
20	8.94	4.73	54.11	1.92	17.38	9.91	1.02	86583.76
21	4.57	4.21	53.94	1.82	16.87	10.27	1.02	84300.35
22	6.68	3.49	60.46	1.13	18.40	9.92	1.02	85853.33
23	8.43	4.41	49.20	2.02	17.78	9.84	1.02	86470.06
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.83	4.95	50.37	1.91	17.33	9.87	1.01	87078.90
最大值	9.47	11.05	60.46	3.68	19.14	10.32	1.05	94359.78
發生時間	17	4	22	10	4	11		6
最小值	0.11	2.19	41.00	1.13	14.90	9.23	0.97	83113.24
發生時間	6	12	7	22	10	4		9
零點偏移(率)	-0.06 %	-0.03 %	-0.01 %	-0.01 %		0.03		-0.10 %
全幅偏移(率)	0.02 %	0.25 %	-0.16 %	-0.03 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 112年11月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.45	3.09	49.91	1.42	16.99	10.56	0.98	83863.29
1	5.38	3.43	53.94	1.38	16.87	10.94	0.98	80849.07
2	7.77	4.25	58.86	1.63	16.16	10.88	0.99	81412.51
3	6.39	5.33	52.64	1.55	15.77	11.12	0.98	80840.47
4	6.13	4.53	55.62	1.91	14.71	11.51	0.99	81691.42
5	7.74	5.25	53.81	1.57	15.70	11.06	0.99	81415.68
6	4.18	5.58	53.06	1.39	16.01	11.03	0.97	80981.80
7	1.10	5.20	42.38	1.11	15.17	10.92	0.97	74387.45
8	1.13	3.69	46.75	0.93	16.18	10.60	0.97	77553.31
9	0.89	5.29	43.63	1.47	14.23	10.98	0.97	74244.12
10	2.77	5.60	46.92	2.48	12.57	11.11	0.97	78080.78
11	1.20	2.30	56.47	2.41	12.82	11.62	0.97	73910.90
12	2.48	7.93	49.46	1.37	15.37	10.47	0.97	78689.92
13	1.26	6.19	52.40	1.53	14.73	10.91	0.97	77443.81
14	3.54	15.99	51.42	1.43	15.34	10.67	0.97	80441.34
15	5.21	9.68	51.95	2.23	13.77	11.08	0.96	75418.76
16	2.18	7.77	49.69	2.01	13.75	11.15	0.98	73980.31
17	4.29	8.05	61.80	1.67	14.62	11.14	0.97	74340.60
18	5.58	4.07	49.34	1.57	15.02	10.73	0.97	77103.44
19	3.16	3.60	50.18	1.55	14.96	10.74	0.96	76545.76
20	4.57	4.85	50.69	2.02	14.29	10.98	0.97	74303.61
21	8.70	4.16	51.83	1.88	14.77	10.91	0.97	75335.67
22	5.31	2.56	55.90	1.42	15.24	10.92	0.98	76982.25
23	6.36	5.26	57.71	1.46	14.79	11.29	0.97	73907.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.37	5.57	51.93	1.64	14.99	10.97	0.97	77655.15
最大值	8.70	15.99	61.80	2.48	16.99	11.62	1.00	83863.29
發生時間	21	14	17	10	0	11		0
最小值	0.89	2.30	42.38	0.93	12.57	10.47	0.94	73907.42
發生時間	9	11	7	8	10	12		23
零點偏移(率)	-0.01 %	-0.05 %	-0.09 %	-0.03 %		0.05		0.00 %
全幅偏移(率)	0.02 %	0.12 %	-0.54 %	0.27 %		0.20		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								