

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月17日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.58	8.05	69.66	0.64	18.69	11.53	1.02	81434.55
1	6.68	9.37	67.76	0.62	19.10	12.32	1.01	74553.79
2	8.63	9.38	44.58	0.36	19.80	10.96	1.00	85136.37
3	9.47	9.50	35.83	0.64	18.70	11.45	1.00	82119.90
4	10.63	10.77	42.64	0.44	19.59	11.20	0.99	82967.80
5	10.50	10.68	50.79	0.54	18.94	11.06	1.02	88393.95
6	9.51	7.92	40.48	0.95	18.07	11.21	1.02	84621.68
7	7.83	9.20	54.71	1.01	16.13	12.68	1.02	73435.60
8	9.15	9.61	54.48	0.32	18.55	11.84	1.02	79068.66
9	9.35	6.66	45.26	0.64	18.49	11.07	1.02	85265.57
10	10.32	5.79	52.68	0.81	18.07	11.33	1.04	83848.29
11	9.19	6.14	48.83	0.71	17.78	11.35	1.02	83692.36
12	7.65	6.21	51.85	0.55	18.06	11.60	1.02	81365.07
13	6.61	6.74	65.60	0.45	18.39	12.22	1.02	75556.37
14	7.03	6.72	56.07	0.41	19.19	11.50	1.02	80786.65
15	4.29	6.04	56.57	0.44	18.56	11.24	1.02	83742.11
16	5.28	5.98	59.86	0.37	19.32	10.98	1.03	84981.14
17	7.46	5.97	46.46	0.81	18.49	10.76	1.01	87916.14
18	9.03	6.12	46.08	0.76	18.24	10.94	1.03	86759.96
19	8.96	5.35	50.76	0.85	17.95	11.11	1.03	86067.27
20	8.04	5.18	52.47	0.55	17.75	11.29	1.03	84100.67
21	9.18	5.43	51.57	0.73	17.47	11.05	1.03	86393.95
22	9.25	5.49	46.35	0.65	18.40	11.01	1.02	85940.52
23	9.19	6.07	51.67	0.61	18.10	11.27	1.02	83854.82
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.45	7.27	51.79	0.62	18.41	11.37	1.02	83000.13
最大值	10.63	10.77	69.66	1.01	19.80	12.68	1.05	88393.95
發生時間	4	4	0	7	2	7		5
最小值	4.29	5.18	35.83	0.32	16.13	10.76	0.99	73435.60
發生時間	15	20	3	8	7	17		7
零點偏移(率)	-0.03 %	-0.02 %	-0.02 %	-0.01 %		-0.08		0.20 %
全幅偏移(率)	0.00 %	0.00 %	0.93 %	0.25 %		-0.11		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月17日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.67	5.60	46.45	1.41	19.08	10.75	0.99	80429.10
1	0.81	6.00	62.15	1.58	17.86	11.64	0.99	74308.02
2	5.19	5.49	57.38	1.83	17.98	10.98	0.99	79845.07
3	4.57	5.09	66.43	1.70	17.60	11.24	0.99	77590.89
4	5.92	4.99	44.05	2.14	17.33	11.08	0.98	79606.16
5	7.31	5.32	42.54	2.07	16.98	11.25	0.95	78497.67
6	6.05	5.30	52.81	1.42	18.77	11.01	0.94	78796.18
7	8.21	5.20	36.87	1.96	17.95	10.74	0.94	81851.17
8	9.10	4.61	42.06	2.41	17.22	11.10	0.96	79627.91
9	7.58	5.88	39.09	1.93	18.02	10.54	0.99	82120.21
10	7.08	1.84	49.09	2.02	17.49	10.81	1.00	80986.02
11	6.74	3.56	51.23	1.86	17.52	10.96	0.98	79722.20
12	7.03	3.45	53.94	1.64	17.79	10.82	0.97	80331.03
13	停機	停機	停機	停機	停機	停機	停機	停機
14	3.89	1.24	41.06	1.72	16.55	11.79	0.96	74791.75
15	1.27	4.08	46.71	1.79	17.35	11.17	0.97	78365.95
16	0.14	3.94	46.96	0.89	19.34	10.47	0.98	81781.43
17	0.93	6.02	44.96	1.44	18.76	10.39	0.98	83456.60
18	6.76	3.20	56.21	2.56	17.13	10.93	0.98	81547.63
19	3.42	3.77	60.67	1.56	17.62	11.36	0.99	77481.77
20	3.78	3.92	50.42	1.82	17.54	10.78	0.99	82278.98
21	1.69	4.00	56.77	1.38	17.47	11.75	1.00	74679.88
22	0.75	3.46	46.63	1.33	17.02	11.59	1.00	75840.05
23	2.57	6.50	46.54	2.40	16.44	11.64	1.00	75884.78
監測時數	23	23	23	23	23	23	23	23
超限次數	0	0	0	0	0	0	0	0
有效時數	23	23	23	23	23	23	23	23
平均值	4.67	4.45	49.61	1.78	17.69	11.08	0.98	79122.63
最大值	9.10	6.50	66.43	2.56	19.34	11.79	1.00	83456.60
發生時間	8	23	3	18	16	14		17
最小值	0.14	1.24	36.87	0.89	16.44	10.39	0.94	74308.02
發生時間	16	14	7	16	23	17		1
零點偏移(率)	-0.09 %	-0.06 %	-0.03 %	-0.01 %		-0.04		-0.10 %
全幅偏移(率)	0.07 %	1.01 %	-0.60 %	0.30 %		-0.16		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 113年04月17日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.76	4.42	58.98	0.31	18.30	11.03	1.00	76610.85
1	1.17	5.08	53.90	0.31	18.94	10.46	1.02	80285.65
2	7.22	5.16	50.99	0.41	17.73	10.68	1.00	80102.33
3	9.97	5.02	52.40	0.97	17.53	10.58	0.99	81698.28
4	8.13	4.71	53.76	0.76	17.04	10.75	0.99	80124.77
5	6.22	5.08	51.65	0.52	17.70	10.43	0.99	81955.94
6	4.10	6.75	48.87	0.41	16.72	10.74	0.99	80798.99
7	4.65	8.40	44.05	0.40	17.11	10.62	0.98	78242.44
8	3.53	7.33	54.88	0.29	18.35	10.70	0.99	79558.64
9	4.30	5.44	47.72	0.46	18.70	10.06	0.98	82794.33
10	5.26	4.18	45.46	0.54	16.24	10.70	0.99	76328.12
11	1.42	8.66	41.13	0.43	15.86	10.84	1.02	74767.25
12	4.30	5.71	50.92	0.55	16.32	11.19	1.02	73559.39
13	2.53	4.32	54.90	0.19	18.10	10.77	1.02	77217.78
14	1.19	4.63	52.00	0.25	17.94	10.70	1.03	79783.57
15	1.19	4.25	52.08	0.20	18.47	10.60	1.03	80039.51
16	1.43	4.49	47.03	0.20	18.48	10.05	1.03	84591.98
17	2.87	4.74	41.67	0.53	16.36	10.56	1.01	81270.55
18	2.14	4.82	45.09	0.39	16.21	10.84	0.98	78577.02
19	4.01	8.54	46.22	0.81	15.50	10.97	0.96	78487.17
20	6.96	5.22	48.75	0.46	17.59	10.56	0.97	80313.80
21	1.43	2.55	52.50	0.17	18.43	11.33	0.99	75102.12
22	3.78	4.51	41.61	0.36	19.56	9.50	0.97	87534.79
23	3.62	2.80	58.51	0.38	17.35	10.73	0.97	80017.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	3.97	5.28	49.79	0.43	17.52	10.64	1.00	79573.44
最大值	9.97	8.66	58.98	0.97	19.56	11.33	1.05	87534.79
發生時間	3	11	0	3	22	21		22
最小值	1.17	2.55	41.13	0.17	15.50	9.50	0.95	73559.39
發生時間	1	21	11	21	19	22		12
零點偏移(率)	-0.14 %	-0.09 %	-0.05 %	-0.01 %		-0.11		0.00 %
全幅偏移(率)	0.02 %	0.06 %	-0.27 %	0.66 %		-0.20		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								