

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月21日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.88	3.13	53.47	1.20	18.38	11.31	1.41	78004.82
1	9.99	5.69	57.07	0.99	19.23	11.47	1.42	75651.28
2	9.75	1.74	52.12	1.13	18.81	11.39	1.42	77354.60
3	10.37	4.28	55.11	1.07	18.60	11.05	1.42	78697.03
4	11.50	9.64	51.34	1.53	17.28	11.71	1.42	75127.90
5	2.77	2.25	60.47	0.70	19.20	11.16	1.40	76876.22
6	10.09	2.36	51.77	0.96	18.92	11.28	1.38	78346.47
7	8.44	1.28	65.22	0.69	19.59	11.46	1.38	76030.45
8	8.07	1.53	59.14	0.58	19.58	11.37	1.38	76088.42
9	10.62	1.44	50.84	0.78	18.99	11.34	1.38	77426.75
10	9.69	5.54	53.32	0.99	18.08	11.64	1.40	75388.19
11	9.57	4.45	61.10	1.06	17.89	12.18	1.39	71271.64
12	10.15	2.82	58.37	0.80	19.26	11.34	1.39	76730.93
13	10.22	2.53	58.98	0.73	19.45	11.18	1.38	77080.03
14	11.23	4.26	65.93	0.98	18.35	11.73	1.41	74442.91
15	11.05	16.04	55.27	1.38	17.37	11.86	1.42	74074.36
16	11.16	6.41	49.66	1.29	17.88	11.49	1.42	76272.15
17	7.71	1.60	67.64	0.66	19.52	11.20	1.43	77464.55
18	7.88	3.63	52.26	0.67	18.66	11.06	1.41	78814.18
19	5.98	1.54	55.77	0.78	18.37	11.49	1.42	76288.97
20	7.20	2.37	52.64	0.51	19.90	10.90	1.41	79593.96
21	4.07	1.03	62.68	0.38	20.36	11.00	1.41	78400.25
22	2.96	4.25	44.56	0.52	19.91	11.46	1.39	74995.69
23	10.58	5.99	56.11	0.59	19.86	11.05	1.36	77800.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.79	3.99	56.29	0.87	18.89	11.38	1.40	76592.59
最大值	11.50	16.04	67.64	1.53	20.36	12.18	1.51	79593.96
發生時間	4	15	17	4	21	11		20
最小值	2.77	1.03	44.56	0.38	17.28	10.90	1.35	71271.64
發生時間	5	21	22	21	4	20		11
零點偏移(率)	-0.04 %	-0.02 %	-0.02 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	-0.67 %	0.53 %	-0.14 %	0.12 %		0.04	-0.03	0.40 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月21日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.89	2.71	63.28	1.57	18.35	10.37	1.42	67501.96
1	10.04	3.35	69.74	1.60	18.68	10.69	1.41	65560.27
2	10.05	3.35	67.43	2.22	17.01	10.50	1.41	67292.46
3	10.48	3.35	64.15	1.89	18.68	10.27	1.41	67324.76
4	10.72	1.26	57.70	2.27	16.86	10.64	1.42	66462.99
5	11.16	6.56	60.06	2.48	17.00	10.44	1.45	66355.47
6	7.35	5.57	59.09	2.26	17.24	10.68	1.46	61458.31
7	10.06	1.22	63.83	2.04	17.32	10.50	1.46	65666.59
8	10.69	1.44	55.79	2.27	16.21	10.84	1.46	64747.30
9	8.07	10.20	59.83	2.61	15.55	11.07	1.47	62940.36
10	9.59	10.62	64.98	2.51	14.74	11.05	1.46	63375.49
11	11.14	1.21	69.11	2.54	15.87	10.90	1.46	62421.90
12	21.04	7.24	58.15	3.63	13.97	11.41	1.46	62748.61
13	9.38	3.52	60.81	3.26	14.17	11.76	1.45	63216.68
14	10.73	9.89	59.99	3.45	14.75	11.17	1.40	63952.03
15	12.12	2.87	65.90	3.59	14.45	11.41	1.39	62948.75
16	10.85	3.50	59.67	2.68	14.80	11.14	1.38	63463.65
17	10.21	1.84	56.22	2.09	16.54	10.75	1.40	65192.49
18	8.63	7.21	53.09	2.45	15.59	10.89	1.40	63493.06
19	10.00	1.29	56.46	1.99	17.43	10.50	1.42	66695.20
20	8.24	1.32	53.21	1.68	17.99	10.59	1.44	66109.37
21	7.29	1.13	63.16	1.19	19.49	10.19	1.46	68039.24
22	10.30	3.48	57.44	1.92	18.12	9.86	1.44	67575.88
23	9.69	1.18	55.30	1.94	17.40	10.44	1.41	65770.08
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.28	3.97	60.60	2.34	16.59	10.75	1.43	65013.04
最大值	21.04	10.62	69.74	3.63	19.49	11.76	1.48	68039.24
發生時間	12	10	1	12	21	13		21
最小值	7.29	1.13	53.09	1.19	13.97	9.86	1.38	61458.31
發生時間	21	21	18	21	12	22		6
零點偏移(率)	-0.14 %	-0.04 %	-0.02 %	-0.01 %		-0.01	0.00	0.00 %
全幅偏移(率)	-0.18 %	0.03 %	0.07 %	0.03 %		0.09	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月21日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.42	5.65	65.87	2.11	16.06	10.73	1.30	87070.32
1	9.64	6.27	58.98	1.86	16.95	10.76	1.30	88356.52
2	8.94	5.62	60.42	2.14	15.43	10.80	1.30	88102.24
3	9.34	2.76	63.78	1.89	16.46	10.49	1.30	89868.57
4	7.43	7.89	65.02	2.06	15.75	10.88	1.30	87653.91
5	11.57	6.01	64.67	2.98	13.81	11.51	1.30	84213.38
6	10.26	4.96	59.62	2.58	15.10	10.95	1.30	86296.41
7	8.61	6.78	67.51	2.17	15.19	10.81	1.27	85337.48
8	12.20	11.58	59.61	2.30	15.14	10.81	1.25	87952.15
9	7.41	6.20	65.55	2.48	14.46	11.09	1.25	83174.45
10	7.97	9.59	59.70	2.69	13.96	11.09	1.25	81152.64
11	9.67	2.04	65.86	3.10	14.03	11.31	1.24	81155.53
12	14.16	16.50	56.88	2.51	13.60	11.37	1.25	80896.97
13	9.35	13.61	58.03	0.94	14.43	11.38	1.25	80132.66
14	11.62	18.30	59.24	1.30	14.81	11.57	1.25	75124.58
15	8.16	32.08	53.03	0.83	14.51	11.42	1.25	77395.25
16	5.95	1.84	51.94	0.35	15.23	11.97	1.25	76379.10
17	3.87	12.04	58.74	0.67	15.95	11.96	1.25	78978.02
18	6.02	12.08	43.57	1.77	14.50	10.89	1.25	84931.33
19	6.46	1.97	70.07	1.89	16.10	11.15	1.26	85135.04
20	5.31	6.50	35.82	1.44	18.12	10.30	1.25	92126.44
21	6.60	2.72	60.34	1.41	16.77	10.89	1.24	88413.06
22	6.54	6.68	57.26	1.83	16.72	10.27	1.25	90513.82
23	9.15	3.31	58.62	2.35	14.67	10.87	1.27	87183.49
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.53	8.46	59.17	1.90	15.32	11.05	1.27	84480.97
最大值	14.16	32.08	70.07	3.10	18.12	11.97	1.32	92126.44
發生時間	12	15	19	11	20	16		20
最小值	3.87	1.84	35.82	0.35	13.60	10.27	1.23	75124.58
發生時間	17	16	20	16	12	22		14
零點偏移(率)	-0.01 %	-0.03 %	-0.00 %	0.00 %		0.01	0.00	0.00 %
全幅偏移(率)	0.04 %	0.01 %	-0.17 %	-0.05 %		0.44	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								