

P001_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月07日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.13	10.73	52.48	1.92	20.84	10.00	1.22	87731.51
1	8.55	11.12	53.33	2.63	20.45	10.30	1.22	86081.62
2	8.94	11.14	46.50	3.60	19.59	10.63	1.21	84710.29
3	6.93	11.78	60.56	3.48	17.85	11.37	1.20	80091.35
4	1.50	13.53	67.36	3.07	16.72	12.50	1.21	71400.64
5	2.21	12.39	52.87	2.25	19.18	10.58	1.21	73431.30
6	8.51	12.04	51.88	3.51	19.14	10.44	1.20	86504.45
7	3.55	13.32	56.75	3.64	16.97	11.47	1.22	79967.56
8	7.02	14.03	43.00	1.81	17.88	12.17	1.24	73158.80
9	9.72	13.26	31.58	2.34	17.43	11.42	1.19	79644.55
10	10.95	12.23	27.40	2.54	18.11	10.62	1.19	85530.16
11	6.82	12.78	28.90	1.12	19.75	10.51	1.22	85474.40
12	11.68	12.56	27.35	2.12	18.18	10.77	1.20	84255.80
13	7.93	12.73	49.54	2.14	17.86	11.14	1.21	81914.42
14	8.28	14.85	62.18	2.70	15.40	12.75	1.18	71222.98
15	9.13	14.05	47.10	2.10	17.13	12.18	1.18	74325.21
16	11.34	12.55	53.02	3.10	18.21	10.91	1.22	83863.64
17	9.06	13.11	53.10	2.98	17.34	11.20	1.21	81749.88
18	9.33	13.01	57.75	2.31	17.63	11.31	1.20	80717.30
19	10.95	13.24	56.53	2.55	16.77	11.37	1.19	81012.85
20	11.41	13.62	54.35	3.38	17.54	11.09	1.18	82561.74
21	11.57	13.28	52.27	3.43	16.58	11.45	1.19	81014.90
22	8.58	12.80	54.78	1.89	17.79	11.00	1.19	83449.26
23	7.27	12.88	47.75	3.44	17.46	10.90	1.18	82490.40
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.31	12.79	49.51	2.67	17.99	11.17	1.20	80929.38
最大值	11.68	14.85	67.36	3.64	20.84	12.75	1.28	87731.51
發生時間	12	14	4	7	0	14		0
最小值	1.50	10.73	27.35	1.12	15.40	10.00	1.16	71222.98
發生時間	4	0	12	11	14	0		14
零點偏移(率)	-0.05 %	-0.11 %	-0.03 %	-0.00 %		0.00	-0.01	0.10 %
全幅偏移(率)	-0.60 %	-2.18 %	0.29 %	-0.23 %		-0.15	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月07日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	0.77	12.52	51.77	0.59	20.96	10.49	0.99	82004.93
1	0.68	12.21	58.83	0.96	20.52	10.48	0.99	82415.11
2	0.53	12.33	54.80	1.67	18.91	10.78	0.99	82227.45
3	0.62	13.13	57.11	1.53	18.71	10.83	0.99	82481.94
4	0.56	12.15	58.92	1.28	19.25	10.60	0.99	83579.29
5	0.53	12.21	51.94	1.03	19.51	10.63	0.99	83178.54
6	0.92	16.29	55.97	2.01	18.17	10.73	0.97	83456.38
7	0.92	11.99	57.44	1.70	18.48	10.72	0.98	83788.37
8	0.90	11.17	52.86	1.39	18.93	10.57	1.01	84498.07
9	0.37	12.40	55.26	2.32	17.37	11.81	1.00	74030.16
10	0.41	11.12	50.25	1.28	18.88	10.63	0.99	83929.45
11	1.02	11.29	57.34	1.20	18.88	10.77	0.99	82503.28
12	1.05	11.24	72.45	1.11	18.86	10.75	1.01	82466.16
13	0.51	11.02	62.59	0.96	19.16	10.68	0.99	82370.03
14	0.79	12.27	62.65	2.04	17.05	11.93	0.99	74623.79
15	0.90	11.84	60.08	1.92	17.63	11.57	0.92	75444.83
16	1.19	12.07	45.25	1.23	19.63	10.19	0.92	86748.51
17	1.38	11.90	55.57	0.99	18.97	10.37	0.94	85642.31
18	1.25	12.16	52.44	1.40	18.56	10.45	0.95	85495.51
19	1.13	12.84	57.57	0.47	20.02	10.99	0.98	79791.51
20	1.07	12.43	47.30	0.89	18.77	10.40	0.98	85871.42
21	1.21	11.99	48.83	1.05	18.78	10.29	0.97	86480.03
22	2.20	12.08	46.05	1.49	17.30	10.72	0.98	81820.60
23	2.82	12.16	50.30	1.35	17.76	10.75	0.97	81636.19
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	0.99	12.20	55.15	1.33	18.79	10.76	0.98	82353.49
最大值	2.82	16.29	72.45	2.32	20.96	11.93	1.02	86748.51
發生時間	23	6	12	9	0	14		16
最小值	0.37	11.02	45.25	0.47	17.05	10.19	0.91	74030.16
發生時間	9	13	16	19	14	16		9
零點偏移(率)	-0.06 %	-0.09 %	-0.05 %	-0.00 %		0.00	-0.01	-0.20 %
全幅偏移(率)	1.23 %	-1.81 %	-0.04 %	-1.23 %		0.22	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003_樹林焚化廠CEMS系統日報表-A

報表日期: 115年06月07日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.80	11.61	58.69	2.80	19.48	9.69	1.41	73622.71
1	3.72	11.25	53.72	2.56	20.46	9.49	1.42	78183.18
2	5.53	11.46	56.33	2.73	20.19	9.72	1.42	77177.08
3	4.05	11.35	56.12	2.71	19.10	9.83	1.42	76642.43
4	5.03	11.23	58.34	2.88	19.18	9.73	1.42	74632.28
5	3.21	11.36	56.47	2.69	20.09	9.71	1.41	74372.76
6	3.95	11.33	49.84	2.59	20.33	9.39	1.42	76512.97
7	3.39	14.16	51.46	2.53	21.43	9.35	1.37	78313.57
8	4.04	14.62	52.03	2.74	18.88	9.37	1.37	76636.66
9	2.41	15.65	60.40	3.00	17.26	10.69	1.37	66600.16
10	4.07	13.97	49.56	2.70	19.55	9.29	1.32	76580.53
11	4.90	14.26	50.51	2.82	19.41	9.41	1.34	75455.86
12	4.19	14.20	58.09	2.59	20.81	9.29	1.36	78890.26
13	4.62	14.22	47.00	2.53	18.91	9.55	1.38	74473.90
14	3.28	15.49	56.43	2.66	18.21	10.48	1.34	69403.76
15	2.64	15.36	59.27	2.72	17.91	10.56	1.31	69113.99
16	5.33	12.82	51.96	2.91	20.05	9.21	1.33	76896.57
17	5.15	11.86	49.29	2.78	20.77	8.96	1.38	75885.27
18	5.00	12.09	48.81	2.87	20.98	8.98	1.37	74114.38
19	4.96	12.95	52.38	3.04	19.10	9.81	1.35	71663.12
20	4.08	13.50	47.00	2.74	20.59	9.79	1.36	71168.74
21	8.82	12.48	48.60	3.76	20.26	8.64	1.39	79085.58
22	10.02	12.49	42.62	2.85	18.65	9.16	1.39	77216.90
23	9.92	12.55	42.27	2.87	18.79	9.15	1.39	75568.30
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.88	13.01	52.38	2.79	19.60	9.55	1.38	74925.46
最大值	10.02	15.65	60.40	3.76	21.43	10.69	1.43	79085.58
發生時間	22	9	9	21	7	9		21
最小值	2.41	11.23	42.27	2.53	17.26	8.64	1.27	66600.16
發生時間	9	4	23	7	9	21		9
零點偏移(率)	-0.05 %	0.01 %	-0.07 %	0.00 %		-0.04	-0.01	-0.10 %
全幅偏移(率)	0.88 %	0.09 %	1.68 %	0.32 %		0.31	0.04	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								