

報表日期: 115年09月01日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.49	12.14	60.15	0.46	19.52	10.44	0.91	85120.18
1	1.20	13.05	46.09	0.75	20.11	11.22	0.91	78329.74
2	1.23	12.51	45.04	0.70	20.89	10.16	0.92	86192.36
3	1.07	12.25	50.82	0.57	20.46	10.39	0.92	84767.87
4	0.91	12.50	48.18	1.28	18.29	10.99	0.92	81686.38
5	0.86	12.74	47.46	1.95	17.55	11.09	0.92	82081.03
6	2.16	13.73	46.69	1.84	17.66	11.03	0.94	81021.13
7	1.55	13.91	47.47	1.30	19.09	10.77	0.94	83528.07
8	2.17	13.58	51.57	0.91	19.98	10.45	0.94	84932.52
9	1.02	14.60	59.10	0.87	18.75	11.53	0.94	77700.72
10	1.24	13.51	49.81	0.89	19.78	10.48	0.94	84865.83
11	7.52	13.72	63.61	1.91	17.58	10.83	0.94	84425.21
12	6.25	13.44	58.08	1.63	18.01	10.84	0.94	83441.16
13	7.55	13.73	59.72	1.78	17.51	10.85	0.94	83434.97
14	1.48	13.55	52.03	1.21	18.48	10.85	0.94	83251.19
15	2.03	12.68	54.17	1.10	18.19	10.82	0.94	79096.73
16	1.85	12.63	54.43	1.92	16.45	11.31	0.94	81711.15
17	6.84	12.21	51.51	1.57	16.89	11.00	0.94	83801.25
18	7.20	12.34	48.09	1.19	18.50	10.52	0.94	85887.00
19	3.15	12.65	46.09	1.03	19.04	10.53	0.93	84995.31
20	5.08	11.95	53.64	1.39	18.04	10.42	0.94	86333.74
21	4.34	12.23	46.67	1.16	18.46	10.81	0.94	83591.74
22	3.45	12.49	45.57	1.85	17.45	11.12	0.94	82170.61
23	4.67	13.37	58.87	0.90	18.10	11.72	0.94	77143.89
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	3.18	12.98	51.87	1.26	18.53	10.84	0.93	82896.24
最 大 值	7.55	14.60	63.61	1.95	20.89	11.72	0.95	86333.74
發生時間	13	9	11	5	2	23		20
最 小 值	0.86	11.95	45.04	0.46	16.45	10.16	0.90	77143.89
發生時間	5	20	2	0	16	2		23
零點偏移(率)	-0.14 %	-0.00 %	-0.08 %	-0.01 %		-0.05	-0.01	-0.10 %
全幅偏移(率)	0.57 %	-0.22 %	0.30 %	-0.38 %		-0.06	-0.06	0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年09月01日

[illegible]