

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月17日

報表日期: 114年07月17日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	5.34	7.75	58.27	2.24	17.85	11.56	1.25	79734.79
1	6.36	8.17	53.71	3.48	18.49	11.18	1.26	82467.81
2	6.97	8.77	48.55	3.65	16.70	11.56	1.26	81147.46
3	2.34	7.83	46.49	2.93	16.52	11.62	1.26	80791.43
4	3.20	8.00	48.41	2.92	16.30	11.68	1.25	79865.78
5	6.19	9.17	48.08	2.30	15.00	12.06	1.28	78880.52
6	5.48	9.99	56.26	2.30	17.17	11.59	1.28	80236.86
7	5.28	9.28	54.51	3.77	15.09	11.76	1.27	79626.90
8	0.50	9.29	62.66	1.84	16.60	12.03	1.29	76135.01
9	3.07	9.27	46.98	3.35	15.50	11.82	1.28	78537.29
10	0.83	10.13	45.32	2.30	15.39	11.91	1.27	73248.38
11	6.81	9.09	55.17	3.44	15.97	11.59	1.27	78436.42
12	4.30	9.95	46.66	2.72	16.15	11.99	1.27	71428.81
13	1.48	9.51	52.62	1.87	16.37	12.11	1.27	75095.61
14	1.24	9.52	54.29	1.60	16.48	12.15	1.28	75883.38
15	3.51	9.31	62.07	1.37	17.21	11.95	1.28	76966.44
16	9.09	9.18	58.30	2.04	17.31	11.65	1.28	79356.37
17	7.42	9.39	64.68	2.05	16.90	11.94	1.29	76684.98
18	7.14	9.16	45.03	2.15	17.03	11.65	1.29	79476.38
19	4.24	9.27	49.65	1.83	16.73	11.65	1.26	79749.89
20	2.93	9.51	57.05	1.46	17.32	11.78	1.26	78022.28
21	6.90	9.66	61.96	1.89	17.77	11.00	1.26	84503.95
22	9.20	9.07	58.61	2.27	17.39	11.47	1.26	80667.19
23	8.37	9.76	59.99	2.17	17.10	11.90	1.28	77656.00
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	4.92	9.17	53.97	2.41	16.68	11.73	1.27	78525.00
最 大 值	9.20	10.13	64.68	3.77	18.49	12.15	1.29	84503.95
發生時間	22	10	17	7	1	14		21
最 小 值	0.50	7.75	45.03	1.37	15.00	11.00	1.25	71428.81
發生時間	8	0	18	15	5	21		12
零點偏移(率)	-0.08 %	-0.00 %	-0.00 %	-0.01 %		-0.11		0.10 %
全幅偏移(率)	0.00 %	-0.02 %	0.57 %	-0.61 %		-0.29		0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

報表日期: 114年07月17日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	8.73	8.54	56.40	3.03	16.54	11.21	0.98	80062.43
1	8.73	8.45	59.26	2.75	17.48	11.19	0.98	80423.61
2	8.59	8.88	60.01	2.84	16.75	11.12	0.98	81103.23
3	10.16	7.93	59.93	3.13	15.93	11.28	0.99	81619.51
4	8.55	7.87	59.31	3.29	16.72	11.10	0.99	81410.41
5	9.03	7.71	57.95	2.72	17.13	10.95	0.99	82565.29
6	10.04	8.30	59.21	1.81	16.15	11.47	1.00	79257.27
7	9.16	8.49	62.70	2.92	16.51	11.22	1.02	80997.45
8	9.29	7.97	61.33	2.74	17.79	10.83	1.02	82243.10
9	8.33	7.83	59.79	2.76	17.34	10.77	1.02	83012.91
10	8.95	8.15	54.67	2.33	18.38	10.35	1.02	82880.82
11	7.17	7.80	62.30	2.07	18.65	10.61	1.01	80145.21
12	9.34	7.29	57.00	1.93	19.29	9.96	1.01	83207.86
13	10.49	9.01	47.32	2.46	17.75	10.44	1.01	81034.22
14	7.54	8.01	51.39	1.54	18.93	10.35	1.00	80759.02
15	8.55	8.59	53.83	1.53	19.48	10.09	1.01	83177.64
16	6.92	9.29	48.75	1.57	19.34	9.92	1.01	84551.27
17	8.75	10.08	46.63	2.12	18.61	10.17	1.00	82156.48
18	9.66	8.86	48.19	1.96	17.99	10.43	1.02	82544.54
19	9.13	9.00	50.99	1.89	18.43	10.26	1.00	82825.94
20	8.26	11.32	56.40	1.75	17.87	10.59	1.02	81267.13
21	10.36	11.81	49.00	1.89	18.37	10.02	1.02	82160.51
22	7.07	10.03	44.78	2.24	17.11	10.40	1.02	79654.59
23	9.78	10.74	57.87	2.01	17.92	10.47	1.02	83263.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.86	8.83	55.21	2.30	17.77	10.63	1.01	81763.50
最 大 值	10.49	11.81	62.70	3.29	19.48	11.47	1.04	84551.27
發生時間	13	21	7	4	15	6		16
最 小 值	6.92	7.29	44.78	1.53	15.93	9.92	0.97	79257.27
發生時間	16	12	22	15	3	16		6
零點偏移(率)	-0.02 %	-0.01 %	0.00 %	-0.01 %		-0.08		-0.10 %
全幅偏移(率)	0.13 %	0.14 %	0.01 %	0.14 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年07月17日

報表日期: 114年07月17日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	8.42	7.36	62.51	2.21	18.51	9.56	1.48	75119.87
1	7.02	8.83	56.86	1.91	18.77	9.66	1.47	76402.63
2	6.92	9.44	57.26	2.28	17.92	9.62	1.46	76572.30
3	7.06	7.59	61.61	2.41	17.25	9.76	1.44	74374.24
4	8.08	10.34	52.21	2.59	16.31	9.42	1.43	71070.08
5	7.67	10.96	50.65	2.20	17.22	9.21	1.43	72886.86
6	8.47	10.27	58.05	2.86	17.15	9.21	1.45	72490.43
7	1.02	8.90	52.36	1.64	15.57	10.25	1.48	70201.44
8	8.32	9.51	50.11	1.95	17.31	9.46	1.44	72416.85
9	11.06	10.78	51.40	2.27	16.51	9.42	1.48	75395.46
10	6.64	9.09	49.91	1.54	17.51	9.01	1.43	75247.60
11	10.51	9.53	54.60	2.68	17.01	9.24	1.44	73508.27
12	5.92	7.19	64.59	1.22	18.23	9.97	1.47	72683.67
13	5.31	10.55	47.41	1.23	18.60	9.55	1.48	76082.55
14	7.12	9.85	50.33	1.27	18.71	9.29	1.47	76426.50
15	5.81	8.26	55.91	1.24	19.16	9.24	1.46	75600.32
16	3.83	10.05	53.70	1.22	20.79	8.36	1.47	79999.49
17	8.04	10.50	49.58	1.62	19.15	8.66	1.46	77245.53
18	8.26	8.32	52.80	1.57	20.49	8.16	1.43	78143.33
19	7.70	9.55	51.77	1.16	18.77	8.83	1.44	77697.99
20	9.14	8.94	54.21	1.41	19.07	8.71	1.46	80306.20
21	8.89	10.70	54.54	1.45	19.97	8.83	1.48	79058.90
22	5.48	6.96	48.85	2.20	17.10	9.79	1.47	75766.04
23	9.36	6.65	51.58	1.82	18.49	8.90	1.43	76066.47
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.34	9.17	53.87	1.83	18.15	9.25	1.46	75448.46
最 大 值	11.06	10.96	64.59	2.86	20.79	10.25	1.48	80306.20
發生時間	9	5	12	6	16	7		20
最 小 值	1.02	6.65	47.41	1.16	15.57	8.16	1.42	70201.44
發生時間	7	23	13	19	7	18		7
零點偏移(率)	-0.10 %	-0.01 %	-0.01 %	0.00 %		-0.20		-0.10 %
全幅偏移(率)	0.02 %	0.86 %	0.40 %	-0.09 %		0.15		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								