

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月01日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.47	3.39	62.59	1.20	17.50	12.30	1.29	74789.38
1	8.13	3.80	62.40	1.22	19.21	11.67	1.29	78720.33
2	7.57	4.31	59.05	0.71	18.19	11.72	1.29	79204.43
3	8.58	4.25	58.79	1.55	16.81	11.94	1.29	78361.41
4	7.48	4.74	53.30	1.69	16.65	11.79	1.29	79889.36
5	7.93	2.86	57.14	1.19	16.60	12.06	1.29	76091.99
6	8.20	3.42	61.63	1.88	16.44	12.10	1.29	77339.57
7	8.76	3.19	60.81	1.29	17.47	11.81	1.29	78885.45
8	9.11	3.35	64.50	1.20	17.32	11.80	1.29	79290.46
9	7.44	3.40	56.69	1.12	18.07	11.22	1.32	82694.12
10	9.96	5.69	49.76	2.29	16.13	11.76	1.30	79890.27
11	8.50	5.91	49.44	1.79	16.56	11.73	1.32	77958.46
12	8.96	8.63	57.62	1.51	16.75	11.85	1.29	74668.13
13	6.23	7.41	52.72	0.94	17.39	11.37	1.30	79154.99
14	9.90	7.99	41.17	2.05	16.85	11.34	1.29	76363.31
15	8.57	2.47	48.59	1.96	15.91	11.73	1.27	75320.59
16	8.19	2.76	54.80	1.61	16.29	12.11	1.27	74995.59
17	8.08	2.28	55.19	2.26	15.85	12.13	1.28	75759.57
18	6.98	2.57	48.98	0.83	17.51	12.44	1.29	73315.27
19	6.71	2.95	51.43	1.25	17.89	11.55	1.31	80387.82
20	5.23	2.81	54.68	1.05	18.29	11.48	1.29	80567.54
21	6.05	2.67	55.99	2.46	16.02	11.91	1.29	79017.12
22	9.05	2.88	58.96	1.86	16.45	12.20	1.31	76268.22
23	7.29	2.75	54.27	1.12	17.97	11.53	1.31	80365.90
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	7.89	4.02	55.44	1.50	17.09	11.81	1.29	77887.47
最 大 值	9.96	8.63	64.50	2.46	19.21	12.44	1.34	82694.12
發生時間	10	12	8	21	1	18		9
最 小 值	5.23	2.28	41.17	0.71	15.85	11.22	1.27	73315.27
發生時間	20	17	14	2	17	9		18
零點偏移(率)	-0.02 %	-0.00 %	-0.05 %	0.00 %		-0.10		0.30 %
全幅偏移(率)	-0.65 %	0.44 %	-0.70 %	0.23 %		-0.24		0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月01日

項目 單位 小時\限標	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.71	3.39	63.77	2.03	16.14	11.48	1.12	78387.72
1	9.55	4.62	59.32	1.64	19.16	10.61	1.12	82978.54
2	10.80	3.41	53.79	1.76	17.32	10.39	1.10	85187.22
3	9.48	5.13	54.20	2.31	14.71	11.34	1.10	80404.52
4	8.95	2.20	52.05	2.35	15.30	11.20	1.10	79215.40
5	10.12	2.63	56.74	2.54	15.39	11.37	1.10	79265.20
6	6.27	2.69	53.70	2.21	14.65	11.39	1.07	83821.45
7	10.81	3.17	52.32	2.56	15.32	11.27	1.07	80381.22
8	9.92	2.35	55.67	2.26	14.89	11.43	1.09	79761.33
9	10.08	3.38	54.91	2.60	15.01	11.30	1.10	80097.57
10	8.83	3.89	51.62	3.02	13.74	11.40	1.09	78475.05
11	12.06	6.53	58.00	2.42	13.86	11.53	1.09	77693.54
12	10.31	3.01	50.37	2.42	15.18	11.13	1.08	81552.02
13	8.71	3.21	55.99	2.24	16.05	11.36	1.09	79269.85
14	9.90	3.01	52.10	2.70	16.05	11.00	1.09	82100.74
15	9.66	5.82	58.34	3.35	15.57	11.05	1.10	82410.68
16	9.78	3.30	49.13	2.61	15.52	11.37	1.10	79544.52
17	9.10	3.82	57.95	2.10	16.50	11.45	1.10	79010.96
18	9.43	6.43	49.67	3.18	16.58	10.98	1.09	82202.86
19	10.16	4.39	51.00	3.18	15.52	11.35	1.09	80188.07
20	7.67	3.43	53.69	3.18	15.97	11.28	1.07	80492.83
21	6.93	3.44	58.74	3.22	15.35	11.85	1.06	76076.58
22	9.04	6.33	53.00	2.61	17.95	10.81	1.07	82985.06
23	8.84	3.89	44.64	2.85	16.60	10.81	1.09	81708.23
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.38	3.89	54.20	2.56	15.76	11.21	1.09	80550.47
最 大 值	12.06	6.53	63.77	3.35	19.16	11.85	1.13	85187.22
發生時間	11	11	0	15	1	21		2
最 小 值	6.27	2.20	44.64	1.64	13.74	10.39	1.06	76076.58
發生時間	6	4	23	1	10	2		21
零點偏移(率)	-0.17 %	-0.00 %	-0.03 %	-0.00 %		-0.10		0.00 %
全幅偏移(率)	0.14 %	1.60 %	0.87 %	0.65 %		-0.09		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 114年03月01日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.95	2.06	62.26	0.80	17.62	10.67	1.49	80146.18
1	10.78	7.57	55.67	0.91	18.80	10.44	1.50	81907.14
2	11.05	3.56	55.33	1.09	18.11	10.16	1.50	84232.49
3	11.08	5.49	53.21	1.29	15.98	10.60	1.50	81218.87
4	12.40	4.07	60.14	1.55	15.86	10.84	1.50	80481.20
5	9.11	5.49	61.56	1.08	16.70	11.06	1.50	79247.72
6	13.41	7.28	55.54	1.11	17.41	10.35	1.50	84206.43
7	7.95	3.88	58.01	0.80	16.26	10.80	1.52	84408.78
8	13.11	3.26	56.64	0.95	16.25	10.90	1.53	80273.61
9	9.38	4.48	60.55	1.16	15.76	11.07	1.53	79657.79
10	13.09	5.87	57.26	1.12	16.12	10.88	1.53	80750.65
11	8.14	4.85	60.80	1.42	14.84	11.18	1.52	78089.06
12	10.43	4.09	59.08	0.99	16.10	10.92	1.52	79578.06
13	6.31	6.49	59.60	1.13	15.46	11.17	1.50	76713.25
14	10.34	9.03	59.77	2.30	13.89	11.29	1.49	74635.89
15	7.09	5.82	55.31	1.42	15.24	11.02	1.52	76064.25
16	5.40	3.55	57.91	1.43	14.97	11.15	1.52	74646.34
17	4.23	4.35	58.68	0.80	16.76	10.85	1.52	78072.73
18	8.85	3.39	58.07	1.00	17.08	10.62	1.49	79636.38
19	8.70	3.74	56.51	0.91	17.04	10.65	1.48	79393.79
20	10.90	2.70	56.47	0.92	16.47	10.86	1.51	77347.95
21	7.46	1.16	59.61	0.78	16.34	10.92	1.51	77719.31
22	9.36	3.06	59.17	0.98	16.51	10.96	1.49	77778.69
23	8.55	3.03	57.17	0.82	17.01	10.62	1.50	78674.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.42	4.51	58.10	1.12	16.36	10.83	1.51	79370.05
最 大 值	13.41	9.03	62.26	2.30	18.80	11.29	1.55	84408.78
發生時間	6	14	0	14	1	14		7
最 小 值	4.23	1.16	53.21	0.78	13.89	10.16	1.48	74635.89
發生時間	17	21	3	21	14	2		14
零點偏移(率)	-0.05 %	-0.00 %	-0.01 %	0.00 %		-0.05		-0.10 %
全幅偏移(率)	0.02 %	0.57 %	-0.18 %	0.24 %		-0.44		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								