

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月28日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.56	9.57	47.82	1.13	18.08	11.17	1.07	75970.01
1	9.91	10.15	53.94	0.94	20.41	10.79	1.08	76430.78
2	9.71	8.35	45.62	1.67	17.83	11.28	1.07	72976.92
3	8.87	7.39	65.08	0.69	17.86	11.54	1.09	73996.62
4	6.62	8.51	60.15	0.62	18.37	11.38	1.08	74667.43
5	8.73	9.34	54.72	1.10	17.63	11.39	1.05	73482.19
6	9.74	7.87	50.91	1.54	16.85	11.45	1.06	75574.28
7	8.97	7.38	54.65	1.36	17.52	11.44	1.09	75425.41
8	7.73	7.73	65.48	0.85	18.25	11.52	1.07	74264.82
9	8.96	7.43	54.56	0.92	18.61	11.18	1.05	76508.06
10	9.07	10.42	51.65	1.30	17.22	11.43	1.05	75719.59
11	9.12	7.90	57.17	1.22	17.45	11.50	1.05	74748.50
12	9.08	7.62	54.64	0.75	18.02	11.35	1.08	75667.75
13	9.58	7.17	52.29	1.30	17.32	11.21	1.10	76678.72
14	9.74	8.03	54.38	2.25	15.81	11.43	1.10	76115.43
15	4.50	8.71	60.09	1.27	16.35	11.69	1.10	74031.37
16	9.19	8.97	58.13	1.36	16.80	11.41	1.10	75482.93
17	6.82	9.42	59.42	0.72	17.41	11.37	1.10	75870.41
18	8.92	7.76	50.90	0.75	19.06	10.67	1.10	79647.89
19	8.34	7.19	55.83	0.73	18.24	10.91	1.10	78209.33
20	6.77	7.97	58.47	0.59	18.49	11.30	1.08	75104.66
21	8.27	7.14	54.33	0.51	19.48	10.46	1.07	80185.96
22	9.47	5.66	49.30	1.00	17.80	11.01	1.05	76617.26
23	8.81	6.62	56.87	0.74	18.21	11.11	1.05	76140.67
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.56	8.10	55.27	1.05	17.88	11.25	1.08	75813.21
最大值	9.91	10.42	65.48	2.25	20.41	11.69	1.11	80185.96
發生時間	1	10	8	14	1	15		21
最小值	4.50	5.66	45.62	0.51	15.81	10.46	1.05	72976.92
發生時間	15	22	2	21	14	21		2
零點偏移(率)	-0.56 %	0.00 %	-0.00 %	-0.00 %		0.00		0.00 %
全幅偏移(率)	0.01 %	0.88 %	0.49 %	0.33 %		0.00		0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月28日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	3.41	7.28	58.04	2.31	16.60	10.94	0.99	81051.30
1	7.87	11.90	58.94	3.57	15.41	11.15	0.99	81211.68
2	8.40	3.45	56.22	2.42	16.97	10.44	0.99	85045.38
3	5.79	4.24	54.80	1.97	17.43	10.59	0.99	83327.68
4	5.65	4.28	58.55	1.93	17.59	10.35	0.99	85157.28
5	8.85	5.28	56.84	2.02	17.38	10.42	0.99	84831.57
6	0.81	9.09	53.57	2.71	16.76	10.77	0.98	77616.73
7	0.73	5.24	57.09	2.20	17.72	10.47	1.01	85321.31
8	3.54	5.83	50.65	2.49	17.83	10.24	0.99	86691.54
9	3.41	5.41	52.58	2.58	17.69	10.38	0.98	85683.96
10	4.56	7.62	54.93	1.85	18.38	10.21	0.97	86685.44
11	4.23	11.83	50.58	2.52	17.35	10.34	0.98	85794.53
12	8.01	6.25	55.59	2.69	16.78	10.51	1.00	84916.63
13	4.91	6.44	57.71	4.13	13.64	11.24	1.00	81962.65
14	3.14	4.44	63.45	3.31	15.11	11.21	0.99	81264.63
15	3.14	2.03	63.59	2.33	16.73	10.65	1.00	83377.84
16	5.96	2.91	67.76	1.66	17.10	10.71	0.99	83508.73
17	7.59	8.07	45.89	1.90	17.89	9.93	0.99	88367.05
18	7.40	5.30	55.87	2.08	16.99	10.55	0.99	84781.24
19	4.02	8.27	51.38	2.70	16.14	10.64	0.98	84266.32
20	4.27	3.99	59.28	2.61	17.05	10.48	0.99	84809.57
21	7.86	7.98	58.29	2.58	17.64	10.24	0.98	86309.22
22	7.06	3.46	60.13	2.45	17.49	10.28	0.98	85716.71
23	4.37	5.86	51.98	1.82	18.41	9.90	0.98	88168.53
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	5.21	6.10	56.40	2.45	17.00	10.53	0.99	84411.15
最大值	8.85	11.90	67.76	4.13	18.41	11.24	1.03	88367.05
發生時間	5	1	16	13	23	13		17
最小值	0.73	2.03	45.89	1.66	13.64	9.90	0.97	77616.73
發生時間	7	15	17	16	13	23		6
零點偏移(率)	-0.37 %	-0.01 %	-0.01 %	0.00 %		0.03		-0.20 %
全幅偏移(率)	0.02 %	-0.75 %	-0.08 %	0.02 %		-0.17		-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年10月28日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.78	11.90	44.02	1.89	15.04	10.88	0.95	77825.44
1	9.82	6.41	52.70	1.51	16.81	10.64	0.97	80348.08
2	8.62	7.48	45.49	1.45	16.52	10.59	0.95	79672.54
3	7.69	7.11	59.27	1.42	15.69	11.30	0.97	75085.90
4	8.22	8.98	46.33	1.40	16.44	10.64	0.97	81943.44
5	9.13	5.06	60.00	1.40	16.67	10.85	0.97	80073.62
6	8.48	9.23	48.52	1.73	15.35	11.15	0.95	78149.60
7	9.24	6.57	48.39	1.66	15.87	10.97	0.94	82947.22
8	8.21	4.70	65.11	1.07	17.29	11.09	0.95	79543.39
9	8.89	5.38	48.53	1.30	16.51	10.92	0.94	85108.25
10	8.70	14.14	56.41	2.23	14.42	11.70	0.96	78689.85
11	8.86	7.16	54.71	1.79	15.28	11.29	0.97	78132.16
12	5.62	6.63	51.15	1.73	14.55	11.12	0.94	75435.75
13	7.22	6.53	50.30	2.05	14.34	11.16	0.95	77078.79
14	7.06	9.58	51.49	3.12	12.71	11.51	0.94	75207.32
15	6.15	1.60	51.61	2.47	13.61	11.18	0.96	75608.46
16	5.61	2.06	50.61	2.17	13.86	11.14	0.95	73322.05
17	8.57	3.10	49.67	1.92	14.77	10.99	0.95	76091.18
18	2.31	4.49	55.85	1.08	16.20	10.93	0.95	77874.07
19	2.51	11.05	51.49	1.38	14.92	11.20	0.95	78730.15
20	5.89	9.86	58.20	1.37	15.34	11.27	0.97	82008.25
21	7.92	7.29	49.98	1.19	16.09	10.86	0.97	82036.13
22	3.26	4.96	48.16	1.63	14.83	11.06	0.96	75780.96
23	2.74	6.35	47.75	1.65	14.82	10.96	0.96	75676.36
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.10	6.98	51.91	1.69	15.33	11.06	0.96	78432.04
最大值	9.82	14.14	65.11	3.12	17.29	11.70	0.97	85108.25
發生時間	1	10	8	14	8	10		9
最小值	2.31	1.60	44.02	1.07	12.71	10.59	0.94	73322.05
發生時間	18	15	0	8	14	2		16
零點偏移(率)	-0.02 %	0.00 %	-0.16 %	-0.01 %		0.01		0.00 %
全幅偏移(率)	0.04 %	-0.29 %	-0.00 %	-0.05 %		0.06		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								