

P001 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月07日

項目 單位 小時\限標	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.60	10.85	59.75	2.34	16.58	11.33	1.23	71449.84
1	8.71	14.61	45.35	2.21	17.12	11.62	1.21	69527.99
2	9.20	12.63	48.87	1.97	16.41	11.69	1.22	70041.83
3	9.93	12.05	58.30	2.07	16.79	11.56	1.23	71033.10
4	9.14	11.98	57.14	2.26	16.53	11.61	1.23	70941.75
5	11.18	13.32	58.60	2.38	16.80	11.58	1.22	68979.46
6	8.48	13.17	54.83	2.35	15.87	11.58	1.21	71418.01
7	12.36	13.55	60.50	3.13	13.95	11.95	1.21	69591.73
8	8.04	13.40	59.12	2.54	15.78	11.72	1.20	70219.84
9	10.11	13.29	52.50	2.79	15.90	11.65	1.20	70306.83
10	9.55	13.39	54.74	2.52	15.50	11.70	1.22	70085.52
11	2.74	13.87	58.15	2.81	13.47	12.17	1.20	68605.56
12	7.60	14.01	57.54	2.43	15.28	12.20	1.20	67062.88
13	10.57	13.23	57.31	2.59	15.46	11.62	1.20	71082.16
14	9.43	13.58	49.48	2.63	14.80	11.89	1.21	69178.29
15	6.87	13.74	57.06	1.92	16.91	11.75	1.21	69009.70
16	8.50	13.81	53.34	2.22	16.69	11.18	1.21	73523.00
17	9.18	13.55	56.82	2.18	16.96	11.61	1.21	70025.20
18	12.71	13.68	53.39	3.26	14.47	11.76	1.20	71442.64
19	6.03	13.50	58.23	2.47	14.88	11.83	1.20	70261.35
20	8.34	13.43	57.29	3.19	13.80	11.87	1.21	70896.02
21	6.98	13.40	56.37	2.92	14.02	11.87	1.21	70005.10
22	8.43	13.37	54.83	2.51	15.49	11.71	1.22	70075.00
23	10.81	13.27	49.92	2.82	15.05	11.68	1.21	70547.55
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	8.90	13.28	55.39	2.52	15.60	11.71	1.21	70221.26
最 大 值	12.71	14.61	60.50	3.26	17.12	12.20	1.24	73523.00
發生時間	18	1	7	18	1	12		16
最 小 值	2.74	10.85	45.35	1.92	13.47	11.18	1.19	67062.88
發生時間	11	0	1	15	11	16		12
零點偏移(率)	-0.07 %	0.00 %	-0.01 %	0.00 %		0.00		0.00 %
全幅偏移(率)	0.00 %	-0.61 %	0.08 %	-0.30 %		-0.01		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年09月07日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	1.34	12.42	58.47	1.78	16.76	11.05	1.02	80701.59
1	1.54	12.93	60.95	2.27	17.11	11.30	1.02	75525.09
2	1.48	12.13	59.77	1.78	17.19	10.71	1.02	83166.36
3	1.51	12.57	55.79	3.10	14.74	11.30	1.02	79294.78
4	1.83	15.60	65.42	3.86	14.74	11.28	1.02	81253.88
5	2.29	13.15	61.39	1.22	14.51	11.50	1.02	79785.17
6	3.50	11.83	52.44	1.75	17.32	10.70	0.99	74337.39
7	3.05	12.54	53.44	2.36	16.27	11.22	1.00	78852.43
8	2.94	12.05	56.42	1.27	18.03	10.58	1.00	80507.60
9	2.74	12.54	57.28	1.50	17.04	11.12	0.99	76912.55
10	1.98	12.43	54.74	2.11	16.39	10.98	1.00	79031.38
11	2.07	12.49	68.17	1.57	17.29	11.04	0.99	78792.19
12	1.94	12.65	64.58	1.88	16.67	11.09	0.98	80127.44
13	1.84	12.67	67.52	2.14	16.43	11.11	0.99	79817.76
14	1.69	12.86	67.56	2.95	15.05	11.40	0.98	78966.85
15	1.63	13.00	64.62	2.92	15.07	11.57	0.99	77824.59
16	1.94	14.01	56.48	2.58	16.02	11.15	0.98	80757.04
17	2.19	13.19	58.82	2.17	16.04	11.61	1.00	77026.85
18	2.14	12.73	57.19	2.11	16.39	11.13	1.00	81122.13
19	2.38	14.72	59.35	2.99	16.95	10.85	1.01	82384.28
20	1.57	11.58	54.24	1.39	13.42	11.70	0.99	76847.96
21	1.90	11.76	68.14	1.04	14.77	11.28	0.97	81091.36
22	2.19	12.14	55.58	0.73	16.95	10.82	0.97	82231.00
23	2.09	12.05	53.12	2.14	16.39	10.85	0.97	81638.43
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	2.07	12.75	59.64	2.07	16.15	11.14	1.00	79499.84
最 大 值	3.50	15.60	68.17	3.86	18.03	11.70	1.02	83166.36
發生時間	6	4	11	4	8	20		2
最 小 值	1.34	11.58	52.44	0.73	13.42	10.58	0.96	74337.39
發生時間	0	20	6	22	20	8		6
零點偏移(率)	-0.11 %	-0.05 %	-0.35 %	-0.02 %		-0.07		-0.10 %
全幅偏移(率)	-1.05 %	-1.18 %	0.41 %	-0.14 %		0.10		0.00 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年09月07日

報表日期: 114年09月07日

[illegible]