

P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	1.08	4.41	55.14	3.29	16.30	12.81	1.30	64707.33
1	0.47	3.77	43.89	2.74	17.74	12.22	1.32	68016.85
2	0.71	4.77	36.02	2.88	17.71	11.97	1.30	71584.19
3	6.50	3.25	40.26	4.00	15.68	12.39	1.31	72509.72
4	7.17	3.46	42.48	4.07	15.82	12.42	1.33	71955.33
5	8.83	11.21	47.54	3.18	17.52	11.64	1.35	75445.39
6	9.20	3.17	40.72	3.06	18.06	11.41	1.38	74474.42
7	7.33	3.40	46.70	3.02	18.07	11.63	1.37	72422.59
8	8.24	3.34	49.84	3.32	17.57	12.01	1.36	71416.47
9	9.73	3.22	49.84	3.72	17.17	12.03	1.33	73546.52
10	8.46	3.59	49.63	3.37	17.89	11.96	1.31	73623.43
11	7.20	3.64	45.50	3.48	16.72	12.27	1.28	72236.02
12	3.04	3.30	60.07	2.96	17.40	12.35	1.28	71696.27
13	0.97	3.44	59.67	2.59	18.62	12.04	1.30	72548.17
14	2.06	3.37	53.30	2.74	18.01	11.79	1.33	75165.08
15	1.64	3.27	60.01	2.56	18.41	11.80	1.35	73759.45
16	0.71	3.50	52.10	2.48	18.41	11.76	1.37	72089.00
17	0.44	3.27	54.47	2.46	18.33	11.58	1.36	73045.03
18	0.71	3.29	54.79	2.47	18.49	11.45	1.33	73476.44
19	0.46	3.22	50.81	2.54	17.99	11.41	1.31	74134.97
20	5.51	4.15	50.81	3.13	16.97	11.72	1.32	72553.22
21	11.54	6.65	50.84	3.99	16.10	12.19	1.33	69743.68
22	8.59	3.89	51.59	3.32	16.85	12.17	1.35	71024.38
23	8.57	3.47	62.11	3.15	17.28	12.20	1.36	70104.41
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	4.96	4.00	50.34	3.10	17.46	11.97	1.33	72136.60
最大值	11.54	11.21	62.11	4.07	18.62	12.81	1.39	75445.39
發生時間	21	5	23	4	13	0		5
最小值	0.44	3.17	36.02	2.46	15.68	11.41	1.28	64707.33
發生時間	17	6	2	17	3	6		0
零點偏移(率)	-0.01 %	-0.00 %	-0.04 %	-0.00 %		-0.04	0.00	0.00 %
全幅偏移(率)	4.33 %	0.07 %	-0.23 %	0.04 %		-0.21	-0.03	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	6.17	2.73	58.40	1.89	18.73	10.76	1.39	77959.17
1	3.81	3.46	48.09	2.07	18.51	11.21	1.40	70958.13
2	5.41	2.79	55.01	2.05	19.08	11.08	1.40	71611.55
3	7.29	3.70	46.61	2.86	17.67	10.75	1.39	74072.58
4	3.13	3.10	51.93	2.50	16.56	11.23	1.38	70613.46
5	4.62	3.70	45.55	2.01	19.48	9.92	1.38	80196.57
6	10.67	5.58	33.12	3.21	19.20	9.66	1.38	86328.98
7	8.69	4.62	46.41	2.60	19.37	10.14	1.38	80799.48
8	19.60	4.50	39.28	4.45	18.45	9.97	1.38	81304.35
9	9.32	3.44	47.46	2.80	19.11	10.10	1.39	79864.66
10	8.45	3.41	54.29	2.60	20.72	9.29	1.42	86114.86
11	9.49	3.04	43.93	3.56	17.41	9.88	1.40	80706.79
12	6.19	2.69	65.58	1.83	19.72	10.38	1.41	80800.51
13	8.65	3.99	40.23	2.18	18.43	10.24	1.38	83287.69
14	6.96	3.43	36.77	2.43	17.30	10.13	1.38	79988.80
15	9.76	3.75	44.56	2.94	18.31	9.83	1.38	80239.90
16	9.16	3.28	44.46	2.62	19.02	9.66	1.38	82254.86
17	3.74	2.63	58.14	1.54	18.67	10.68	1.38	77915.01
18	0.08	2.80	45.59	1.42	18.41	10.60	1.38	79978.01
19	2.44	4.32	45.87	1.87	17.60	10.09	1.38	84017.90
20	7.65	4.14	51.79	2.40	16.99	10.35	1.38	82145.90
21	6.70	5.21	42.49	2.05	18.40	9.96	1.37	81508.47
22	5.10	3.31	46.52	1.65	18.64	10.06	1.37	80691.71
23	2.15	3.41	63.03	1.18	19.46	10.74	1.38	79375.02
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	6.88	3.63	48.13	2.36	18.55	10.28	1.39	79697.26
最大值	19.60	5.58	65.58	4.45	20.72	11.23	1.47	86328.98
發生時間	8	6	12	8	10	4		6
最小值	0.08	2.63	33.12	1.18	16.56	9.29	1.36	70613.46
發生時間	18	17	6	23	4	10		4
零點偏移(率)	-0.02 %	-0.00 %	-0.06 %	0.00 %		-0.08	0.00	0.00 %
全幅偏移(率)	0.54 %	0.21 %	0.02 %	0.09 %		-0.25	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年04月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.93	2.82	63.36	3.66	14.82	11.54	1.42	71835.90
1	1.44	2.88	53.40	3.18	15.40	12.13	1.41	68089.61
2	1.65	2.43	51.70	3.15	15.24	11.79	1.41	69642.69
3	2.94	3.20	48.99	3.76	14.06	11.71	1.41	69985.01
4	3.80	3.84	63.15	4.50	13.03	12.24	1.42	69086.04
5	6.59	7.28	47.00	3.59	17.66	10.66	1.43	78358.17
6	9.48	5.80	38.49	3.09	17.64	9.73	1.42	81793.83
7	0.71	16.72	37.71	6.33	20.78	9.26	1.41	88196.84
8	8.14	0.29	48.46	3.47	18.62	9.45	1.42	83363.96
9	10.06	2.71	45.98	2.88	17.09	10.56	1.43	81525.20
10	8.48	1.30	51.12	3.04	16.80	10.39	1.43	82140.88
11	9.12	1.52	56.34	2.93	17.32	10.60	1.43	83921.58
12	8.80	1.92	58.36	2.86	16.31	10.91	1.45	83637.06
13	8.81	4.57	61.00	3.54	17.09	10.87	1.44	83489.94
14	10.00	1.40	52.66	2.97	15.91	11.00	1.43	80654.19
15	7.15	1.77	57.52	2.80	17.15	10.62	1.43	80170.28
16	9.56	1.42	52.82	2.81	16.47	10.61	1.43	80638.29
17	9.66	1.25	55.84	2.87	17.49	10.32	1.43	83614.45
18	12.44	1.57	57.75	3.14	16.41	10.64	1.43	83518.52
19	7.94	1.18	59.20	2.80	17.75	10.34	1.43	83279.55
20	10.07	1.56	51.72	2.90	16.39	10.49	1.43	80878.35
21	10.11	4.06	55.15	3.20	16.35	10.32	1.43	83733.37
22	8.31	1.29	54.58	2.87	16.24	10.66	1.43	80194.12
23	8.71	2.99	57.66	2.64	17.84	10.28	1.43	82281.35
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	7.45	3.16	53.33	3.29	16.66	10.71	1.43	79751.22
最大值	12.44	16.72	63.36	6.33	20.78	12.24	1.49	88196.84
發生時間	18	7	0	7	7	4		7
最小值	0.71	0.29	37.71	2.64	13.03	9.26	1.40	68089.61
發生時間	7	8	7	23	4	7		1
零點偏移(率)	-0.05 %	-0.00 %	-0.24 %	-0.02 %		-0.03	0.00	0.00 %
全幅偏移(率)	1.23 %	0.49 %	-0.41 %	0.12 %		-0.02	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								