

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 114年12月20日

報表日期: 114年12月20日

項目 單位	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO ₂ _C	#1-H ₂ O	#1-O ₂ _C	#1-OPAC	#1-FLOW_C
小時\限標	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.01	12.75	65.47	2.41	16.47	12.24	1.28	74610.00
1	11.73	12.49	65.04	2.75	17.59	11.83	1.28	77129.15
2	12.57	12.17	55.69	2.92	18.26	11.44	1.28	79729.55
3	11.53	11.67	48.03	3.86	16.15	11.37	1.27	82571.84
4	11.81	12.47	50.35	4.19	15.01	12.20	1.27	76026.07
5	12.04	13.90	58.10	1.86	16.34	12.19	1.27	73003.91
6	13.24	12.82	47.94	2.45	16.57	11.41	1.27	81515.77
7	12.06	13.61	51.36	2.63	15.28	12.09	1.28	76826.88
8	11.66	13.49	48.82	2.23	16.45	11.86	1.28	77805.77
9	11.64	13.34	37.26	2.68	15.65	11.74	1.27	79722.18
10	12.47	13.68	44.31	2.68	15.40	12.02	1.27	77414.05
11	13.27	14.38	49.52	2.69	15.10	12.32	1.26	75655.14
12	12.39	13.00	49.94	2.21	16.48	11.51	1.25	80620.03
13	9.74	13.91	47.95	2.55	14.69	12.34	1.26	75267.03
14	11.82	14.80	56.12	1.77	15.62	12.77	1.26	70992.98
15	12.16	14.37	58.03	1.90	15.92	12.50	1.25	72429.80
16	11.44	13.25	66.67	1.16	17.17	12.25	1.25	74069.53
17	12.24	11.73	46.97	1.52	17.37	11.45	1.25	80345.81
18	13.08	11.55	52.39	1.94	16.56	11.43	1.25	81192.89
19	11.99	11.55	51.89	1.67	17.02	11.39	1.25	81132.78
20	10.98	12.00	51.14	1.48	16.93	11.76	1.25	78525.16
21	7.90	17.36	54.69	1.58	17.67	11.41	1.25	76700.19
22	9.24	10.68	62.92	2.27	16.43	11.71	1.25	78459.57
23	11.78	12.15	45.79	2.60	17.01	11.85	1.26	77283.07
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	11.70	13.05	52.77	2.33	16.38	11.88	1.26	77459.55
最 大 值	13.27	17.36	66.67	4.19	18.26	12.77	1.29	82571.84
發生時間	11	21	16	4	2	14		3
最 小 值	7.90	10.68	37.26	1.16	14.69	11.37	1.25	70992.98
發生時間	21	22	9	16	13	3		14
零點偏移(率)	-0.13 %	-0.09 %	-0.02 %	-0.01 %		-0.05	-0.01	0.20 %
全幅偏移(率)	1.39 %	1.05 %	-1.19 %	-0.80 %		0.06	0.10	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P002 樹林焚化廠CEMS系統日報表-A

報表日期: 114年12月20日

項目 單位 小時\限標	#2-HCl_C ppm	#2-CO_C ppm	#2-NOx_C ppm	#2-SO2_C ppm	#2-H2O %	#2-O2_C %	#2-OPAC %	#2-FLOW_C m3/Hour
0	10.64	12.02	47.58	1.89	17.10	10.28	1.04	78539.81
1	11.60	12.00	50.65	1.82	16.53	10.51	1.04	77917.58
2	12.40	11.93	57.90	1.77	16.07	10.65	1.05	76843.39
3	11.09	12.15	56.26	1.60	15.35	10.96	1.04	76898.59
4	14.23	12.67	48.63	2.79	15.47	10.59	1.04	76937.15
5	12.08	12.44	62.86	2.61	15.67	10.92	1.04	77217.87
6	14.59	11.90	42.94	2.19	16.03	10.58	1.04	80545.78
7	12.99	12.41	54.98	2.42	15.87	10.95	1.03	76427.05
8	11.88	14.07	51.03	2.30	16.18	10.41	1.03	77499.43
9	15.43	14.31	46.53	4.20	15.21	10.59	1.02	77904.60
10	11.18	12.98	33.93	3.11	16.28	10.67	1.02	74993.41
11	12.01	14.81	30.38	2.92	15.50	10.49	1.02	76997.72
12	19.03	12.04	34.64	2.29	17.25	9.93	1.02	78518.98
13	11.89	13.59	46.84	2.99	17.15	11.12	1.04	72610.63
14	11.73	13.80	41.13	2.30	17.98	10.33	1.03	82332.56
15	13.84	12.52	31.64	4.12	17.10	10.49	1.02	78732.38
16	12.82	12.31	36.85	3.36	18.11	9.98	1.02	79854.61
17	13.99	12.02	59.59	3.57	16.78	10.37	1.02	80345.48
18	11.62	11.82	63.42	1.81	16.72	10.49	1.03	78645.40
19	14.35	11.72	62.62	1.93	17.11	10.29	1.02	80040.08
20	12.25	11.77	53.47	2.16	17.59	9.94	1.02	79341.08
21	12.58	12.57	63.56	1.50	19.35	9.46	1.02	85086.50
22	11.74	11.26	60.89	1.49	18.33	10.02	1.02	81513.47
23	12.64	11.57	48.41	1.31	19.38	9.99	1.03	82981.88
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.86	12.53	49.45	2.44	16.84	10.42	1.03	78696.89
最 大 值	19.03	14.81	63.56	4.20	19.38	11.12	1.06	85086.50
發生時間	12	11	21	9	23	13		21
最 小 值	10.64	11.26	30.38	1.31	15.21	9.46	1.02	72610.63
發生時間	0	22	11	23	9	21		13
零點偏移(率)	-0.06 %	0.01 %	-0.05 %	-0.01 %		-0.04	-0.01	0.10 %
全幅偏移(率)	-1.00 %	-0.42 %	-0.44 %	-1.33 %		-0.04	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A 報表日期: 114年12月20日

報表日期: 114年12月20日

項目 單位 小時\限標	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO ₂ _C	#3-H ₂ O	#3-O ₂ _C	#3-OPAC	#3-FLOW_C
	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	12.20	11.35	57.67	2.66	16.20	11.07	1.09	76030.02
1	12.88	11.47	62.89	2.58	16.94	11.24	1.09	75822.15
2	11.37	10.86	51.98	2.95	15.92	10.59	1.09	78329.13
3	12.13	11.63	59.58	3.36	15.57	10.85	1.09	75371.71
4	11.89	11.06	56.72	3.02	16.35	10.83	1.10	75516.50
5	12.37	13.26	57.97	2.88	16.13	10.92	1.09	75458.98
6	11.94	13.61	57.81	3.15	15.47	11.00	1.09	74805.11
7	14.28	12.13	57.62	3.10	16.14	10.89	1.14	75256.24
8	12.52	10.75	51.21	2.37	16.60	10.56	1.15	76429.03
9	10.77	10.95	56.08	2.24	16.62	10.86	1.15	74012.80
10	12.54	11.88	48.17	2.37	17.64	10.24	1.14	76239.98
11	10.99	11.74	49.68	2.11	17.30	10.61	1.13	70815.88
12	12.84	11.34	55.12	2.79	15.89	10.69	1.12	76230.96
13	12.07	11.93	60.19	2.60	14.97	11.19	1.14	69941.20
14	12.42	12.06	67.29	2.57	15.77	10.90	1.13	71574.35
15	17.37	11.44	54.67	4.08	17.57	10.01	1.12	72328.85
16	12.64	13.22	46.94	3.12	16.60	9.73	1.13	78520.92
17	10.63	13.78	51.94	1.14	16.74	10.34	1.13	77967.09
18	11.52	13.82	53.54	1.22	16.34	10.38	1.15	74951.10
19	11.40	13.39	44.71	1.10	16.88	9.96	1.12	76897.67
20	12.11	13.66	51.22	1.06	17.33	10.21	1.10	76186.11
21	12.64	13.72	51.48	1.15	16.69	10.13	1.13	78378.97
22	13.09	13.36	48.37	1.29	16.54	10.00	1.13	75270.88
23	11.75	12.05	48.04	1.84	17.28	9.96	1.13	76979.33
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	12.35	12.27	54.20	2.36	16.48	10.55	1.12	75388.12
最 大 值	17.37	13.82	67.29	4.08	17.64	11.24	1.16	78520.92
發生時間	15	18	14	15	10	1		16
最 小 值	10.63	10.75	44.71	1.06	14.97	9.73	1.09	69941.20
發生時間	17	8	19	20	13	16		13
零點偏移(率)	-0.12 %	-0.01 %	-0.01 %	0.00 %		-0.05	-0.01	0.00 %
全幅偏移(率)	-1.17 %	-0.47 %	0.54 %	-0.48 %		0.08	0.04	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								