

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月20日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.86	4.67	63.87	0.53	19.97	11.44	1.46	75860.58
1	9.35	3.54	51.18	0.34	21.06	10.84	1.44	79680.58
2	11.63	1.53	63.30	0.34	20.93	10.98	1.44	78673.28
3	13.99	1.83	59.95	1.01	19.46	11.16	1.43	79016.82
4	13.57	2.05	65.42	0.87	20.24	10.85	1.43	80276.69
5	10.52	1.96	53.37	1.31	19.93	10.71	1.39	82089.79
6	12.10	4.05	55.01	1.40	18.55	11.42	1.39	77784.39
7	11.93	2.92	56.23	1.26	18.97	11.38	1.40	77596.58
8	9.75	1.56	58.10	0.75	19.78	11.51	1.41	75733.86
9	10.64	1.40	53.61	0.80	20.02	11.27	1.43	77432.49
10	11.97	3.75	50.42	1.11	18.45	11.33	1.39	77740.21
11	12.64	9.86	53.19	1.25	18.23	11.40	1.42	77219.43
12	9.92	4.46	50.67	1.03	18.22	11.35	1.45	77090.58
13	12.75	3.14	52.84	1.15	18.16	11.41	1.41	76380.61
14	17.14	11.61	45.26	2.10	17.22	11.88	1.41	72614.93
15	6.25	3.74	51.04	2.26	17.10	11.88	1.41	74129.05
16	9.74	1.43	59.77	0.96	18.58	11.62	1.44	75149.93
17	4.25	1.42	65.13	0.80	18.62	12.09	1.49	71701.79
18	0.15	1.07	65.35	0.68	19.13	12.38	1.44	68436.90
19	2.67	0.77	38.08	0.33	20.88	10.97	1.41	77862.13
20	7.65	4.74	46.23	0.94	19.10	11.22	1.43	77683.74
21	10.75	6.46	47.24	1.14	18.19	11.20	1.40	78006.92
22	11.85	1.84	57.28	1.10	18.71	11.33	1.37	77157.11
23	13.90	2.83	44.45	1.38	18.26	11.21	1.39	78278.81
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.21	3.44	54.46	1.03	19.07	11.37	1.42	76816.55
最大值	17.14	11.61	65.42	2.26	21.06	12.38	1.52	82089.79
發生時間	14	14	4	15	1	18		5
最小值	0.15	0.77	38.08	0.33	17.10	10.71	1.36	68436.90
發生時間	18	19	19	19	15	5		18
零點偏移(率)	0.00 %	-0.01 %	-0.01 %	-0.01 %		0.02	0.00	0.00 %
全幅偏移(率)	4.85 %	0.21 %	-0.42 %	0.17 %		0.16	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月20日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	4.29	2.99	63.56	1.37	18.19	10.66	1.45	66213.03
1	4.18	2.46	64.12	1.12	19.83	10.47	1.46	65765.82
2	8.04	1.12	59.02	1.84	18.41	10.43	1.46	67231.64
3	8.38	1.50	62.73	2.13	17.45	10.80	1.46	65516.04
4	10.52	1.33	61.84	2.42	17.65	10.49	1.46	67394.72
5	9.21	3.71	62.30	2.32	17.32	10.72	1.46	66155.38
6	10.70	1.91	62.87	2.14	17.56	10.78	1.44	69623.02
7	9.48	1.32	62.12	1.63	18.85	10.50	1.45	66148.21
8	9.28	12.09	55.33	2.36	17.66	10.54	1.46	65456.71
9	13.29	7.31	58.44	3.32	16.10	10.83	1.43	63288.10
10	11.69	10.70	55.34	3.11	15.03	10.89	1.44	61679.04
11	10.33	5.57	45.88	3.06	14.23	11.14	1.46	60587.06
12	9.98	5.16	52.46	2.67	14.09	11.24	1.45	62926.45
13	3.62	7.85	46.93	2.63	13.40	11.18	1.45	60319.49
14	1.79	4.69	56.26	2.70	13.18	11.47	1.43	60096.84
15	6.08	4.49	52.33	2.56	14.41	10.82	1.43	64847.70
16	8.48	2.55	59.16	2.60	15.67	10.86	1.42	63150.43
17	9.27	1.34	62.28	2.80	16.39	10.93	1.44	63996.39
18	5.44	2.52	65.02	2.10	17.56	10.76	1.46	64408.13
19	11.06	8.56	60.09	3.56	14.89	11.08	1.43	63118.85
20	11.36	2.14	54.36	2.77	14.40	10.70	1.40	60617.34
21	10.66	2.86	67.36	2.71	14.44	11.16	1.45	62225.16
22	9.51	2.82	61.94	2.20	16.10	10.86	1.46	62673.49
23	9.64	3.14	66.01	1.88	17.39	10.74	1.44	64657.80
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.60	4.17	59.07	2.42	16.26	10.84	1.45	64087.37
最大值	13.29	12.09	67.36	3.56	19.83	11.47	1.48	69623.02
發生時間	9	8	21	19	1	14		6
最小值	1.79	1.12	45.88	1.12	13.18	10.43	1.39	60096.84
發生時間	14	2	11	1	14	2		14
零點偏移(率)	-0.02 %	-0.01 %	-0.01 %	-0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.62 %	0.34 %	-0.14 %	0.03 %		0.01	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 111年12月20日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	7.21	4.65	56.54	1.60	15.44	11.13	1.30	82791.92
1	7.19	2.81	60.69	1.81	15.56	11.40	1.30	81583.28
2	7.81	2.17	58.04	1.78	15.96	11.15	1.31	83856.63
3	9.00	2.83	56.83	1.89	15.62	10.96	1.33	85202.91
4	6.27	5.67	60.16	1.84	15.49	11.07	1.33	85111.81
5	9.99	1.97	55.82	1.97	15.85	10.81	1.33	87435.46
6	8.61	10.40	60.73	2.61	14.37	11.42	1.33	83022.90
7	9.62	2.25	60.37	1.87	16.28	11.02	1.32	80104.01
8	10.51	4.78	54.65	1.69	17.51	10.64	1.30	88667.30
9	15.58	28.08	55.27	8.69	13.22	11.17	1.27	83371.99
10	11.89	3.44	53.94	6.29	12.19	11.38	1.27	80914.60
11	8.67	5.42	56.17	5.32	12.89	11.22	1.28	80559.52
12	11.28	2.72	54.65	3.51	13.70	10.97	1.29	82057.05
13	7.79	2.56	49.97	2.34	14.27	10.54	1.30	82003.32
14	8.57	2.12	59.35	2.74	13.69	10.79	1.30	81382.59
15	10.54	8.42	53.83	2.92	13.58	10.65	1.29	83512.80
16	9.34	4.29	58.33	3.18	13.12	11.08	1.30	79508.74
17	10.13	1.08	56.15	2.34	15.31	10.47	1.29	82575.29
18	7.73	0.56	56.80	2.01	15.64	10.37	1.26	82964.57
19	9.41	1.64	54.92	2.86	14.06	10.77	1.27	82963.91
20	9.14	1.92	62.94	3.38	13.21	11.17	1.26	82400.91
21	14.62	2.23	59.79	5.15	11.80	11.43	1.25	79823.39
22	8.48	3.17	63.70	2.01	15.76	10.97	1.26	85332.07
23	9.26	5.46	59.43	2.07	15.04	10.83	1.28	87420.37
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.53	4.61	57.46	2.99	14.57	10.98	1.29	83106.97
最大值	15.58	28.08	63.70	8.69	17.51	11.43	1.35	88667.30
發生時間	9	9	22	9	8	21		8
最小值	6.27	0.56	49.97	1.60	11.80	10.37	1.25	79508.74
發生時間	4	18	13	0	21	18		16
零點偏移(率)	-0.08 %	0.00 %	-0.02 %	-0.02 %		0.02	0.00	0.00 %
全幅偏移(率)	0.05 %	0.24 %	-0.30 %	-0.01 %		0.53	0.02	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								