

## P001\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月25日

項目	#1-HCl_C	#1-CO_C	#1-NOx_C	#1-SO2_C	#1-H2O	#1-O2_C	#1-OPAC	#1-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	9.26	4.17	56.02	4.45	13.46	12.64	1.30	68381.35
1	10.25	3.54	69.06	3.57	15.27	12.62	1.32	66936.20
2	9.09	3.77	54.23	3.43	15.44	12.51	1.32	67600.55
3	10.49	3.50	59.26	4.13	13.78	12.52	1.33	68884.05
4	9.20	5.64	59.36	3.68	14.56	12.58	1.33	67993.21
5	6.01	9.35	66.32	5.24	12.67	13.67	1.34	65663.69
6	11.23	4.43	56.00	4.44	13.61	12.55	1.36	69895.51
7	9.38	3.39	66.64	3.55	15.28	12.46	1.34	69865.24
8	9.18	3.68	57.22	4.40	13.50	12.62	1.34	69120.41
9	8.86	5.55	53.01	5.09	13.27	13.07	1.38	63498.99
10	10.48	4.09	48.28	3.87	15.49	12.29	1.33	71714.86
11	10.74	3.25	57.06	3.45	15.81	12.30	1.39	71881.88
12	10.66	3.52	58.67	2.83	17.46	11.94	1.40	71081.07
13	10.03	3.23	44.50	3.73	15.30	12.25	1.38	72258.29
14	11.05	5.23	54.51	3.62	15.51	12.17	1.38	72918.02
15	10.56	4.06	45.34	4.33	14.49	12.50	1.35	71937.94
16	10.75	3.14	56.80	3.86	15.80	12.30	1.32	72263.30
17	10.63	3.19	58.89	2.82	16.97	11.83	1.35	73179.05
18	10.15	3.13	56.20	2.91	16.48	12.07	1.32	70845.06
19	7.62	4.52	57.92	2.50	16.65	11.86	1.32	71936.36
20	8.73	3.57	41.59	3.09	16.02	12.35	1.33	68850.24
21	6.09	1.67	56.79	2.24	17.37	12.02	1.33	70260.29
22	8.57	1.71	58.27	2.40	17.41	11.92	1.33	70939.39
23	8.18	1.78	50.00	2.36	17.53	11.91	1.33	71198.59
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	9.47	3.88	55.91	3.58	15.38	12.37	1.34	69962.65
最大值	11.23	9.35	69.06	5.24	17.53	13.67	1.41	73179.05
發生時間	6	5	1	5	23	5		17
最小值	6.01	1.67	41.59	2.24	12.67	11.83	1.30	63498.99
發生時間	5	21	20	21	5	17		9
零點偏移(率)	-0.01 %	0.00 %	0.00 %	-0.00 %		0.00	0.00	0.00 %
全幅偏移(率)	3.26 %	0.81 %	-0.25 %	0.17 %		0.10	0.00	0.30 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P002\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月25日

項目	#2-HCl_C	#2-CO_C	#2-NOx_C	#2-SO2_C	#2-H2O	#2-O2_C	#2-OPAC	#2-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	10.42	5.46	53.17	2.80	15.88	10.52	1.43	82112.84
1	9.65	4.02	53.39	2.33	18.09	10.27	1.43	85317.95
2	10.16	6.93	56.30	2.49	19.04	10.06	1.47	85732.97
3	9.59	3.83	59.02	2.99	16.77	10.69	1.48	82148.60
4	10.15	3.47	62.85	2.84	17.54	10.51	1.47	83302.31
5	9.03	7.10	62.57	2.84	18.01	10.27	1.44	84952.56
6	11.83	10.22	57.06	2.83	18.15	10.47	1.43	84498.63
7	10.68	4.25	50.58	3.41	17.64	10.22	1.47	80730.72
8	10.17	5.31	48.68	2.82	17.52	10.21	1.49	84118.91
9	11.52	4.88	56.09	3.14	15.74	10.84	1.47	80459.87
10	9.36	7.01	54.83	3.98	14.62	11.03	1.45	79013.00
11	7.34	3.82	59.91	2.42	17.66	10.57	1.49	83636.87
12	11.88	4.96	61.15	3.76	15.62	10.73	1.46	81799.42
13	18.91	11.27	54.90	8.35	14.19	10.44	1.44	78017.58
14	15.06	5.49	49.34	5.65	14.46	10.35	1.45	75863.75
15	14.63	3.32	57.91	4.90	14.55	10.62	1.49	75575.02
16	10.74	2.97	42.88	3.10	16.33	10.16	1.49	83397.34
17	10.06	2.26	58.70	2.69	16.32	10.24	1.45	82204.66
18	10.33	1.62	55.66	2.41	17.57	10.15	1.46	81472.29
19	8.77	1.92	50.41	2.36	17.11	10.38	1.45	78692.87
20	10.41	2.24	63.93	2.84	16.42	10.94	1.48	76286.37
21	9.90	2.58	50.00	2.87	15.63	10.77	1.48	78364.69
22	10.14	1.99	57.02	2.39	17.77	10.30	1.49	79585.02
23	9.62	1.81	52.87	2.05	19.56	9.89	1.50	82468.57
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	10.85	4.53	55.38	3.26	16.76	10.44	1.46	81239.70
最大值	18.91	11.27	63.93	8.35	19.56	11.03	1.51	85732.97
發生時間	13	13	20	13	23	10		2
最小值	7.34	1.62	42.88	2.05	14.19	9.89	1.43	75575.02
發生時間	11	18	16	23	13	23		15
零點偏移(率)	-0.02 %	-0.01 %	-0.02 %	0.00 %		-0.01	0.00	0.00 %
全幅偏移(率)	0.40 %	0.48 %	-0.04 %	0.38 %		-0.01	0.00	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

## P003\_樹林焚化廠CEMS系統日報表-A

報表日期: 112年03月25日

項目	#3-HCl_C	#3-CO_C	#3-NOx_C	#3-SO2_C	#3-H2O	#3-O2_C	#3-OPAC	#3-FLOW_C
單位	ppm	ppm	ppm	ppm	%	%	%	m3/Hour
小時\限標	60.00	150.00	220.00	150.00	100.00	25.00	10.00	999999.00
0	8.76	7.33	61.90	3.31	15.00	10.92	1.36	79130.02
1	9.35	4.19	61.15	3.23	14.71	11.36	1.38	80534.34
2	8.69	6.42	60.42	3.07	16.18	11.13	1.38	80183.29
3	9.79	2.45	63.17	3.23	16.83	10.41	1.38	85021.88
4	11.63	3.67	61.48	3.43	17.09	10.23	1.37	82572.95
5	10.60	5.38	54.47	3.25	15.60	10.66	1.37	82963.02
6	11.25	9.38	57.08	3.36	15.11	10.92	1.33	81273.87
7	12.18	9.65	54.85	3.93	14.01	11.29	1.34	79889.60
8	9.28	8.32	59.54	3.21	14.45	11.03	1.37	82098.34
9	11.06	14.43	59.10	3.91	13.99	11.24	1.38	83293.12
10	10.22	5.90	60.41	3.25	15.83	10.95	1.40	83216.75
11	9.76	2.80	54.86	3.07	15.09	10.95	1.40	83050.79
12	11.58	5.43	56.94	3.70	14.12	11.02	1.38	79712.04
13	13.04	6.25	56.11	4.96	14.21	11.00	1.38	78973.56
14	11.52	15.38	46.05	9.59	14.15	10.29	1.38	75010.35
15	4.98	3.98	44.24	7.19	13.15	10.79	1.35	73352.81
16	2.85	4.23	54.81	2.96	14.23	11.10	1.38	76856.91
17	7.06	2.22	56.78	2.55	15.70	10.80	1.37	79624.10
18	5.97	1.89	59.56	2.32	16.57	10.81	1.34	80581.63
19	6.88	4.61	53.66	2.43	16.15	10.61	1.37	81140.41
20	3.73	1.87	56.93	2.16	16.20	11.25	1.37	76084.52
21	5.25	5.89	49.33	2.20	16.56	10.45	1.37	82704.85
22	9.58	4.71	48.08	2.73	16.25	10.31	1.35	82686.24
23	8.86	3.53	54.43	2.47	17.71	10.27	1.36	83358.72
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平均值	8.91	5.83	56.06	3.56	15.37	10.82	1.37	80554.75
最大值	13.04	15.38	63.17	9.59	17.71	11.36	1.42	85021.88
發生時間	13	14	3	14	23	1		3
最小值	2.85	1.87	44.24	2.16	13.15	10.23	1.31	73352.81
發生時間	16	20	15	20	15	4		15
零點偏移(率)	-0.02 %	0.00 %	-0.08 %	-0.01 %		0.05	0.00	0.00 %
全幅偏移(率)	-0.61 %	-0.17 %	-0.55 %	0.08 %		0.03	-0.03	0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								