

P001 樹林焚化廠CEMS系統日報表-A 報表日期: 115年07月14日

報表日期: 115年07月14日

項目 單位 小時\限標	#1-HCl_C ppm	#1-CO_C ppm	#1-NOx_C ppm	#1-SO2_C ppm	#1-H2O %	#1-O2_C %	#1-OPAC %	#1-FLOW_C m3/Hour
0	9.11	11.81	48.37	1.49	19.80	10.66	1.29	83788.81
1	7.97	11.17	54.85	0.92	21.90	9.86	1.29	87811.86
2	10.11	11.30	60.75	1.34	20.86	10.55	1.29	84390.90
3	9.57	11.73	49.28	2.09	20.77	9.86	1.29	89531.71
4	10.47	11.16	56.51	2.29	20.10	10.17	1.29	87894.54
5	8.71	10.79	47.08	1.87	19.25	10.35	1.29	85307.14
6	9.04	11.00	52.07	1.77	19.32	10.47	1.29	86016.07
7	9.51	11.46	61.01	1.88	18.87	11.04	1.29	82207.68
8	5.65	11.05	57.36	2.57	19.74	10.55	1.27	85314.48
9	7.61	11.28	57.43	3.18	19.80	10.36	1.27	87274.10
10	8.14	11.17	61.21	3.55	18.83	10.81	1.27	85377.19
11	9.86	10.99	58.03	3.15	19.67	10.50	1.27	86616.74
12	9.38	11.58	63.01	2.70	18.97	10.98	1.26	83516.72
13	9.07	11.17	51.78	2.83	19.15	10.72	1.25	84985.35
14	9.99	11.08	56.27	2.99	18.84	10.70	1.26	85302.29
15	8.48	11.13	61.19	3.27	18.90	10.73	1.27	84928.75
16	10.99	10.65	54.98	3.10	19.56	10.12	1.26	88871.29
17	7.80	10.95	43.96	3.01	19.55	10.11	1.25	89104.98
18	9.47	11.19	60.31	3.13	18.52	10.82	1.26	84040.08
19	10.18	11.41	50.74	4.77	16.75	11.10	1.26	83455.78
20	9.04	12.71	55.91	5.20	15.91	11.25	1.27	83181.05
21	10.75	11.87	58.31	4.94	16.12	11.56	1.26	80362.83
22	11.97	11.83	54.78	4.06	16.49	11.31	1.26	82393.43
23	8.32	12.04	61.69	2.65	18.04	11.12	1.27	82429.42
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	9.22	11.36	55.70	2.86	18.99	10.65	1.27	85170.97
最 大 值	11.97	12.71	63.01	5.20	21.90	11.56	1.31	89531.71
發生時間	22	20	12	20	1	21		3
最 小 值	5.65	10.65	43.96	0.92	15.91	9.86	1.24	80362.83
發生時間	8	16	17	1	20	1		21
零點偏移(率)	-0.03 %	-0.00 %	-0.08 %	-0.00 %		0.00	-0.01	0.10 %
全幅偏移(率)	1.55 %	0.14 %	-1.25 %	0.01 %		-0.07	-0.06	0.10 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								

P003 樹林焚化廠CEMS系統日報表-A

報表日期: 115年07月14日

項目 單位 小時\限標	#3-HCl_C ppm	#3-CO_C ppm	#3-NOx_C ppm	#3-SO2_C ppm	#3-H2O %	#3-O2_C %	#3-OPAC %	#3-FLOW_C m3/Hour
0	9.90	11.37	49.83	1.87	21.04	9.03	1.31	82592.85
1	6.16	11.68	61.74	1.33	20.93	9.87	1.31	74588.96
2	8.10	12.25	61.63	1.37	19.38	10.15	1.31	75238.95
3	7.76	11.79	65.67	1.49	20.06	9.84	1.31	79625.68
4	14.60	11.82	58.63	2.71	19.17	10.24	1.30	78875.10
5	6.92	12.06	57.47	1.42	18.52	10.41	1.30	77523.09
6	4.48	12.21	57.69	1.35	17.20	10.87	1.30	74911.80
7	4.78	11.82	56.08	2.66	18.25	10.42	1.34	79357.41
8	9.60	11.82	63.82	3.11	18.67	10.20	1.32	78855.74
9	5.37	11.57	61.28	2.49	18.44	10.12	1.35	79259.47
10	8.10	11.64	54.98	2.87	18.90	10.00	1.35	78853.11
11	5.12	11.84	58.23	2.51	19.40	10.24	1.30	78151.42
12	4.69	12.01	58.42	2.37	20.21	10.19	1.31	76975.19
13	4.16	11.82	54.48	2.81	19.65	10.21	1.31	80149.15
14	8.28	11.66	60.28	2.83	18.53	10.21	1.30	79853.48
15	6.84	12.10	58.82	2.60	17.91	10.70	1.29	77050.31
16	11.01	12.02	48.33	2.56	17.15	10.38	1.33	77213.35
17	7.03	12.47	57.56	2.56	18.15	10.57	1.32	75659.32
18	3.60	11.92	59.45	2.50	18.70	10.33	1.32	81245.06
19	9.68	12.11	55.35	3.05	18.59	9.97	1.36	81949.25
20	1.84	15.20	51.51	3.11	16.12	10.79	1.35	72487.66
21	2.61	12.50	47.86	2.50	16.97	10.38	1.34	74462.64
22	3.43	12.39	51.96	2.63	16.24	10.69	1.32	73861.73
23	7.47	12.84	51.58	3.07	16.80	10.42	1.31	76317.93
監測時數	24	24	24	24	24	24	24	24
超限次數	0	0	0	0	0	0	0	0
有效時數	24	24	24	24	24	24	24	24
平 均 值	6.73	12.12	56.78	2.41	18.54	10.26	1.32	77710.78
最 大 值	14.60	15.20	65.67	3.11	21.04	10.87	1.36	82592.85
發生時間	4	20	3	8	0	6		0
最 小 值	1.84	11.37	47.86	1.33	16.12	9.03	1.29	72487.66
發生時間	20	0	21	1	20	0		20
零點偏移(率)	-0.03 %	-0.00 %	-0.01 %	0.00 %		-0.06	-0.01	-0.20 %
全幅偏移(率)	1.69 %	0.41 %	-0.09 %	-0.75 %		0.28	0.00	-0.20 %
有效比率	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %	100.00 %
備註								